

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND

BUILDING PERMIT

This is to certify that
HIGH TECH FIRE PROTECTION CO, INC.
PO BOX 156
MINOT, ME 04258

For installation at
38 PREBLE ST
TEEN SHELTER

Job ID: 2012-08-4798-FAFS

CBL: 037- F-020-001

has permission to install sprinkler and standpipes

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be

Bjankoff
Fire Prevention Officer

(58)

Code Enforcement Officer / Plan Reviewer

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
PENALTY FOR REMOVING THIS CARD

BUILDING PERMIT INSPECTION PROCEDURES

Please call 874-8703 or 874-8693 (ONLY)

or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

Final Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.



PORTLAND MAINE

Strengthening a Remarkable City, Building a Community for Life • www.portlandmaine.gov

Director of Planning and Urban Development
Jeff Levine

**Job ID: 2012-08-4798-FAFS
install sprinkler and standpipes**

**For installation at:
38 PREBLE ST
TEEN SHELTER**

CBL: 037- F-020-001

Conditions of Approval:

Fire

Gauges for Class I and III standpipe hose connections. The Fire Department requires the installer to provide two Kocheck 2 1/2" NH 45 Degree Line Gauge [LG25-45] to the Fire Department for each new Class I standpipe.

Fire department connection shall be three 2 1/2". The Fire department connection shall indicate auto sprinkler and standpipe and will require Knox locking caps.

Class I Standpipes shall be installed in accordance with the City of Portland Fire Department Regulations and NFPA 14. A signed compliance letter will be required.

The sprinkler system shall be installed in accordance with the City of Portland Fire Department Regulations and NFPA 13. A signed compliance letter will be required.

Sprinkler supervision shall be provided in accordance with NFPA 101, *Life Safety Code*, and NFPA 72, *National Fire Alarm and Signaling Code*.

Sprinkler protection shall be maintained. Where the system is to be shut down for maintenance or repair, the system shall be checked at the end of each day to insure the system has been placed back in service.

System acceptance and commissioning must be coordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.

A separate sprinkler permit is required from the State Fire Marshal's Office.

A Knox Box is required.

City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, FAX: (207) 8716

Job No: 2012-08-4798-FAFS	Date Applied: 8/23/2012	CBL: 037- F-020-001	
Location of Construction: 38 PREBLE ST	Owner Name: PREBLE STREET	Owner Address: 38 PREBLE STREET PORTLAND ME 04101	Phone:
Business Name:	Contractor Name: High Tech Fire Protection	Contractor Address: PO Box 156, Minot, ME 04258	Phone: 207-998-2551
Lessee/Buyer's Name:	Phone:	Permit Type: FIRE SUPPRESSON - Fire Supression	Zone: B-3
Past Use: Teen Shelter – Permit #2012-04-3738	Proposed Use: Same – Teen Shelter – install a fire suppression system	Cost of Work: 36000.00	CEO District:
		Fire Dept: 9/10/12 <input checked="" type="checkbox"/> Approved w/conditions <input type="checkbox"/> Denied <input type="checkbox"/> N/A	Inspection: Use Group: Type:
		Signature: <i>[Signature]</i> (58)	Signature:
Proposed Project Description: fire suppression system		Pedestrian Activities District (P.A.D.)	

Permit Taken By: Gayle	Zoning Approval
------------------------	------------------------

<p>1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.</p> <p>2. Building Permits do not include plumbing, septic or electrical work.</p> <p>3. Building permits are void if work is not started within six (6) months of the date of issuance. False informatin may invalidate a building permit and stop all work.</p>	Special Zone or Reviews <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetlands <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan <input type="checkbox"/> Maj <input type="checkbox"/> Min <input type="checkbox"/> MM Date: <i>OK w/ condition 8/30/12 JBL</i>	Zoning Appeal <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Date:	Historic Preservation <input type="checkbox"/> Not in Dist or Landmark <input type="checkbox"/> Does not Require Review <input type="checkbox"/> Requires Review <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Date: <i>9/4/12</i> <i>D. Anderson</i>
	CERTIFICATION		

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the appication is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
------------------------	---------	------	-------

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE	DATE	PHONE
---	------	-------

Entered 7/25

2012-08-4798

66



Fire Suppression System Permit

If you or the property owner owes real estate or property taxes or user charges on any property within the city, payment arrangements must be made before permits of any kind are accepted.

Installation address: 38 Preble St CBL: 037 F020

Exact location: (within structure) Teen Shelter Building

Type of occupancy(s) (NFPA & ICC): Office / Residential

Building owner: _____

Managing Supervisor: Ed Poulva License No: 515

Supervisor phone: _____ E-mail: EPoulva@fairpoint.net

Installing contractor: High Tech Fire Protection License No: 102

Contractor phone: 207-998-2551 E-mail: HTFP@fairpoint.net

The suppression work to be done will be: New: Renovation: Addition to existing system:

This is an amendment to an existing permit: Yes: NO Permit no: 2121371

NFPA Standard will this system is designed to: 13 Edition: 2010

*Non-NFPA systems are not approved for use within the City of Portland.

Download a new copy of this document from Inspection Division on-line at www.portlandmaine.gov for every submittal. Attach all design information and complete approved submittals as may be required by the State Fire Marshal's Office on 11X17 copies or electronic PDF's in addition to full sized plans.

Contractor shall verify location and type of all FDCs shall be approved in writing by the Fire Prevention Bureau.

Submit all information to the Building Inspections Department, 389 Congress Street, Room 315, Portland, Maine 04101.

Prior to acceptance of any fire protection system, a complete commissioning and acceptance test must be coordinated with all fire system contractors and the Fire Department, and proper documentation of such test(s) provided.

All installation(s) must comply with NFPA and the Fire Department Technical Standard(s).

COST OF WORK: <u>\$35,735.00</u>
PERMIT FEE: <u>\$380.00</u>
(\$10 PER \$1,000 + \$30 FOR THE FIRST \$1,000)

Applicant signature: Timothy A. Fata Date: 8-14-12

RECEIVED


AUG 23 2012

Dept. of Building Inspections
City of Portland Maine

HIGH TECH FIRE PROTECTION

PO Box 156 • MINOT, ME 04258-0156

PHONE: (207)998-2551 • FAX: (207)998-4187



Letter of Transmittal

To: Inspections Dept
Portland, Maine 04141

Date: 8-13-12	Job No.
Attention: Inspection Dept	
Re: 38 Preble St (Teen Shelter)	

We are sending you:

- Owners Manuals Preliminary Plans Asbuilt Plans Hydraulic Calculations
 Product Data Permit Check _____

Copies	Date	No.	Description
1	8-13-12		Fire Protection Drawing (FP-01& FP-02)
1	8-13-12		Hydraulic Calculations (3 rd Fl & Stand Pipe)
1	8-13-12		Payment for Permit (Check)
1	8-13-12		CD with the PDF's of the above Drawings and Calc's
1	8-13-12		Permit Application

These are Transmitted as checked below:

- For Approval For your use Return _____ corrected copy
 As requested For review and comment

Comments:

Signed : 
Tim Fortin

*Specializing in Commercial and Residential Fire Sprinkler Systems
Design • Installation • Inspection • Service*



PORTLAND MAINE

Strengthening a Remarkable City, Building a Community for Life • www.portlandmaine.gov

Receipts Details:

Tender Information: Check , BusinessName: High Tech Fire Protection, Check Number:
18252

Tender Amount: 380.00

Receipt Header:

Cashier Id: gguertin

Receipt Date: 8/23/2012

Receipt Number: 47491

Receipt Details:

Referance ID:	7779	Fee Type:	BP-Constr
Receipt Number:	0	Payment Date:	
Transaction Amount:	380.00	Charge Amount:	380.00
Job ID: Job ID: 2012-08-4798-FAFS - fire suppression system			
Additional Comments: 38 Preble St., High Tech Fire Protection			

Thank You for your Payment!



. . . Fire Protection by Computer Design

HIGH TECH FIRE PROTECTION
PO. BOX 156
MINOT, ME 04258-0258
207-998-2551

Job Name : Teen Sheter
Building : TEEN SHELTER
Location : 38 PREBLE ST
System : WET
Contract : 042712-1
Data File : Teen Shelter.WXF

Hydraulic Design Information Sheet

Name - TEEN SHELTER Date - 8-20-12
 Location - 38 PREBLE ST
 Building - TEEN SHELTER System No. - WET
 Contractor - HIGH TECH FIRE PROTECTION Contract No. - 042712-1
 Calculated By - Drawing No. - FP-01/FP-02
 Construction: (X) Combustible () Non-Combustible Ceiling Height - VARIES
 Occupancy - LIGHT HAZARD

S (X) NFPA 13 (X) Lt. Haz. Ord.Haz.Gp. () 1 () 2 () 3 () Ex.Haz.
 Y () NFPA 231 () NFPA 231C () Figure Curve

S Other

T Specific Ruling Made By Date

M	Area of Sprinkler Operation	- 900	System Type	Sprinkler/Nozzle
	Density	- .1	(X) Wet	Make GLOBE
D	Area Per Sprinkler	- 225	() Dry	Model GL5606
E	Elevation at Highest Outlet	- 43	() Deluge	Size 1/2"
S	Hose Allowance - Inside	-	() Preaction	K-Factor 5.6
I	Rack Sprinkler Allowance	-	() Other	Temp.Rat.165
G	Hose Allowance - Outside	- 100		

N Note

Calculation Flow Required - 310 Press Required - 75
 Summary C-Factor Used: 120 Overhead 140 Underground

W	Water Flow Test:	Pump Data:	Tank or Reservoir:
A	Date of Test - 10-10-97		Cap. -
T	Time of Test -	Rated Cap.-	Elev.-
E	Static Press - 102	@ Press -	
R	Residual Press - 88	Elev. -	Well
	Flow - 1342		Proof Flow
S	Elevation -		

U Location - PORTLAND STREET AND PREBLE STREET

P Source of Information - PORTLAND WATER DISTRICT

C	Commodity	Class	Location
O	Storage Ht.	Area	Aisle W.
M	Storage Method: Solid Piled	% Palletized	% Rack
M	() Single Row	() Conven. Pallet	() Auto. Storage () Encap.
S	() Double Row	() Slave Pallet	() Solid Shelf () Non
T	() Mult. Row		() Open Shelf

R K Flue Spacing Clearance:Storage to Ceiling
 A Longitudinal Transverse

G Horizontal Barriers Provided:


Water Supply Curve (C)

HIGH TECH FIRE PROTECTION
Teen Sheter

Page 2
Date 7/24/12

City Water Supply:
 C1 - Static Pressure : 102
 C2 - Residual Pressure: 88
 C2 - Residual Flow : 1342

Demand:
 D1 - Elevation : 18.623
 D2 - System Flow : 211.684
 D2 - System Pressure : 76.286
 Hose (Adj City) :
 Hose (Demand) : 100
 D3 - System Demand : 311.684
 Safety Margin : 24.774



Fittings Used Summary

HIGH TECH FIRE PROTECTION
Teen Sheter

Page 3
Date 7/24/12

Fitting Legend		1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
Abbrev.	Name																				
B	Generic Butterfly Valve	0	0	0	5	6	7.5	7	10	0	12	9	10	12	19	21	0	0	0	0	0
Cv	Check Viking D1-G1							6	10		13		20	23							
E	90° Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																			
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	90° Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
V	90° Ell Firelock #001	0	0	0	0	0	3.5	4.3	5	0	6.8	8.5	10	13	0	0	0	0	0	0	0
Zib	Wilkins 350A	Fitting generates a Fixed Loss Based on Flow																			

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

HIGH TECH FIRE PROTECTION
Teen Sheter

Page 4
Date 7/24/12

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DP1	41.0	5.6	16.14	na	22.5	0.1	225	7.0
10	43.0	K = K @ EQO1	35.36	na	22.5			
11	43.0	K = K @ EQO1	35.54	na	22.56			
12	43.0	K = K @ EQO1	36.7	na	22.92			
13	43.0	K = K @ EQO1	38.98	na	23.63			
14	43.0	K = K @ EQO1	41.02	na	24.23			
20	43.0	K = K @ EQO1	39.21	na	23.7			
21	43.0	K = K @ EQO1	39.46	na	23.77			
22	43.0	K = K @ EQO1	40.31	na	24.02			
23	43.0	K = K @ EQO1	41.43	na	24.36			
M1	43.0		41.42	na				
M2	43.0		41.84	na				
M3	43.0		43.2	na				
M4	43.0		46.98	na				
R3	43.0		53.13	na				
R2	28.0		59.76	na				
R1	18.0		64.22	na				
R	8.0		68.66	na				
B1	3.0		71.28	na				
B2	3.0		71.33	na				
UND	-4.0		77.83	na				
U1	-4.0		77.87	na				
U2	-10.0		80.5	na				
U3	-16.0		83.11	na				
TEST	0.0		76.29	na	100.0			

The maximum velocity is 13.23 and it occurs in the pipe between nodes 13 and M1

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	***** Notes *****
DP1 to EQO1	22.50 22.5	1.049 120.0 0.1619	1E 2.0 1T 5.0 0.0	2.000 7.000 9.000	16.143 17.757 1.457		K Factor = 5.60 Vel = 8.35
	0.0 22.50				35.357		K Factor = 3.78
10 to 11	22.50 22.5	1.682 120.0 0.0162	0.0 0.0 0.0	11.000 0.0 11.000	35.357 0.0 0.178		K Factor @ node EQO1 Vel = 3.25
11 to 12	22.56 45.06	1.682 120.0 0.0587	2E 9.9 0.0 0.0	9.900 9.900 19.800	35.535 0.0 1.162		K Factor @ node EQO1 Vel = 6.51
12 to 13	22.92 67.98	1.682 120.0 0.1255	2E 9.9 0.0 0.0	8.300 9.900 18.200	36.697 0.0 2.284		K Factor @ node EQO1 Vel = 9.82
13 to M1	23.62 91.6	1.682 120.0 0.2180	1T 9.9 0.0 0.0	1.300 9.900 11.200	38.981 0.0 2.442		K Factor @ node EQO1 Vel = 13.23
	0.0 91.60				41.423		K Factor = 14.23
14 to M1	24.23 24.23	1.682 120.0 0.0186	1T 9.9 0.0 0.0	11.900 9.900 21.800	41.017 0.0 0.406		K Factor @ node EQO1 Vel = 3.50
	0.0 24.23				41.423		K Factor = 3.76
20 to 21	23.70 23.7	1.682 120.0 0.0179	0.0 0.0 0.0	14.000 0.0 14.000	39.213 0.0 0.250		K Factor @ node EQO1 Vel = 3.42
21 to 22	23.77 47.47	1.682 120.0 0.0646	0.0 0.0 0.0	13.100 0.0 13.100	39.463 0.0 0.846		K Factor @ node EQO1 Vel = 6.85
22 to M2	24.02 71.49	1.682 120.0 0.1378	1T 9.9 0.0 0.0	1.200 9.900 11.100	40.309 0.0 1.530		K Factor @ node EQO1 Vel = 10.32
	0.0 71.49				41.839		K Factor = 11.05
23 to M2	24.36 24.36	1.682 120.0 0.0188	1T 9.9 0.0 0.0	11.900 9.900 21.800	41.429 0.0 0.410		K Factor @ node EQO1 Vel = 3.52
	0.0 24.36				41.839		K Factor = 3.77
M1 to M2	115.84 115.84	2.635 120.0 0.0378	0.0 0.0 0.0	11.000 0.0 11.000	41.423 0.0 0.416		Vel = 6.82

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
M2	95.84	2.635		11.800		41.839			
to		120.0		0.0		0.0			
M3	211.68	0.1153		11.800		1.361		Vel = 12.45	
M3	0.0	2.635	1V	5.903	26.900	43.200			
to		120.0		0.0	5.903	0.0			
M4	211.68	0.1153		0.0	32.803	3.783		Vel = 12.45	
M4	0.0	2.635	1V	5.903	3.500	46.983			
to		120.0	1B	9.61	23.750	3.000		* Fixed loss = 3	
R3	211.68	0.1153	1Fsp	0.0	27.250	3.143		Vel = 12.45	
			1Cv	8.237					
	0.0								
	211.68					53.126		K Factor = 29.04	
R3	211.68	4.26		12.000		53.126			
to		120.0		0.0		6.496			
R2	211.68	0.0112		12.000		0.134		Vel = 4.76	
R2	0.0	4.26		12.000		59.756			
to		120.0		0.0		4.331			
R1	211.68	0.0111		12.000		0.133		Vel = 4.76	
R1	0.0	4.26		10.000		64.220			
to		120.0		0.0		4.331			
R	211.68	0.0112		10.000		0.112		Vel = 4.76	
R	0.0	4.26		40.500		68.663			
to		120.0		0.0		2.166			
B1	211.68	0.0111		40.500		0.449		Vel = 4.76	
B1	0.0	4.26		5.000		71.278			
to		120.0		0.0		0.0			
B2	211.68	0.0112		5.000		0.056		Vel = 4.76	
B2	0.0	4.26	1V	8.954	3.000	71.334			
to		120.0	1Zib	0.0	8.954	6.364		* Fixed loss = 3.333	
UND	211.68	0.0111		0.0	11.954	0.133		Vel = 4.76	
UND	0.0	6.16	1V	10.786	10.000	77.831			
to		120.0		0.0	10.786	0.0			
U1	211.68	0.0018		0.0	20.786	0.038		Vel = 2.28	
U1	0.0	8.27	1E	28.468	20.000	77.869			
to		140.0	1G	6.326	90.148	2.599			
U2	211.68	0.0003	1T	55.354	110.148	0.036		Vel = 1.26	
U2	0.0	16.41	1T	166.859	200.000	80.504			
to		140.0		0.0	166.860	2.599			
U3	211.68	0.0		0.0	366.860	0.004		Vel = 0.32	
U3	0.0	6.16	1T	43.037	35.000	83.107			
to		140.0		0.0	43.037	-6.930			
TEST	211.68	0.0014		0.0	78.037	0.109		Vel = 2.28	

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	100.00								
	311.68				76.286				
							Qa = 100.00		
							K Factor = 35.69		



... Fire Protection by Computer Design

HIGH TECH FIRE PROTECTION
PO. BOX 156
MINOT, ME 04258-0258
207-998-2551

Job Name : Teen Sheter Stand Pipe Calc
Building : TEEN SHELTER
Location : 38 PREBLE ST
System : HOSE VALVES
Contract : 042712-1
Data File : HOSE VALVE CALC.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - TEEN SHELTER
 Location - 38 PREBLE ST
 Building - TEEN SHELTER
 Contractor - HIGH TECH FIRE PROTECTION
 Calculated By - TIM FORITN
 Occupancy - LIGHT HAZARD

Date - 8-9-12

System No. - HOSE VALVES
 Contract No. - 042712-1
 Drawing No. - FP-01/FP-02

S (X)NFPA 14 Number of Standpipes ()1 (X)2 ()3 ()4 ()
 Y ()Other
 S ()Specific Ruling Made by Date
 T
 E Flow at Top Most Outlet - 250 Gpm System Type
 M Pres. at Top Most Outlet - 21.7 Psi (X) Wet () Dry
 Flow For Ea. Additional Standpipe - 250 Gpm
 D Total Additional Flow - 450 Gpm
 E Elevation at Highest Outlet - 37.5 Feet
 S Hose Valve Connection ()1 1/2" (X)2 1/2"
 I Class Service (X)I ()II ()III
 G Note:CITY OF PORTLAND PUMPER TRUCK INFO: 1250 GPM AT 150 PSI
 N

Calculation Gpm Required 750 Psi Required 21.7 At Test
 Summary C-Factor Used: Overhead 120 Underground

W Water Flow Test: Pump Data: Tank or Reservoir:
 A Date of Test - Cap.
 T Time of Test - Rated Cap. Elev.
 E Static (Psi) - 200 @ Psi
 R Residual (Psi) - 150 Elev. Well
 Flow (Gpm) - 1250 Proof Flow Gpm
 S Elevation - 3.5
 U

P Location: PUMPER TRUCK HOOKED UP TO FIRE DEPARTMENT CONNECTION

P
 L Source of Information: CITY OF PORTLAND
 Y


Water Supply Curve (C)

HIGH TECH FIRE PROTECTION
Teen Sheter Stand Pipe Calc

Page 2
Date 7/24/12

City Water Supply:
 C1 - Static Pressure : 200
 C2 - Residual Pressure: 150
 C2 - Residual Flow : 1250

Demand:
 D1 - Elevation : 16.241
 D2 - System Flow :
 D2 - System Pressure : 21.744
 Hose (Adj City) :
 Hose (Demand) : 750
 D3 - System Demand : 750
 Safety Margin : 158.823



Fittings Used Summary

HIGH TECH FIRE PROTECTION
Teen Sheter Stand Pipe Calc

Page 3
Date 7/24/12

Fitting Legend

Abbrev. Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
--------------	-----	-----	---	-------	-------	---	-------	---	-------	---	---	---	---	----	----	----	----	----	----	----

Units Summary

Diameter Units	Inches
Length Units	Feet
Flow Units	US Gallons per Minute
Pressure Units	Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with *. The fittings marked with a * show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a * will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

Pressure / Flow Summary - STANDARD

HIGH TECH FIRE PROTECTION
 Teen Sheter Stand Pipe Calc

Page 4
 Date 7/24/12

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
HV1	37.5		0.0	na	250.0			
HV2	25.5		5.38	na	250.0			
S	37.5		0.11	na				
S1	25.5		5.49	na				
S2	12.5		11.77	na				
S3	9.0		13.94	na				
S4	9.0		14.02	na				
S5	9.0		16.06	na				
HV3	37.5		4.55	na	250.0			
R3	37.5		4.63	na				
R2	25.5		9.88	na				
R1	12.5		15.69	na				
S6	3.5		19.71	na				
TEST	0.0		21.74	na				

The maximum velocity is 16.88 and it occurs in the pipe between nodes S6 and TEST

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
HV1	250.00	2.469	0.0	0.500	0.0			Qa = 250	
to		120.0	0.0	0.0	0.0				
S	250.0	0.2160	0.0	0.500	0.108			Vel = 16.75	
	0.0								
	250.00				0.108			K Factor = 760.73	
HV2	250.00	2.469	0.0	0.500	5.379			Qa = 250	
to		120.0	0.0	0.0	0.0				
S1	250.0	0.2140	0.0	0.500	0.107			Vel = 16.75	
	0.0								
	250.00				5.486			K Factor = 106.74	
S	250.00	4.26	0.0	12.000	0.108				
to		120.0	0.0	0.0	5.197				
S1	250.0	0.0151	0.0	12.000	0.181			Vel = 5.63	
S1	250.00	4.26	0.0	12.000	5.486				
to		120.0	0.0	0.0	5.630				
S2	500.0	0.0546	0.0	12.000	0.655			Vel = 11.25	
S2	0.0	4.26	0.0	12.000	11.771				
to		120.0	0.0	0.0	1.516				
S3	500.0	0.0545	0.0	12.000	0.654			Vel = 11.25	
S3	0.0	4.26	0.0	1.500	13.941				
to		120.0	0.0	0.0	0.0				
S4	500.0	0.0547	0.0	1.500	0.082			Vel = 11.25	
S4	0.0	4.26	0.0	37.300	14.023				
to		120.0	0.0	0.0	0.0				
S5	500.0	0.0545	0.0	37.300	2.033			Vel = 11.25	
S5	0.0	4.26	0.0	23.300	16.056				
to		120.0	0.0	0.0	2.382				
S6	500.0	0.0545	0.0	23.300	1.270			Vel = 11.25	
	0.0								
	500.00				19.708			K Factor = 112.63	
HV3	250.00	2.635	0.0	0.500	4.549			Qa = 250	
to		120.0	0.0	0.0	0.0				
R3	250.0	0.1580	0.0	0.500	0.079			Vel = 14.71	
R3	0.0	4.26	0.0	3.500	4.628				
to		120.0	0.0	0.0	5.197				
R2	250.0	0.0151	0.0	3.500	0.053			Vel = 5.63	
R2	0.0	4.26	0.0	12.000	9.878				
to		120.0	0.0	0.0	5.630				
R1	250.0	0.0152	0.0	12.000	0.182			Vel = 5.63	
R1	0.0	4.26	0.0	8.000	15.690				
to		120.0	0.0	0.0	3.898				
S6	250.0	0.0150	0.0	8.000	0.120			Vel = 5.63	

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 250.00					19.708		K Factor = 56.31	
S6 to TEST	750.00 750.0	4.26 120.0 0.1156	0.0 0.0 0.0	4.500 0.0 4.500	19.708 1.516 0.520			Vel = 16.88	
	0.0 750.00					21.744		K Factor = 160.84	