

592-596 CONGRESS STREET



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date Oct. 14, 19 80
Receipt and Permit number A 51783

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of
Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 594 Congress St.

OWNER'S NAME: Carbo Co.

ADDRESS: _____

		FEE	
OUTLETS:			
Receptacles	Switches	Plugmold _____ ft. TOTAL <u>1-30</u> <u>3.00</u>	
FIXTURES: (number of)			
Incandescent <u>6</u>	Flourescent <u>2</u> (not strip)	TOTAL <u>1-10</u> <u>3.00</u>	
Strip Flourescent _____	ft.		
SERVICES			
Overhead <u>x</u>	Underground	Temporary	TOTAL amperes <u>100</u> . <u>3.00</u>
METERS (number of) <u>1</u>			<u>.50</u>
MOTORS: (number of)			
Fractional _____			
1 HP or over _____			
RESIDENTIAL HEATING			
Oil or Gas (number of units) _____			
Electric (number of rooms) _____			
COMMERCIAL OR INDUSTRIAL HEATING:			
Oil or Gas (by a main boiler) _____			
Oil or Gas (by separate units) _____			
Electric Under 20 kws <u>x</u> Over 20 kws _____ <u>5.00</u>			
APPLIANCES (number of)			
Ranges _____	Water Heaters _____ <u>x</u>		
Cook Tops _____	Disposals _____		
Wall Ovens _____	Dishwashers _____		
Dryers _____	Compactors _____		<u>3.00</u>
Fans _____ <u>x</u>	Others (denote) _____		<u>5.00</u>
TOTAL <u>22.50</u>			
MISCELLANEOUS: (number of)			
Branch Panels _____			
Transformers _____			
Air Conditioners Central Unit <u>x</u> <u>5.00</u>			
Separate Units (windows) _____			
Signs 20 sq. ft. and under _____			
Over 20 sq. ft. _____			
Swimming Pools Above Ground _____			
In Ground _____			
Fire/Burglar Alarms Residential _____			
Commercial _____			
Heavy Duty Outlets, 220 Volt (such as welders) 30 amps and under _____			
over 30 amps _____			
Circus, Fairs, etc. _____			
Alterations to wires _____			
Repairs after fire _____			
Emergency Lights, battery _____			
Emergency Generators _____			
INSTALLATION FEE DUE: _____			
FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT ... DOUBLE FEE DUE: _____			
FOR REMOVAL OF A "STOP ORDER" (304-16.b) ... _____			
TOTAL AMOUNT DUE: <u>22.50</u>			

INSPECTION:

done

, 19__; or Will Call _____

CONTRACTOR'S NAME: Jim McGuire

ADDRESS: 1 Malison St. So. Windham, Me.

TEL: 892-2419

MASTER LICENSE NO: 3967

LIMITED LICENSE NO: _____

SIGNATURE OF CONTRACTOR:

James J. McGuire

INSPECTOR'S COPY — WHITE

OFFICE COPY — CANARY

CONTRACTOR'S COPY — GREEN

PROGRESS INSPECTIONS:	
	10-16-80
	10-24-80
	11-18-80
	11-24-80

CODE
COMPLIANCE
COMPLETED

REMARKS:

ELECTRICAL INSTALLATIONS —

Permit Number	517783
Location	594 Congress St
Owner	Carbo Co.
Date of Permit	10-14-80
Final Inspection	11-24-80
By Inspector	W. H. H. /
Permit Application Register Page No.	68



APPLICATION FOR PERMIT

B.O.C.A. USE GROUP

B.O.C.A. TYPE OF CONSTRUCTION

ZONING LOCATION

PORTLAND, MAINE, May 21, 1980

PERMIT ISSUED

JUN 11 1980

00 94

CITY of PORTLAND

To the DIRECTOR OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION 594 Congress St. Fire District #1 ☐ #2 ☐
1. Owner's name and address Carbo 82 Exchange St. Telephone
2. Lessee's name and address Telephone
3. Contractor's name and address Allied Constr. 9 Circus Time Rd. Telephone 772-2888
4. Architect So. Portland Plans No. of sheets
Proposed use of building Canal Bank No. families
Last use drug store No. families
Material No. stories Heat Style of roof Roofing
Other buildings on same lot
Estimated contractual cost \$ 40,000. Fee \$ 181.
6-7-80

FIELD INSPECTOR—Mr.

GENERAL DESCRIPTION

Telephone is for:

@ 775-5451

Building

Ext. 234

To make renovations as per plan

Ga.

Masonry Bldg.

Metal Bldg.

Alterations

Demolitions

Change of Use

Other

Stamp of Special Conditions

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

PERMIT IS TO BE ISSUED TO 1 ☒ 2 ☐ 3 ☐ 4 ☐

Other:

DETAILS OF NEW WORK

Is any plumbing involved in this work? Is any electrical work involved in this work?
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber—Kind Dressed or full size? Corner posts Sills
Size Girder Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor 2nd 3rd roof
On centers: 1st floor 2nd 3rd roof
Maximum span: 1st floor 2nd 3rd roof
If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No. cars now accommodated on same lot to be accommodated . . . number commercial cars to be accommodated . . .
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY:

DATE

BUILDING INSPECTION—PLAN EXAMINER

ZONING:

BUILDING CODE:

Fire Dept.:

Health Dept.:

Others:

MISCELLANEOUS

Will work require disturbing of any tree on a public street? . .

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? . . yes..

Signature of Applicant

Phone #

Type Name of above

David Cook

1 ☐ 2 ☐ 3 ☐ 4 ☐

Other

and Address

FIELD INSPECTOR'S COPY

801 394

594 Comps. &

Carthage, (General Banks)

6-11-80

1945-1946

12. In the following find



APPLICATION FOR PERMIT

PERMIT ISSUED

B.O.C.A. USE GROUP

B.O.C.A. TYPE OF CONSTRUCTION

ZONING LOCATION

PORTLAND, MAINE, Aug. 27, 1980

00 681

CITY OF PORTLAND

To the DIRECTOR OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION 594 Congress Street - 2nd floor Fire District #1 ☐ #2 ☐
1. Owner's name and address Carbo Co. - 85 Exchange St. Telephone 772-1333
2. Lessee's name and address Telephone
3. Contractor's name and address Allied Constr. - P.O. Box 1396 Telephone 772-2888
4. Architect Specifications Plans No. of sheets
Proposed use of building undecided No. families
Last use drug store No. families
Material N stories Heat Style of roof Roofing
Other buildings on same lot
Estimated construction cost \$ 10,000 Fee \$ 46.00

FIELD INSPECTOR—Mr.

GENERAL DESCRIPTION

Application is for:

@ 775-5451

elling

Ext. 234

Garage

Masonry Bldg.

Metal Bldg.

Alterations

Demolitions

Change of Use

Other

To make alterations to 2nd floor of building as per plans. 2 sheets of plans. no structural changes.

Stamp of Special Conditions

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

PERMIT IS TO BE ISSUED TO 1 ☐ 2 ☐ 3 ☒ 4 ☐

Other:

DETAILS OF NEW WORK

Is any plumbing involved in this work? Is any electrical work involved in this work?
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber—Kind Dressed or full size? Corner posts Sills
Size Girder Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor 2nd 3rd roof
On centers: 1st floor 2nd 3rd roof
Maximum span: 1st floor 2nd 3rd roof
If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No. cars now accommodated on same lot, to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY:

DATE

MISCELLANEOUS

BUILDING INSPECTION—PLAN EXAMINER

Will work require disturbing of any tree on a public street?

ZONING:

BUILDING CODE

Fire Dept.:

Health Dept.:

Others:

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed?

Signature of Applicant

David Cook

Phone # same

Type Name of above

David Cook

Allied Construction

1 ☐ 2 ☐ 3 ☒ 4 ☐

Other

and Address


FIELD INSPECTOR'S COPY

NOTES

2-2 a notice of work stoppage -
probably around 11:20 AM
on 2/2/81. The work stoppage
was by the
✓

Permit No. 20/681
Location 294 Longview St.
Owner Carter, Inc.
Date of permit 2-2-81
Approved 8-28-80 J. H. [Signature]





2ND FLOOR TOILETS CARGO H. H. AAY

RELOCATED

RECEIVED
AUG 27 1980
DEPT. OF BLDG. INSP.
CITY OF PORTLAND



APPLICATION FOR PERMIT
DEPARTMENT OF BUILDING INSPECTIONS SERVICES
ELECTRICAL INSTALLATIONS

Date July 22, 19 80
Receipt and Permit number A 51519

To the CHIEF ELECTRICAL INSPECTOR, Portland, Maine:

The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the Portland Electrical Ordinance, the National Electrical Code and the following specifications:

LOCATION OF WORK: 594 Congress St.

OWNER'S NAME: Canal Bank

ADDRESS Canal Plaza

FEES

OUTLETS:

Receptacles _____ Switches _____ Plugmold _____ ft. TOTAL _____

FIXTURES: (number of)

Incandescent _____ Fluorescent X (not strip) TOTAL 30

5.00

Strip Fluorescent _____ ft. _____

3.00

SERVICES:

Overhead _____ Underground X Temporary _____

TOTAL amperes 200

2.00

METERS: (number of)

4

MOTORS (number of)

Fractional _____

1 HP or over _____

RESIDENTIAL HEATING:

Oil or Gas (number of units) _____

Electric (number of rooms) _____

COMMERCIAL OR INDUSTRIAL HEATING:

Oil or Gas (by a main boiler) _____

Oil or Gas (by separate units) _____

Electric Under 20 kws _____

Over 20 kws 27kw

10.00

APPLIANCES: (number of)

Ranges _____

Cook Tops _____

Wall Ovens _____

Dryers _____

Fans _____

Water Heaters _____

Disposals _____

Dishwashers _____

Compactors _____

Others (denote) _____

TOTAL _____

MISCELLANEOUS: (number of)

Branch Panels _____

Transformers _____

Air Conditioners Central Unit X

Separate Units (windows) _____

5.00

Signs 20 sq. ft. and under _____

Over 20 sq. ft. X

5.00

Swimming Pools Above Ground _____

In Ground _____

Fire/Burglar Alarms Residential _____

Commercial _____

Heavy Duty Outlets, 220 Volt such as welders) 30 amps and under _____

over 30 amps _____

Circus, Fairs, etc. _____

Alterations to wires _____

Repairs after fire _____

Emergency Lights, battery _____

Emergency Generators _____

INSTALLATION FEE DUE: _____

FOR ADDITIONAL WORK NOT ON ORIGINAL PERMIT DOUBLE FEE DUE: _____

FOR REMOVAL OF A "STOP ORDER" (304-16.b) TOTAL AMOUNT DUE: 30.00

INSPECTION:

Will be ready on _____, 19____; or Will Call XX

CONTRACTOR'S NAME: A. W. Sewall Co

ADDRESS: Scarborough, Me.

TEL: mk 883-3471

MASTER LICENSE NO.: 3306

LIMITED LICENSE NO.: _____

SIGNATURE OF CONTRACTOR: A. W. Sewall

INSPECTOR'S COPY — WHITE

OFFICE COPY — CANARY

CONTRACTOR'S COPY — GREEN



APPLICATION FOR PERMIT

B.O.C.A. USE GROUP

B.O.C.A. TYPE OF CONSTRUCTION

00 228

PERMIT ISSUED

APR 23 1980

ZONING LOCATION _____ PORTLAND, MAINE, April 18, 1980

CITY of PORTLAND

To the DIRECTOR OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following provisions:

LOCATION 592 Congress Street - 2nd & 3rd floors Fire District #1 ☐ #2 ☐
1 Owner's name and address J. B. Brown - 57 Exchange St. Telephone 774-6908
2 Lessee's name and address Allied Shoe Telephone
3 Contractor's name and address F. W. Cunningham & Sons Inc. Telephone 775-0246
4 Architect 81 Commercial Specifications Plans No. of sheets
Proposed use of building No. families
Last use No. families
Material No. stories Heat Style of roof Roofing
Other buildings on same lot

Estimated contractual cost \$ 54,500 Fee \$ 248.50

FIELD INSPECTOR—Mr. Marge GENERAL DESCRIPTION ch of use 15.00

This application is for: @ 775-5451 pd. 246.25 bal. 17.25 4.23-80

Demolition Ext. 234 Change of use from department store

Garage to office area, with alterations

Masonry Bldg. as per plans. 3 sheets of plans.

Metal Bldg. Stamp of Special Conditions

Alterations

Demolitions

Change of Use with alterations

Other:

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

PERMIT IS TO BE ISSUED TO 1 ☐ 2 ☐ 3 ☒ 4 ☐

Other:

DETAILS OF NEW WORK

Is any plumbing involved in this work? Is any electrical work involved in this work?

Is connection to be made to public sewer? If not, what is proposed for sewage?

Has septic tank notice been sent? Form notice sent?

Height average grade to top of plate Height average grade to highest point of roof

Size, front depth No. stories solid or filled land? earth or rock?

Material of foundation Thickness, top bottom cell

Kind of roof Rise per foot Roof covering

No. of chimneys Material of chimneys of Kind of heat fuel

Framing Lumber—Kind Dressed or full size? Corner posts Sills

Size Girder Columns under girders Size Max. on centers

Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.

Joists and rafters: 1st floor 2nd 3rd roof

On centers: 1st floor 2nd 3rd roof

Maximum span: 1st floor 2nd 3rd roof

If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No. cars now accommodated on same lot, to be accommodated number commercial cars to be accommodated

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY: DATE MISCELLANEOUS

BUILDING INSPECTION—PLAN EXAMINER Will work require disturbing of any tree on a public street?

ZONING:

BUILDING CODE: Will there be in charge of the above work a person competent

Fire Dept.: to see that the State and City requirements pertaining thereto

Health Dept.: are observed?

Others:

Signature of Applicant F. W. Cunningham & Sons Inc. Phone # same

Type Name of above F. W. Cunningham & Sons Inc. 1 ☐ 2 ☐ 3 ☐ 4 ☒

Other

and Address

OFFICE FILE COPY



APPLICATION FOR PERMIT

PERMIT ISSUED

B.O.C.A. USE GROUP

B.O.C.A. TYPE OF CONSTRUCTION 00 034

FEB 21 1980

ZONING LOCATION PORTLAND, MAINE, Feb. 20, 1980

CITY of PORTLAND

To the DIRECTOR OF BUILDING & INSPECTION SERVICES, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect, alter, repair, demolish, move or install the following building, structure, equipment or change use in accordance with the Laws of the State of Maine, the Portland B.O.C.A. Building Code and Zoning Ordinance of the City of Portland with plans and specifications, if any, submitted herewith and the following specifications:

LOCATION 594 Congress St.

1. Owner's name and address Portland Landmarks -165 State Street Telephone 774-5561
2. Lessee's name and address
3. Contractor's name and address F.P. & C.H. Murray, P.O. Box 2297 Telephone 799-8136
4. Architect Specifications Plans No. of sheets
Proposed use of building drug store No. families
Last use No. families
Material No. stories Heat Style of roof Roofing
Other buildings on same lot
Estimated contractual cost \$ 95,000. Fee \$ 428.50

FIELD INSPECTOR—Mr. GENERAL DESCRIPTION

This application is for: @ 775-5451 Ext. 234 To remove non bearing partitions, and renovate window areas.

Dwelling
Garage
Masonry Bldg.
Metal Bldg.
Alterations
Demolition
Change of Use
Other
Stamp of Special Conditions

NOTE TO APPLICANT: Separate permits are required by the installers and subcontractors of heating, plumbing, electrical and mechanicals.

PERMIT IS TO BE ISSUED TO 1 2 3 4
Other:

DETAILS OF NEW WORK

Is any plumbing involved in this work? Is any electrical work involved in this work?
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber—Kind Dressed or full size? Corner posts Sills
Size Girder Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor 2nd 3rd roof
On centers: 1st floor 2nd 3rd roof
Maximum span: 1st floor 2nd 3rd roof
If one story building with masonry walls, thickness of walls? height?

IF A GARAGE

No. cars now accommodated on same lot, to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

APPROVALS BY:

DATE

MISCELLANEOUS

BUILDING INSPECTION—PLAN EXAMINER Will work require disturbing of any tree on a public street?
ZONING:
BUILDING CODE: Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes
Fire Dept.:
Health Dept.:
Others:

Signature of Applicant C.H. Murray Phone #
Type Name of above C.H. Murray 1 2 3 4
Other
and Address

FIELD INSPECTOR'S COPY

NOTES
 4-3-80 most of new windows is -
 Still working on exterior -
 5-21-80 Mostly finished with
 work - is done. Some paint
 work on exterior - inside ready
 4 waiting for tenant to decide
 on specific interior provisions
 See permit for final work
 1 Sept like one for upstairs

work

Permit No. 80/957
 Location 594 Young Street
 Owner 2000 and 2000
 Date of permit 2-20-80
 Approved 2-21-80
 Interior application
 2000 and 2000

Date Issued **6-12-72**
Portland Plumbing Inspector
By ERNOLD R GOODWIN

App. First Insp.

Date _____

By

App. Final Insp.

Date _____

By

Type of Bldg.

- ☐ Commercial
☐ Residential
☐ Single
☐ Multi Family
☐ New Construction
☐ Remodeling

PERMIT TO INSTALL PLUMBING

Address **594** ~~594~~ ~~594~~ ~~594~~

Installation For **Rest.**

Owner of Bldg Harris of Hay Ave

Owner's Address **SAME**

Plumber: **Reuben Katz**

NEW	REP'L	L73 Neal St.
-----	-------	---------------------

PERMIT NUMBER

Date **6-12-72**

[illegible]

TOTAL	1	2.00
-------	---	------

Building and Inspection Services Dept.: Plumbing Inspection



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR
HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, May 26, 1972

PERMIT ISSUED

MAY 26 1972

0588

CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 594 Congress St. Use of Building Drug store No. Stories New Building
Existing "
Name and address of owner of appliance H. H. Hayak Drug Store
Installer's name and address H. J. Katz 173 Neal St. Telephone 773-8343

General Description of Work

To install oil fired hot water heater

IF HEATER, OR POWER BOILER

Location of appliance basement Any burnable material in floor surface or beneath? no
If so, how protected? Kind of fuel? oil
Minimum distance to burnable material, from top of appliance or casing top of furnace
From top of smoke pipe From front of appliance From sides or back of appliance
Size of chimney flue 8x10 Other connections to same flue no
If gas fired, how vented? Rated maximum demand per hour
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion?

IF OIL BURNER

Name and type of burner Labelled by underwriters' laboratories?
Will operator be always in attendance? Does oil supply line feed from top or bottom of tank?
Type of floor beneath burner Size of vent pipe
Location of oil storage Number and capacity of tanks
Low water shut off Make No.
Will all tanks be more than five feet from any flame? How many tanks enclosed?
Total capacity of any existing storage tanks for furnace burners

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance From sides and back From top of smokepipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

30 gal. Bock heater - Und. Label

Amount of fee enclosed? \$4.00 (\$2.00 for one heater, etc., \$1.00 additional for each additional heater, etc., in same building at same time)

APPROVED:

O.K. E. J. 5/26/72

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? Yes

H. J. Katz

Signature of Installer

Daniel S. Campbell

Leo Campbell #

CS 300

INSPECTION COPY

Permit No. 784 0588

Location 594 Congress St

Owner H. H. Hays Albany Alaska

Date of permit 5/26/75

Notif. closing-in


Inspn. closing-in


Final Notif.

E. E.
Permit Inspn. SAM

Cert. of Occupancy issued

NOTES

7-5-72 0-3




H. H. Hays:

This kitchen range on
3'd floor has been in
operation over 20 years
& until moved or replaced
can not come under
bdg. code regulations

Opinion

[Signature]

File 594 Congress

REFERRAL MEMORANDUM
HEALTH DEPARTMENT

To: Mr. Gerald Mayberry
From: N.D. McDowell
Date: 1/27/67
Subject: Ventilation H.H. Hays and State Drug

Conditions or Defects: H.H. Hays Drug Store has commercial cooking equipment in their 3rd floor kitchen which is not ventilated as required by the building code.

The State Drug Store has the same problem with a range in their cellar food preparation area.


Sanitarian

The responsible department or division is requested to reply on this form and return the form to the Environmental Health Division.

Reply:

Date:

Division or Department Head

Instructions: Sanitarians will complete this form in triplicate retaining one copy for the district file and two copies to the central office. Central office will retain one copy on their file and the original will be sent to the responsible division or city department.

A.P.- 594 Congress St.

Jan. 23, 1967

Haley's Metal Shop
539 Elm Street
Biddeford, Maine

cc to: Hay's Drug Store
594 Congress Street

Gentlemen:

Permit to install air conditioning system in store at the above named location is not issuable at this time. The 5-ton A.C. unit, weight 620#, is to be located on the second floor. We will need to know the framing of this area of the second floor as well as the location of the unit in relation to the framing.

With this information at hand we may be able to further process this application.

Framing OK
mm

Very truly yours,

Archie L. Seekins
Deputy Director Building & Inspection Services

ALS:m

B3 BUSINESS ZONE

PERMIT ISSUED
00053

JAN 27 1967

CITY of PORTLAND



APPLICATION FOR PERMIT

Class of Building or Type of Structure Second Class
Portland, Maine, January 1, 1967

To the INSPECTOR OF BUILDINGS, PORTLAND, MAINE

The undersigned hereby applies for a permit to erect alter repair demolish install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code and Zoning Ordinance of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 594 Congress St. Within Fire Limits? Dist. No.
Owner's name and address Hay's Drug Store, 594 Congress St. Telephone
Lessee's name and address Telephone
Contractor's name and address Haley's Metal Shop, 539 Elm St., Biddeford Telephone
Architect Specifications Plans yes No. of sheets
Proposed use of building Store No. families
Last use families
Material No. stories Heat Style of roof Roofing
Other buildings on same lot Fee \$ 5.00
Estimated cost \$

General Description of New Work

To install air conditioning system as per plan

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor. PERMIT TO BE ISSUED TO Haley's Metal Shop

Details of New Work

Is any plumbing involved in this work? Is any electrical work involved in this work?
Is connection to be made to public sewer? If not, what is proposed for sewage?
Has septic tank notice been sent? Form notice sent?
Height average grade to top of plate Height average grade to highest point of roof
Size, front depth No. stories solid or filled land? earth or rock?
Material of foundation Thickness, top bottom cellar
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining Kind of heat fuel
Framing Lumber—Kind Dressed or full size? Corner posts Sills
Size Girder Columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 4x16" O. C. Bridging in every floor and flat roof span over 8 feet.
Joists and rafters: 1st floor, 2nd, 3rd, roof
On centers: 1st floor, 2nd, 3rd, roof
Maximum span: 1st floor, 2nd, 3rd, roof
If one story building with masonry walls, thickness of walls? height?

If a Garage

No. cars now accommodated on same lot, to be accommodated number commercial cars to be accommodated
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building?

Miscellaneous

Will work require disturbing of any tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes
Hay's Drug Store
Haley's Metal Shop

APPROVED:


CS 501

INSPECTION COPY

Signature of owner By:

Permit No. 61785
Location 594 Green Street
Owner Hay's Drug Store
Date of permit 1/27/67
Notif. closing-in
Inspn. closing-in
Final Notif.
Final Inspn.
Cert. of Occupancy issued
Staking Out Notice
Form Check Notice

NOTES

3-29-67 Completed *DP*




FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT FOR
HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, December 15, 1965

PERMIT ISSUED
DEC 17 1965
CITY of PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 594 Congress Street Use of Building Store No. Stories 2 New Building Existing
Name and address of owner of appliance H.H. Hays Drug Co., 594 Congress St.
Installer's name and address Aaskov Plumbing & Heating Co., 501 Summit St Telephone 797-2523

General Description of Work

To install oil-fired domestic hot water heater replacing gas-fired heater
Texaco Fire Chief Model TJ 125-3

IF HEATER, OR POWER BOILER

Location of appliance basement Any burnable material in floor surface or beneath? no
If so, how protected? Kind of fuel? oil
Minimum distance to burnable material, from top of appliance or casing top of furnace 12 1/2 ft 10"
From top of smoke pipe 16" From front of appliance 4" From sides or back of appliance 8"
Size of chimney flue 8x8 Other connections to same flue none
If gas fired, how vented? Rated maximum demand per hour
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion?

IF OIL BURNER

Name and type of burner Paragon Labelled by underwriters' laboratories? yes
Will operator be always in attendance? Does oil supply line feed from top or bottom of tank? bottom
Type of floor beneath burner concrete Size of vent pipe
Location of oil storage basement Number and capacity of tanks existing
Low water shut off Make No.
Will all tanks be more than five feet from any flame? How many tanks enclosed?
Total capacity of any existing storage tanks for furnace burners

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance From sides and back From top of smokepipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Boam over smoke pipe already shielded PD

Amount of fee enclosed? 2.00 (\$2.00 for one heater, etc., \$1.00 additional for each additional heater, etc., in same building at same time.)

APPROVED:

O.K. 17-16-65 PD

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Aaskov Plumbing & Heating Co.

Signature of Installer By:

Dan Aaskov

CS 300

INSPECTION COPY


PH

Permit No. 1381
 Location 794 Longman Drive
 Owner W. H. Longman Co.
 Date of permit 11/17/61
 Approved _____

NOTES

1	Fill Pipe	
2	Vent Pipe	
3	Kind of Heat	
4	Butter Rtg. No.	
5		
6		
7		
8		
9		
10		
11		
12		
13		
14		
15		
16		

1-16 66 Completed PH



15365

TOTAL	2.00
-------	------

PORTLAND HEALTH DEPT. PLUMBING INSPECTION

584 Congress St.

B-3

11/1/65

Alma

4' x 6' 4" Projecting Sign

✓ Zone - B-3

✓ Flashing - Steady lighting

✓ Green Sidewalk

3. Code

Weight 150 lb

1- Bolts - 3/4" - thru bolt

2- Sign - 14" above sidewalk

4.6" from edge of sidewalk

✓ Sign - 51 1/2" projection

✓ Sign - 7/8"

✓ 7/8" thickness

✓ Angles

Bottom of sign - Lag bolts

✓ 2- Plexiglass faces

○

WRITTEN CONSENT AND AGREEMENT RELATING TO A CERTAIN SIGN PROPOSED TO BE

ERECTED PROJECTING OVER A PUBLIC SIDEWALK FROM THE PREMISES

AT 5th Congress St. IN PORTLAND, MAINE


Shaw Bros. Inc., being the owner of the premises at 5th Congress St. in Portland, Maine hereby gives consent to the erection of a certain sign owned by Coca-Cola Co. projecting over the public sidewalk from said premises as described in application to the Inspector of Buildings of Portland, Maine for a permit to cover erection of said sign;

And in consideration of the issuance of said permit Shaw Bros. Inc., owner of said premises, in event said sign shall cease to serve the purpose for which it was erected or shall become dangerous and in event the owner of said sign shall fail to remove said sign or make it permanently safe in case the sign still serves the purpose for which it was erected, hereby agrees for himself or itself, for his heirs, its successors, and his or its assigns, to completely remove said sign within ten days of notice from said Inspector of Buildings that said sign is in such condition and of order from him to remove it.

In Witness whereof the owner of said premises has signed this consent and agreement this 4th day of January, 1965.

Anna M. Viatile
Witness

Shaw Bros. Inc.
By Henry M. Shaw, Jr.
Owner





2. sq. ft. plexiglass- Und. Label B3 BUSINESS ZONE

APPLICATION FOR PERMIT TO ERECT
SIGN OVER PUBLIC SIDEWALK OR STREET

PERMIT ISSUED
00052
CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

Portland, Maine, Jan. 7, 1965

The undersigned hereby applies for a permit to erect the following described sign extending over a public sidewalk or street in accordance with the Building Code of the City of Portland, and the following specifications:

Location: 594 Congress St. Within Fire Limits? Dist. No.
Owner of building to which sign is to be attached Schwartz, Inc., 10 Congress Sq.
Name and address of owner of sign Hay's Drug Store, 594 Congress St.
Contractor's name and address Coyne Sign Co., 195 St. John St. Telephone
When does contractor's bond expire? Dec., 1965

Information Concerning Building

No. stories 3 Material of wall to which sign is to be attached brick

Details of Sign and Connections

Building owner's consent and agreement filed with application yes
Electric? yes Vertical dimension after erection 4' Horizontal 6' 4"
Weight 150 lbs. Will there be any hollow spaces? yes Any rigid frame? yes
Material of frame angle iron No. advertising faces 2 material plastic
No. rigid connections 4 Are they fastened directly to frame of sign? yes
No. through bolts 2 Size 3/4" Location, top or bottom top
No. guys 1 material cable Size 5/16
Minimum clear height above sidewalk or street 14'
Maximum projection into street 5' 6"

A. A. S.
INSPECTION COPY

Signature of contractor

J. S. Coyne

Fee \$ 2.00

mm

2/16

Permit No. 65/53

Location 594 Oregon Street

Owner Hay's Drug Store

Date of permit 1/11/65


Sign Contractor

Final Inspn. 1/29/65

1/13/65 - NOTES Shop
inspected E.S.B.

1/18/65 Not hung yet.
E.S.B.

1/29/65 - work done.
E.S.B.




594 Congress St.

H H Hay Son

Lynn, The Painter


(See 27 Essex St.)



FREE ST. 36/1320

131/825

15-0



ELECTRIC SIGN

594 CONGRESS ST. UPPER STORE



GENERAL BUSINESS ZONE

PERMIT ISSUED
Permit No. 0825

APPLICATION FOR PERMIT TO ERECT SIGN
OVER PUBLIC SIDEWALK OR STREET

Portland, Maine, May 20, 1931

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect the following described sign extending over a public sidewalk or street in accordance with the Building Code of the City of Portland, and the following specifications:

Location 334 Congress Street Ward E Within Fire Limits? Yes Dist. No. 1

Owner of building to which sign is to be attached H. H. Hay Lens, 334 Congress St.

Name and address of owner of sign Thomas Skinner Co. 127 Main St. So. Port.

Contractor's name and address Telephone

When does contractor's bond expire? February 1932

Information Concerning Building

No. stories 3 Material of wall to which sign is to be attached Brick

Details of Sign and Connections

Electric? Yes Vertical dimension after erection 4' 12" Horizontal 4' 0"

Weight 100 lbs., Will there be any hollow spaces? Yes Any rigid frame? Yes

Material of frame angle iron No. advertising faces 2 material metal

No. rigid connections 2 Are they fastened directly to frame of sign? Yes

No. through bolts 2 Size 5/8" C/A Location, top or bottom top and bottom

No. guys 5 material cable Size 1"

Minimum clear height above sidewalk or street 12'

Maximum projection into street 4' 6"

Thomas Skinner Co.

Fee \$ 1.00

Signature of contractor By


G. T. McLeannick

INSPECTION COPY Oliver T. Sanborn

CHIEF OF FIRE DEPT.

Final Inspn.

5/20/31 - *Supervised by permit 96/1320*
 says that in part of
 sign or signs will be
 closed to the side of the
 sidewalk. A. J. S.
 6/3/31 - I was in
 in widow's letter was
 in the same way
 thing about to take
 centering - *copy*
 1/7/32 - *Mr. Mac*
 told that the best
 go to the right
 9/22/34 - *Mr. Mac*
 - *Mr. Mac*
 - *Mr. Mac*



← WALL

15'-0"

ELECTRIC SIGN

93-5 FREE ST. UPPER STORE.



(G) GENERAL BUSINESS ZONE

PERMIT No. 0824

MAY 20 1931

APPLICATION FOR PERMIT TO ERECT SIGN
OVER PUBLIC SIDEWALK OR STREET

Portland, Maine, May 18, 1931

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect the following described sign extending over a public sidewalk or street in accordance with the Building Code of the City of Portland, and the following specifications:

Location 157-5 Free Street Ward 5 Within Fire Limits? yes Dist. No. 1

Owner of building to which sign is to be attached H. H. Day Sons

Name and address of owner of sign H. H. Day Sons

Contractor's name and address Thomas Skinner Co., 127 Main St. So. Port Telephone P 7753

When does contractor's bond expire? February 1932

Information Concerning Building

No. stories 5 Material of wall to which sign is to be attached brick

Details of Sign and Connections

Electric? yes Vertical dimension after erection 4' 0" Horizontal 4' 0"

Weight 100 lbs., Will there be any hollow spaces? yes Any rigid frame? yes

Material of frame angle iron No. advertising faces 2 material metal

No. rigid connections 2 Are they fastened directly to frame of sign? yes

No. through bolts 2 Size 5/8" Location, top or bottom top and bottom

No. guys 5 material cable Size 1/2"

Minimum clear height above sidewalk or street 15'

Maximum projection into street 4' 0" Fee \$ 2.00

Thomas Skinner Co.

Signature of contractor

Oliver T. Sanborn

INSPECTION COPY

Oliver T. Sanborn

Ward 5 Permit No. 31/824
Location 158-5 Free St.
Owner H. H. Hay Sons
Date of permit 5/23/31
Sign Contractor _____
Final Inspn. 7/29/32

NOTES

5/20/31 Mr. M. C. Connick
said that no part of
sign or sign will
be closer than 15 ft
to sidewalk - A.G.
6/3/31 Only canvas
windows. No through
6/3/31 No top center
6/3/31 A.G.
6/17/31 Mr. M. C. Connick
said that no
9/25/31 No thru bolts

Details of Sign and Connections

RECEIVED SIGN PERM
JUL 29 1932

FILL IN COMPLETELY AND SIGN WITH INK



APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine,

June 8 1931

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 594 Congress Use of Building Residential

Name and address of owner H H Hays Ward _____

Contractor's name and address Portland Gas Co 9 Temple Telephone F 5-5-60

General Description of Work

To install One Incinerator

IF HEATER, POWER BOILER OR COOKING DEVICE

Is heater or source of heat to be in cellar? No If not, which story 3rd Kind of Fuel Gas

Material of supports of heater or equipment (concrete floor or what kind) concrete slab

Minimum distance to wood or combustible material, from top of boiler or casing top of furnace, 6ft

from top of smoke pipe 6ft, from front of heater 6ft from sides or back of heater 6ft

IF OIL BURNER

Name and type of burner _____ Approved by Underwriters' Laboratories? _____

Location oil storage _____ No. and capacity of tanks _____

Will all tanks be more than seven feet from any flame? _____ How many tanks fireproofed? _____

Amount of fee enclosed? 1.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

Signature of contractor Portland Gas Co

By A. S. Sargent

INSPECTION COPY

Ward 5 Permit No 31/584

Location 594 Congress St.

Owner H. H. Hay Sons

Date of permit 6/9/31

Notif. closing-in _____

Inspn. closing-in _____


Final Notif. _____

Final Inspn. 6/9/31

Cert. of Occupancy issued None

NOTES

6/9/31 - Probably O.K. - Grates





FILL IN COMPLETELY AND SIGN WITH INK

PERMIT
1006

Permit No.

JUN 11 1931

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, June 11, 1931

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 594 Congress Street Use of Building mercantile
Name and address of owner H. H. Hay Sons, 594 Congress St. Ward 5
Contractor's name and address Portland Gas Light Co., 9 Temple St. Telephone F 5500

General Description of Work

To install gas restaurant range (Junior)

IF HEATER, POWER BOILER OR COOKING DEVICE

Is heater or source of heat to be in cellar? no If not, which story 3d Kind of Fuel gas
Material of supports of heater or equipment (concrete floor or wood - insulated as per requirements
Minimum distance to wood or combustible material, from top of boiler or casing top of furnace, 6'
from top of smoke pipe 18", from front of heater 8" from sides or back of heater 8"

IF OIL BURNER

Name and type of burner Approved by Underwriters' Laboratories? P.C. 6/11/31
Location oil storage and capacity of tanks
Will all tanks be more than seven feet from any How many tanks fireproofed?
Amount of fee enclosed? 1.00 (\$1.00 for heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

Signature of contractor


Allen R. Andrews
5060A

INSPECTION COPY

Ward 5 Permit No. 31/1006
Location 594 Congress St.
Owner H H. Hay Sr.
Date of permit 6/11/31
Notif. closing-in _____
Inspn. closing-in _____
Final Notif. _____
Final Inspn. 5/2/32
Cert. of Occupancy issued None

NOTES

9/25/31 - No hood
yet over range. (initials)





FILL IN COMPLETELY AND SIGN WITH INK

PERMIT ISSUED
6877

Permit No.

JAN 29 1933

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

January 23, 1933

Portland, Maine,

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 594 Congress Street Use of Building Store
Name and address of owner H. H. Hay Sons, 594 Congress St. Ward 5
Contractor's name and address C. H. Bryce, 155 Ocean St. So. Port. Telephone F 10295 M

General Description of Work

To install Oil Burning Hot Water Heater

IF HEATER, POWER BOILER OR COOKING DEVICE

Is heater or source of heat to be in cellar? yes If not, which story _____ Kind of Fuel _____
Material of supports of heater or equipment (concrete floor or what kind) concrete
Minimum distance to wood or combustible material, from top of boiler or casing top of furnace _____
from top of smoke pipe _____ from front of heater _____ from sides or back of heater _____

IF OIL BURNER

Name and type of burner Motor Wheel Labeled and approved by Underwriters' Laboratories? yes
Will operator be always in attendance? _____ Type of oil feed (gravity or pressure) gravity
Location oil storage basement No. and capacity of tanks 1 - 100 gal.
Will all tanks be more than seven feet from any flame? yes How many tanks fireproofed? _____

Amount of fee enclosed? _____ (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

INSPECTION COPY

Signature of contractor C. H. Bryce

NOTIFICATION BEFORE LATENT
OR CLOSING-IN IS WAIVED.
CERTIFICATE OF OCCUPANCY
REQUIREMENT IS WAIVED
C. H. Bryce
1/28/33

Ward 5 Permit No. 33/77
Location 594 Congress St.
Owner H. H. Hay Sons
Date of permit 1/23/33.
Notif. closing-in _____
Inspn. closing-in _____
Final Notif. _____
Final Inspn. 2/10/33 - O.T.
Cert. of Occupancy issued None.

NOTES

1. Kind of heat Hot Water Heating
2. Label ✓
3. Anti-siphon ✓
4. Oil storage ✓
5. Tank distance ✓
6. Vent pipe ✓
7. Fill pipe ✓
8. Gauge no
9. Rigidity ✓
10. Feed safety no
11. Pipe sizes & material ✓
12. Control valve ✓
13. Ash pit-vent —
14. Temp. or pressure safety ✓
15. Instruction card ✓
16. _____



GENERAL BUSINESS ZC

APPLICATION FOR PERMIT TO ERECT SIGN
OVER PUBLIC SIDEWALK OR STREET

PERM. ISSUED

OCT 27 1934

Portland, Maine, ~~10/22~~ 10/22 1934

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect the following described sign extending over a public sidewalk or street in accordance with the Building Code of the City of Portland, and the following specifications:

Location 594 Congress St Ward 5 Within Fire Limits? yes Dist. No. 1Owner of building to which sign is to be attached Miss Georgia RayName and address of owner of sign H. H. Ray Sons, 594 Congress StreetContractor's name and address The Kimball System, 51 Cross St Telephone 2-5047When does contractor's bond expire? January 7, 1935

Information Concerning Building

No. stories 3 Material of wall to which sign is to be attached brick wall

Details of Sign and Connections

Electric? yes Vertical dimension after erection 4' 10" Horizontal V-shape 7' sidesWeight approx. 450 lbs. Will there be any hollow spaces? yes Any rigid frame? yesMaterial of frame 1 1/2 x 1 1/2 x 3/16 angle iron No. advertising faces 2 material 24 ga. galv. sheet steelNo. rigid connections 4 Are they fastened directly to frame of sign? yesNo. through bolts 2 Size 1" Location, top or bottom topNo. guys 2 material 4 ga. galv. cable Size 1/4"Minimum clear height above sidewalk or street 15'Maximum projection into street 5' 6"Fee \$ 1.00

Signature of contractor

THE KIMBALL SYSTEM OF PORTLAND

INSPECTION COPY

CHIEF OF FIRE DEPT.

R. F. Colver

CERTIFICATE OF OCCUPANCY
REQUIREMENT IS WAIVED

Way 57 Permit No. 34/1763
Location 594 Congress St.
Owner H. H. Hays Sons
Date of permit 10/27/34
Sign Contractor
Final Inspn. 1/3/35. O.B.

NOTES

Ready for dig 12/6/34 6:00 P.M.
12/12/34 - shop OK
12/29/34, Revisions to original
plan shown on attached
plan. No new plan
filed as noted. O.B.
1/3/35, Single run
with three bolts
at top. O.B.



FILL IN COMPLETELY AND SIGN WITH INK

PERMIT 1988

GENERAL BUSINESS ZONE

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, November 16, 1935

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 594 Congress Street Use of Building Store & Offices
Name and address of owner H.H. Hay Sons, 594 Congress St. Ward 5
Contractor's name and address Ballard Oil & Equip. Co. of Maine Telephone 2-1991
124 High Street

General Description of Work

To install Automatic Hot Water Heater for hot water supply to restaurant,
soda fountains, etc.

IF HEATER, POWER BOILER OR COOKING DEVICE

Is heater or source of heat to be in cellar? yes If not, which story _____ Kind of Fuel oil
Material of supports of heater or equipment (concrete floor or what kind) Concrete
Minimum distance to wood or combustible material, from top of boiler or casing top of furnace, _____
from top of smoke pipe _____, from front of heater _____ from sides or back of heater _____
Size of chimney flue _____ Other connections to same flue _____

IF OIL BURNER

Name and type of burner Motor Wheel Model D Labeled and approved by Underwriters' Laboratories? yes
Will operator be always in attendance? _____ Type of oil feed (gravity or pressure) Pressure
Location oil storage basement No. and capacity of tanks one 110 gals. already installed
Will all tanks be more than seven feet from any flame? yes How many tanks fireproofed? _____

Amount of fee enclosed? \$1.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)
Signature of contractor Ballard Oil & Equipment Co. of Maine

INSPECTION COPY

Ward 5 Permit No 35/1988

Location 594 Congress St.

Owner H. H. Harg & Sons.

Date of permit Nov. 16, 35.

Post Card sent

Notif. for insp. None

Approval Tag issued 11/29/35. P. 16.

Oil Burner Check List (date) 11/29/35.

1. Kind of heat Hot Water Heater

2. Label ☒

3. Anti-siphon ☒

4. Oil storage ☒

5. Tank distance ☒

6. Vent pipe Old installation

7. Fill pipe ☒

8. Gauge ☒

9. Rigidity ☒

10. Feed safety ☒

11. Pipe sizes and material ☒

12. Control valve ☒


13. Ash pit vent ☒

14. Temp. or pressure safety ☒

15. Instruction card ☒

16. Inapt. or stat in smoke pipe

NOTES




SIGN FOR H.H. HAY CO.
 REBUILT AND TO BE HUNG
 AT SAME LOCATION 594 CONGRESS

$$\frac{160 \times 510 \times 1.5}{8} = 1200$$

$$\frac{1200}{100} = 12$$

$$\frac{12}{3.0} = 0.06$$

REBUILDING INCLUDES: NEW METAL FACE
 NEON TUBES REPLACING ALL GLASS
 LETTERING — BULBS AND RECEIVERS
 REMOVED — TRANSFORMERS INSTALLED
 1 1/4 x 1 3/4 x 3/16 ANGLE ADDED TO BUILDING END
 OF SIGN FRAME





GENERAL BUSINESS ZONE

PERMIT ISSUED
Permit No. 1320

APPLICATION FOR PERMIT TO ERECT SIGN
OVER PUBLIC SIDEWALK OR STREET

Portland, Maine, Aug 25th 1936

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect the following described sign extending over a public sidewalk or street in accordance with the Building Code of the City of Portland, and the following specifications:

Location 574 CONGRESS ST Ward _____ Within Fire Limits? _____ Dist. No. _____

Owner of building to which sign is to be attached _____

Name and address of owner of sign H. H. HAY PO 1

Contractor's name and address KIMBALL SYSTEM

Telephone 2 5047

When does contractor's bond expire? JAN 1937

Information Concerning Building

No. stories 3 Material of wall to which sign is to be attached BRICK
~~As existing to be made to existing sign has reference to same location as building~~

Details of Sign and Connections

Electric? YES Vertical dimension after erection 4' Horizontal 4'

Weight 250 lbs., Will there be any hollow spaces? YES Any rigid frame? YES

Material of frame ANGLE IRON No. advertising faces 2, material METAL

No. rigid connections 2 Are they fastened directly to frame of sign? YES

No. through bolts 1, Size 1 1/2, Location, top or bottom TOP

No. guys 5, material CABLE, Size 1 1/4"

Minimum clear height above sidewalk or street 15'

Maximum projection into street 5'

Oliver O. Lamborn

Signature of contractor

H. Kimball System
H. F. Cochran

Fee \$

CLERK OF FIRE DEPT.
INSPECTION COPY

CERTIFICATE OF OCCUPANCY
REQUIREMENTS SATISFIED

1 5 Permit No. 367 0
Loc. 594 Cincinnati
Owner N. H. Hay Sons
Date of permit 8/26/36
Sign Contractor
Final Inspn.
Supervises permit
ST. 13/825 NOTES
Elec. Insp.
Shop Insp.
Sign file plan made
Through Bolt
Distance above sidewalk
Ornament Underside
SIDEWALK OR STREET
PERMIT TO EFFECT WORK



IN GENERAL BUSINESS ZONE PERMIT ISSUED
Permit No. 2166
APPLICATION FOR PERMIT TO ERECT SIGN 1936
OVER PUBLIC SIDEWALK OR STREET

Portland, Maine, 12/15 1936

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect the following described sign extending over a public sidewalk or street in accordance with the Building Code of the City of Portland, and the following specifications:

Location 592 CONGRESS ST Ward 5 Within Fire Limits? yes Dist. No. 1
Owner of building to which sign is to be attached MISS GEORGIA RAY
Name and address of owner of sign H. H. King Drug Co.
Contractor's name and address Kimball System Telephone 2-5047
When does contractor's bond expire? Jan 1937

Information Concerning Building

No. stories 3 Material of wall to which sign is to be attached brick

Details of Sign and Connections

Electric? yes Vertical dimension after erection 17" Horizontal 26"
Weight 60 lbs. Will there be any hollow spaces? yes Any rigid frame? yes
Material of frame Angle iron No. advertising faces 2 material galv. metal
No. rigid connections 3 Are they fastened directly to frame of sign? yes
No. through bolts _____, Size _____, Location, top or bottom _____
No. guys 2, material cable, Size 1/4"
Minimum clear height above sidewalk or street 7'-0"

Maximum projection into street 2'-0"

Oliver V. Lumbou

Signature of contractor

Kimball System Fee \$1.-
R. F. Cochrane

CHIEF OF FIRE DEPT.
INSPECTION COPY

CERTIFICATE OF OCCUPANCY
REQUIREMENT IS WAIVED

War 5 Permit No. 36/2168
Location 592 Congress St
Owner J. H. May, Dug Co
Date of permit 12/18/36
Sign Contractor

Final Inspn. 1/12/37. C. G.

NOTES

Sticker
Elec. Insp.
Shop Insp.
Sign file plan made
Disturbance sidewalk
Ornament Underside





12/19/36


11/1/37

By J. H. May and C. G. G.

3-STORY BRICK BUILDING
AT #592 CONGRESS STREET
OWNER - MISS GEORGIA W. RAY

592596
Congress







SIGN 8' FROM
SIDE WALK
MAXIMUM PROJECTION
2' FROM BUILDING



GUYS DO NOT INTERFERE
WITH ANY WINDOWS

WEIGHT - 60 LBS.



BLANK BRICK WALL





FILL IN COMPLETELY AND SIGN WITH INK

PERMIT ISSUED
Permit No. 1617
NOV 26 1945

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, November 14, 1945

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 594 Congress Street Use of Building Store No. Stories 2 New Building
Existing "

Name and address of owner of appliance H. H. Hay & Sons, 594 Congress St.

Installer's name and address Randall McAllister, 84 Commercial St. Telephone 3-2941

General Description of Work

To install Oil burning equipment in connection with existing steam heat

IF HEATER, POWER BOILER OR COOKING DEVICE

Is appliance or source of heat to be in cellar? Yes If not, which story _____ Kind of Fuel Oil

Material of supports of appliance (concrete floor or what kind) concrete

Minimum distance to wood or combustible material, from top of appliance or casing top of furnace,
from top of smoke pipe _____ from front of appliance _____ from sides or back of appliance _____

Size of chimney flue _____ Other connections to same flue _____

IF OIL BURNER

Name and type of burner Glow Silent Automatic Labeled and approved by Underwriters' Laboratories? Yes
Does oil supply line feed from top or bottom of tank? bottom

Will operator be always in attendance? _____ Type of oil feed (gravity or pressure) bottom

Location oil storage basement - existing No. and capacity of tanks 1-275 gal.

Will all tanks be more than seven feet from any flame? Yes How many tanks fireproofed? _____

Amount of fee enclosed? 1.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)
Randall & McAllister

Signature of Installer By: Arthur Riley

Original

Permit No. 45/1617

Location 694 Congress St.

Owner H. H. Hay & Sons

Date of Permit 11/14/45

Post Card sent

Notif. for insp. 12-3-45 V.P.I.

Approval Tag issued

Oil Burner Check List (date)

1. Kind of heat Steam
2. Label ☒
3. Anti-siphon ☒
4. Oil storage ☒
5. Tank Distance ☒
6. Vent Pipe ☒
7. Fill Pipe ☒
8. Gauge No. 1 ☒
9. Rigidity ☒
10. Feed safety ☒
11. Pipe sizes and material ☒
12. Control valve ☒
13. Ash pit vent ☒
14. Temp. or pressure safety ☒
15. Instruction card ☒
- 16.

NOTES

12-3-45 Th gauge to Tank
E.P.I. Inc.

31/37-I

May 13, 1931

H. H. Hay Sons
690 Congress Street
Portland, Maine

Gentlemen:

In connection with the alterations of your building at 690-694 Congress Street, it appears that the enclosure of the boiler room in the cellar has been built only four inches thick. The Building Code requires at this point a standard fireproof heater room, a construction which calls for a masonry wall at least eight inches thick.

Will you be kind enough to make this adjustment as promptly as possible?

Very truly yours,

Inspector of Buildings.

RM/HC

Copy to John Calvin & John Howard Stevens-477 Congress St.
" " Messrs. Googins & Clark-46 Portland, Street



FILL IN COMPLETELY AND SIGN WITH INK

Permit No. 0090

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, Jan. 31, 1931

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 594 Congress St. Use of Building Drug store and restaurant

Name and address of owner H.H. Hay & Sons, 594 Congress St. Portland Ward

Contractor's name and address The Fels Co. Telephone Forest 193

General Description of Work

To install New boiler and radiation

IF HEATER, POWER BOILER OR COOKING DEVICE

Is heater or source of heat to be in cellar? yes If not, which story Kind of Fuel

Material of support of heater or equipment (concrete floor or what kind) concrete

Minimum distance to wood or combustible material, from top of boiler or casing top of furnace, 24"

from top of smoke pipe 15", from front of heater 5' from sides or back of heater 4'

IF OIL BURNER

Name and type of burner Approved by Underwriters' Laboratories?

Location oil storage No. and capacity of tanks

Will all tanks be more than seven feet from any flame? How many tanks fireproofed?

Amount of fee enclosed? (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

Signature of contractor

The Fels Co.
Charles H. Nelson

INSPECTION COPY

NOTIFICATION BEFORE LAYING
OR CLOSING-IT IS REQUIRED
CERTIFICATE OF OCCUPANCY
REQUIREMENT IS FULFILLED

4079A

Ward 5 Permit No. 31/90
Location 574 Congress St.
Owner H. H. Hayes Sons
Date of permit 2/2/31
Notif. closing-in _____
Inspn. closing-in _____
Final Notif. _____
Final Inspn. 3/4/31
Cert. of Occupancy issued None

NOTES

2/19/31 Shield not
put over smokepipe
which is only 10
below metal path
+ plaster ceiling A.W.
2/27/31 - Shield Apts.
Canvas on pipe
covering close to
side and above
smokepipe should
be removed. - A.G.D.
2/27/31 - Called F.H. Co.
who said they would
look after above. A.G.D.
3/4/31 - Made no new
inspection copy of 31/167
looked up on removal
of canvas covering. - A.G.D.

