SIGN TEAM TEL No.2077752694 Jun 21.95 17:35 No.019 P.02/03

orcement
Safety
ecurity

Maine Criminal Justice Academy
State Fire Marshal
State Police

ECEIVED

DEPARTMENT OF PUBLIC SAFETY
36 HOSPITAL STREET • AUGUSTA, MAINE 04330

SEP 21 1983

TLAND DESIGN TEAM

554 Congress St.

September 19, 1983

Portland Design Team
Attn: Frank M. Locker, AIA
50 Exchange Street
Portland, Maine 04101

Re: Waiver for H.H. Hay Building, Portland, Maine

Dear Frank:

We have reviewed your request for a waiver at H.H. Hay Building, Portland, Maine. The supporting documentation and alternative safety measures are acceptable to this office. Your request is approved.

If we can be of any further assistance, please do not hesitate to contact us.

Very truly yours,

Richard A. Dolby
Plans Examiner
State Fire Marshal's Office

RAD/jmd

FILL IN AND SIGN WITH INK

941296

PERMIT ISSUED
DEC - 5 1994
CITY OF PORTLAND

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, 12/2/94

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 594 Congress St Use of Building retail book store Stories New Building Existing "
Name and address of owner of appliance Harding's Books - 594 Congress St. Ptld
Installer's name and address Rudi the Plumber 797-8311 Telephone
1231 Forest Ave- Ptld, ME 04103

General Description of Work

To install replace oil furnace with gas boiler

IF HEATER, OR POWER BOILER

Location of appliance basement Any burnable material in floor surface or beneath? no
If so, how protected? Kind of fuel? natural gas
Minimum distance to burnable material, from top of appliance or casing top of furnace 36 in
From top of smoke pipe 24 inc From front of appliance 72 in From sides or back of appliance 72 in
Size of chimney flue 8 inch Other connections to same flue no
If gas fired, how vented? chimney Rated maximum demand per hour 200,000 btu
Will sufficient fresh air be supplied to the appliance to insure proper and safe combustion?

IF OIL BURNER

Name and type of burner Labelled by underwriters' laboratories?
Will operator be always in attendance? Does oil supply line feed from top or bottom of tank?
Type of floor beneath burner Size of vent pipe
Location of oil storage Number and capacity of tanks
Low water shut off Make No.
Will all tanks be more than five feet from any flame? How many tanks enclosed?
Total capacity of any existing storage tanks for furnace burners

IF COOKING APPLIANCE

Location of appliance Any burnable material in floor surface or beneath?
If so, how protected? Height of Legs, if any
Skirting at bottom of appliance? Distance to combustible material from top of appliance?
From front of appliance From sides and back From top of smokepipe
Size of chimney flue Other connections to same flue
Is hood to be provided? If so, how vented? Forced or gravity?
If gas fired, how vented? Rated maximum demand per hour

MISCELLANEOUS EQUIPMENT OR SPECIAL INFORMATION

Rolf Casna 1 1/2 FILL PIPE plumber
Kind of heat 06694
Burner fidelity & support
Name & Label
Remote control
High limit control
Main cut off switch
Low water cut off
High limit control
Piping
Gauge
Tank gauge
Oil gauge
Instruction card
Other
Equipment
Amount of fee enclosed? $15

APPROVED:

Never called for inspection

CS 300

Signature of Installer

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

INSPECTION FILE APPLICANT'S ASSESSOR'S COPY

D MS Manson