

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

FITZGIBBONS VIRGINIA S & LEE F STREET TRUSTEE

Located at

594 CONGRESS ST (2nd Flr)

PERMIT ID: 2017-00391

ISSUE DATE: 03/28/2017

CBL: 037 G001001

has permission to **Change of Use on second floor to personal services. Install 2 sinks and paint.** provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Jason Grant

/s/ Laurie Leader

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

personal services (tattoo parlor)

Building Inspections

Use Group:

2nd floor

MUBEC/IBC 2009

Type: 3B

Fire Department

Classification:

Business

This Space

NFPA 101 CH 39

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703
or email: buildinginspections@portlandmaine.gov

**Check the Status of Permit or Schedule an Inspection at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that are attached to this permit.**
- **Permits expire in 6 months if the project is not started or ceases for 6 months.**
- **If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.**

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing w/Fire & Draft Stopping
Certificate of Occupancy/Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

City of Portland, Maine - Building or Use Permit		Permit No: 2017-00391	Date Applied For: 03/24/2017	CBL: 037 G001001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Second Floor: Personal Services (tattoo parlor)		Proposed Project Description: Change of Use on second floor to personal services. Install 2 sinks and paint.		
Dept: Historic		Status: Approved w/Conditions	Reviewer: Robert Wiener	Approval Date: 03/28/2017
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:		1) No exterior alterations are approved with this permit.		
Dept: Zoning		Status: Approved w/Conditions	Reviewer: Christina Stacey	Approval Date: 03/24/2017
Note: B-3 zone Personal services allowed use per §14-217(a)(2)(c) Change of use in B-3 zone does not require off-street parking		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:		1) This property shall remain a single family dwelling. Any change of use shall require a separate permit application for review and approval.		
		2) Separate permits shall be required for any new signage.		
		3) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.		
Dept: Building Inspecti		Status: Approved w/Conditions	Reviewer: Laurie Leader	Approval Date: 03/28/2017
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:		1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.		
		2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.		
Dept: Engineering DPS		Status: Not Applicable	Reviewer: Rachel Smith	Approval Date: 03/28/2017
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:		1) This approval is non-applicable to Engineering DPW as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Works for any other reason than FOG, please contact 207-874-8801.		
Dept: Fire		Status: Approved w/Conditions	Reviewer: Jason Grant	Approval Date: 03/28/2017
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:		1) All construction shall comply with City Code, Chapter 10. All construction shall comply with 2009 NFPA 101, Chapter # 423 All construction shall comply with 2009 NFPA 1, Fire Code. Review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code (Chapter 1.14.4). All means of egress to remain accessible at all times.		