

6/4/02 Framing, Plumbing inspection. All OK. However, Stairs  
Have 8" Rise. Contractor has submitted new stair Plans  
to m. Nugent. Will verify w/ m. Nugent. JN

7/30/02 - Final inspection. Stairs all set all work complete  
Ready for c/o JN

037-6-005  
BP 02-0366



CITY OF PORTLAND, MAINE  
Department of Building Inspection

# Certificate of Occupancy

LOCATION 580 Congress St

CBL 037 G005001

Issued to Bbb Inc/EJ Construction

Date of Issue 08/07/2002

This is to certify that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. 02-0366, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

Office Space

Use Group B Type 3A  
(Boca 1999)

**Limiting Conditions:**

This is for Interior Renovations only

This certificate supersedes  
certificate issued

Approved:

shba  
(Date)

Jon Reed  
Inspector

[Signature]  
Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or leasee for one dollar.

Handwritten notes: MMS, 08/08/02, WMS