

544-568 CONGRESS STUFF
1922-1945 # 1

ATH
RMT
FR
AJS
ES

465 Congress Street-1

June 18, 1945

Mr. J. H. Kennedy
103 Frolic Street
Mr. George Hagelen
465 Congress Street

Subject: Building permit to make certain minor
alterations in the part of the building at
465 Congress Street occupied by Puritan Tea
Room

Gentlemen:

It is indicated that the portion of metal duct to be re-located is either
merely for straight ventilation or is a return air duct in connection with the air
conditioning system. Nevertheless care should be exercised to establish a clearance
of no less than one-inch between all parts of this re-located duct and combustible
material. This space of one-inch should be fire stopped of course with incombustible
material (mineral wool is satisfactory) to prevent a fire in case one develops from
ing up into such space.

These changes are being made to satisfy the requirements of the Public Health
Ordinance and some other changes are to be made not included and not required to be
included in the building permit. Referring to my former letters to the operators of
the Tea Room, they have elected to solve the problem of too close quarters around the
entrance, by removing the temporary inside vestibule at the entrance. This is probably
only a temporary solution of the proposition. Doubtless when bad weather comes again
the need will be felt for protection against the elements through the entrance doors
which was the purpose of the inside vestibule in the first place. It is to be borne
in mind that this vestibule cannot be again installed, until a safe arrangement of it
and the surrounding equipment has been worked out, a plan of the new arrangement filed
here and approved.

When the improvements included in the permit and all other improvements indicated
on the architect's plans have been made, and finally inspected, duplicate blueprints
of the architect's plans should be filed here for routine inspection purposes, one at
this department and one for the Chief of the Fire Department, the plans having been
revised, of course, to show any differences that may arise during the making of the
improvements.

Very truly yours,

Inspector of Buildings

WHD/3

CC: Edgworth, Boston & Tuttle
92 Exchange Street

Mr. Harry C. Libby
465 Congress Street



(G) GENERAL BUSINESS ZONE
APPLICATION FOR PERMIT

PERMIT ISSUED
592

Class of Building or Type of Structure Second Class

Portland, Maine. JUN 11, 1945

JUN 16 1945

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 556 Congress Street Within Fire Limits? Yes Dist. No. 1
Owner's or Lessee's name and address Fraternity Co., Monument Square Telephone
Contractor's name and address George Mageles, 556 Congress St. Telephone 2-9671
Architect J. H. Kennedy, 105 Noble Street Plans filed Yes No. of sheets 1
Proposed use of building Restaurant and mercantile No. families
Other buildings on same lot
Estimated cost \$ 299x 450. Fee \$ 2.00

Description of Present Building to be Altered

Material brick No. stories Heat Style of roof Roofing
Last use Restaurant and mercantile No. families

General Description of New Work

- To change out hardware on front and rear doors,
- To re-arrange existing booths
- To relocate heating duct as per plan

Sent to Health Dept. 6/11
Rec'd. from Health Dept. 6/11

CERTIFICATE OF OCCUPANCY
REQUIREMENT IS W

TRANS. P. BURROUGHS, M.E.
CITY HEALTH OFFICER

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Is any plumbing work involved in this work?
Is any electrical work involved in this work? yes Height average grade to top of plate
Size, front depth No. stories Height average grade to highest point of roof
To be erected on solid or filled land? earth or rock?
Material of foundation Thickness top bottom cellar
Material of underpinning Height Thickness
Kind of roof Rise per foot Roof covering
No. of chimneys Material of chimneys of lining
Kind of heat Type of fuel Is gas fitting involved?
Framing lumber—Kind Dressed or full size?
Corner posts Sills Girt or ledger board? Size
Material columns under girders Size Max. on centers
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
Joists and rafters: 1st floor , 2nd , 3rd , roof
On centers: 1st floor , 2nd , 3rd , roof
Maximum span: 1st floor , 2nd , 3rd , roof
If one story building with masonry walls, thickness of walls? height?

If a Garage

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? no

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Signature of owner George Mageles

121 1/2 Congress St.

January 10, 1915

Mr. John Jones
Parlman Tea Room
565 Congress Street
Portland 5, Maine

Subject: Permit for repair after fire at the
Parlman Tea Room, 565 Congress Street and
protection beneath restaurant
range

Dear Sir:

Above permit is being issued to F. W. Cunningham & Sons, contractors, today.

Following my letter of January 2 relating to provision of suitable insulation beneath this range to prevent a recurrence of ignition of the wooden floor beneath the heat from the range at the dining department, I understand that the Portland Gas Light Company is arranging to set up a new range and legs in such a way that the heat from the range will be directed above the wooden floor surface so that there will be at least four inches "live" air space between the bottom of the range and the floor. The sheet of asbestos board which is to be placed upon the wooden floor before the range is set up, the asbestos board to extend a suitable distance around the outside of the range; thus the heat existing at the base of the range at ends and in the middle and the ventilated air along the rear of the range will be removed and there will be opportunity for free circulation of air from beneath the range out into the room. This arrangement satisfies the requirements of the Building Code--Section 831-b, and the above building permit for repair after fire is issued on that basis.

Very truly yours,

WCB/S

Inspector of Buildings

CC: F. W. Cunningham & Sons
181 State Street

The Fraternity Company
565 Congress Street

Portland Gas Light Company
5 Temple Street

Mr. Harry C. Libby
425 Congress Street

✓ATH
✓HRP
✓RMC
✓PE
✓AJS
✓ES



APPLICATION FOR PERMIT TO REPAIR BUILDING

cond Class Building

Permit No. 123100
JAN 10 1945

Portland, Maine, January 9, 1945

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to repair the following described building in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 566 Congress Street

Within fire limits? yes Dist. No. 1

Owner's name and address The Fraternity Co.

Telephone

Contractor's name and address F. W. Cunningham & Sons, 181 State St.

Telephone 3-0246

Use of building Restaurant, offices

No. stories 4

Style of roof

Type of present roof covering

General Description of New Work

To Repair after Fire to former condition. No alterations.
(Cause - heat from range igniting floor)

Sent to Fire Dept. 1/9/45
Rec'd. from Fire Dept. 1/10/45
Sent to Health Dept. 1/9/45
Rec'd. from Health Dept. 1/9/45

If Roof Covering is to be Repaired or Renewed

Is any plumbing work involved in this work? Is any electrical work involved in this work?
Are repairs or renewal due to damage by fire? If so, what area damaged? sq. ft.
Area of roof to be repaired now? sq. ft.
Type of roofing to be used No. plies
Trade name and grade of roof covering to be used

Estimated cost \$ 100.

Fee \$.50

ORIGINAL

Signature of owner By:

The Fraternity Co.
F. W. Cunningham & Sons

Thomas F. Feltman

1883-1087

Permit No. 45/23
Location 56 Congress St
Owner The Fraternity Co
Date of permit 1/10/45
Notif. closing-in
Inspn. closing-in
Final Notif.
Final Inspn. 1/10/45
Crt. of Occupancy issued 1/10/45

NOTES

~~1/12/45 first attempt to be
made on account of weather
1/14/45 work was done on
work and location of
existing building there
at time of first attempt
to close it was
the failure of the
work to be closed in~~

C-46-2

January 2, 1934

ATH
HMF
RMT
PH
AJS
BS

The Fraternity Company
1111 12th Street

Subject: Unsafe condition of restaurant
in the office of the Fraternity Company
Congress Street

Gentlemen:

The fact that the second fire from the same cause took place beneath this restaurant range makes it obvious that the insulation is not safe.

Normally the Building Code would allow this range, supported by wooden floor framing and wooden floor surface, to be set a little more than four inches above the floor. With this space filled in by 4-inch hollow tile, the tile being set with no voids or spaces in the tile construction so that hot air striking down on the range would be intercepted by these air spaces and would pass through the floor and up into the atmosphere in the room. Beneath this tile to be placed asbestos lumber or metal and upon the tile the same material, then the range to be set on top of that. Thus under this scheme the top of the range would be four or five inches higher than it is now.

However, I find that it is practically impossible to introduce this 4-inch hollow tile ventilating system as the situation exists for the reason that the ends of the insulating layer would be so close to other material that there would not be proper circulation of the hot air through the flues of the tile and thence up into the air of the room.

If by rearrangement of the equipment of the kitchen, you can introduce this type of insulation in such a way that there will be no doubt that both ends of the flues in the tile will have free vent up into the atmosphere of the kitchen, this method of protection will be satisfactory; but even so, I will have to look into the strength of the framing to hold together or not. It is also wise to support the additional weight of the hollow tile plus the normal weights from range and otherwise which have always come on the floor.

In event you cannot so rearrange this appliance so to get proper ventilation from the hollow tile type of insulation, I suggest that you have the entire floor framing taken out from beneath the range and for a small distance beyond both ends of the range and the front, reconstruct the framing so as to be strong enough and then pour a reinforced concrete slab beneath the entire range area, thus eliminating all work on the floor and obviously preventing another fire from that same cause.

In case the latter method is followed, it will be necessary for you to employ a competent designer to make a plan of the present framing, show how he intends to adjust it to support the concrete slab, show the thickness and details of design, including reinforcement of the concrete slab, attach his own personally signed statement of design to the plan and file here with the application for the building permit to cover repair after fire.

Very truly yours,

Inspector of Buildings

WCH/S

CC: Port and Gas Light Co.
Attn: Mr. Carl Morgan

The Fraternity Company
Puritan Tea Room ————— 2

January 1, 1945

It seems to me this finally disposes of the question as to whether or not this type of range is safe. I will therefore have to withdraw arrangement which we made a week or two ago, and on the basis of which I sent you a copy of the memorandum. There are several similar installations on wooden floors throughout the city, and I shall appreciate your looking into the matter of how many and where they are. It is my feeling that as soon as possible we should notify the owners of buildings and the owners of the range in such cases of what has developed so that they can take full precautions to avoid fires in their establishments.

Warren McDonald

532 Congress Street

January 9, 1945

ATB:
RM:

Mr. Morgan of the Portland Gas Light Company has asked if it would satisfy the requirements if they remove the metal "skirting" entirely from both ends and the rear and the front of the restaurant range and set the range on legs so that there would be air space four inches deep between the bottom of the range and the floor surface, then cover the floor surface with asbestos lumber before setting in the legs, and I have told him that would be satisfactory. And I have told him that would satisfy the requirements of the Building Code. He says that is what they will do.

I believe F. W. Cunningham & Sons are to apply for the permit for repair after fire and when that permit is issued prepare a letter for me to sign (long hand only) calling attention to everyone who should know about this arrangement proposed for the range and a copy of the letter ought to be sent to Harry Libby, City Councillor, besides the others.

Warren McDonald



INSPECTION COPY

CITY OF PORTLAND, MAINE
DEPARTMENT OF BUILDING INSPECTION

Complaint No. 45-2

COMPLAINT

Date received January 2, 1945

Location 554-568 Congress Street Use of Building Stores & Restaurant
Owner's name and address Fraternity Co., 555 Congress Street Telephone
Tenant's name and address Puritan Tea Room, 566 Congress Street Telephone
Complainant's name and address RMT Telephone

Description: A second fire (first fire in March 1944 took place beneath the gas fired range in the kitchen of the Puritan Tea Room on January 1, 1945, heat from the ovens having been sufficient to ignite the wood of the floor beneath the range. despite the fact that last March after that fire several thicknesses of asbestos lumber were put on the floor.

U.S. GEN. BUSINESS ZONE

Complainant No. 5-2

Location: 34-568 Congress St

Date Received 1/2/44

Date Disposed of 1-1-77

NR

1757

[Faint handwritten notes at the bottom of the page]

[Handwritten signature]

1947 - 1948 - 1949 - 1950 - 1951 - 1952 - 1953 - 1954 - 1955 - 1956 - 1957 - 1958 - 1959 - 1960 - 1961 - 1962 - 1963 - 1964 - 1965 - 1966 - 1967 - 1968 - 1969 - 1970 - 1971 - 1972 - 1973 - 1974 - 1975 - 1976 - 1977 - 1978 - 1979 - 1980 - 1981 - 1982 - 1983 - 1984 - 1985 - 1986 - 1987 - 1988 - 1989 - 1990 - 1991 - 1992 - 1993 - 1994 - 1995 - 1996 - 1997 - 1998 - 1999 - 2000 - 2001 - 2002 - 2003 - 2004 - 2005 - 2006 - 2007 - 2008 - 2009 - 2010 - 2011 - 2012 - 2013 - 2014 - 2015 - 2016 - 2017 - 2018 - 2019 - 2020 - 2021 - 2022 - 2023 - 2024 - 2025 - 2026 - 2027 - 2028 - 2029 - 2030 - 2031 - 2032 - 2033 - 2034 - 2035 - 2036 - 2037 - 2038 - 2039 - 2040 - 2041 - 2042 - 2043 - 2044 - 2045 - 2046 - 2047 - 2048 - 2049 - 2050 - 2051 - 2052 - 2053 - 2054 - 2055 - 2056 - 2057 - 2058 - 2059 - 2060 - 2061 - 2062 - 2063 - 2064 - 2065 - 2066 - 2067 - 2068 - 2069 - 2070 - 2071 - 2072 - 2073 - 2074 - 2075 - 2076 - 2077 - 2078 - 2079 - 2080 - 2081 - 2082 - 2083 - 2084 - 2085 - 2086 - 2087 - 2088 - 2089 - 2090 - 2091 - 2092 - 2093 - 2094 - 2095 - 2096 - 2097 - 2098 - 2099 - 2100 - 2101 - 2102 - 2103 - 2104 - 2105 - 2106 - 2107 - 2108 - 2109 - 2110 - 2111 - 2112 - 2113 - 2114 - 2115 - 2116 - 2117 - 2118 - 2119 - 2120 - 2121 - 2122 - 2123 - 2124 - 2125 - 2126 - 2127 - 2128 - 2129 - 2130 - 2131 - 2132 - 2133 - 2134 - 2135 - 2136 - 2137 - 2138 - 2139 - 2140 - 2141 - 2142 - 2143 - 2144 - 2145 - 2146 - 2147 - 2148 - 2149 - 2150 - 2151 - 2152 - 2153 - 2154 - 2155 - 2156 - 2157 - 2158 - 2159 - 2160 - 2161 - 2162 - 2163 - 2164 - 2165 - 2166 - 2167 - 2168 - 2169 - 2170 - 2171 - 2172 - 2173 - 2174 - 2175 - 2176 - 2177 - 2178 - 2179 - 2180 - 2181 - 2182 - 2183 - 2184 - 2185 - 2186 - 2187 - 2188 - 2189 - 2190 - 2191 - 2192 - 2193 - 2194 - 2195 - 2196 - 2197 - 2198 - 2199 - 2200 - 2201 - 2202 - 2203 - 2204 - 2205 - 2206 - 2207 - 2208 - 2209 - 2210 - 2211 - 2212 - 2213 - 2214 - 2215 - 2216 - 2217 - 2218 - 2219 - 2220 - 2221 - 2222 - 2223 - 2224 - 2225 - 2226 - 2227 - 2228 - 2229 - 2230 - 2231 - 2232 - 2233 - 2234 - 2235 - 2236 - 2237 - 2238 - 2239 - 2240 - 2241 - 2242 - 2243 - 2244 - 2245 - 2246 - 2247 - 2248 - 2249 - 2250 - 2251 - 2252 - 2253 - 2254 - 2255 - 2256 - 2257 - 2258 - 2259 - 2260 - 2261 - 2262 - 2263 - 2264 - 2265 - 2266 - 2267 - 2268 - 2269 - 2270 - 2271 - 2272 - 2273 - 2274 - 2275 - 2276 - 2277 - 2278 - 2279 - 2280 - 2281 - 2282 - 2283 - 2284 - 2285 - 2286 - 2287 - 2288 - 2289 - 2290 - 2291 - 2292 - 2293 - 2294 - 2295 - 2296 - 2297 - 2298 - 2299 - 2300 - 2301 - 2302 - 2303 - 2304 - 2305 - 2306 - 2307 - 2308 - 2309 - 2310 - 2311 - 2312 - 2313 - 2314 - 2315 - 2316 - 2317 - 2318 - 2319 - 2320 - 2321 - 2322 - 2323 - 2324 - 2325 - 2326 - 2327 - 2328 - 2329 - 2330 - 2331 - 2332 - 2333 - 2334 - 2335 - 2336 - 2337 - 2338 - 2339 - 2340 - 2341 - 2342 - 2343 - 2344 - 2345 - 2346 - 2347 - 2348 - 2349 - 2350 - 2351 - 2352 - 2353 - 2354 - 2355 - 2356 - 2357 - 2358 - 2359 - 2360 - 2361 - 2362 - 2363 - 2364 - 2365 - 2366 - 2367 - 2368 - 2369 - 2370 - 2371 - 2372 - 2373 - 2374 - 2375 - 2376 - 2377 - 2378 - 2379 - 2380 - 2381 - 2382 - 2383 - 2384 - 2385 - 2386 - 2387 - 2388 - 2389 - 2390 - 2391 - 2392 - 2393 - 2394 - 2395 - 2396 - 2397 - 2398 - 2399 - 2400 - 2401 - 2402 - 2403 - 2404 - 2405 - 2406 - 2407 - 2408 - 2409 - 2410 - 2411 - 2412 - 2413 - 2414 - 2415 - 2416 - 2417 - 2418 - 2419 - 2420 - 2421 - 2422 - 2423 - 2424 - 2425 - 2426 - 2427 - 2428 - 2429 - 2430 - 2431 - 2432 - 2433 - 2434 - 2435 - 2436 - 2437 - 2438 - 2439 - 2440 - 2441 - 2442 - 2443 - 2444 - 2445 - 2446 - 2447 - 2448 - 2449 - 2450 - 2451 - 2452 - 2453 - 2454 - 2455 - 2456 - 2457 - 2458 - 2459 - 2460 - 2461 - 2462 - 2463 - 2464 - 2465 - 2466 - 2467 - 2468 - 2469 - 2470 - 2471 - 2472 - 2473 - 2474 - 2475 - 2476 - 2477 - 2478 - 2479 - 2480 - 2481 - 2482 - 2483 - 2484 - 2485 - 2486 - 2487 - 2488 - 2489 - 2490 - 2491 - 2492 - 2493 - 2494 - 2495 - 2496 - 2497 - 2498 - 2499 - 2500 - 2501 - 2502 - 2503 - 2504 - 2505 - 2506 - 2507 - 2508 - 2509 - 2510 - 2511 - 2512 - 2513 - 2514 - 2515 - 2516 - 2517 - 2518 - 2519 - 2520 - 2521 - 2522 - 2523 - 2524 - 2525 - 2526 - 2527 - 2528 - 2529 - 2530 - 2531 - 2532 - 2533 - 2534 - 2535 - 2536 - 2537 - 2538 - 2539 - 2540 - 2541 - 2542 - 2543 - 2544 - 2545 - 2546 - 2547 - 2548 - 2549 - 2550 - 2551 - 2552 - 2553 - 2554 - 2555 - 2556 - 2557 - 2558 - 2559 - 2560 - 2561 - 2562 - 2563 - 2564 - 2565 - 2566 - 2567 - 2568 - 2569 - 2570 - 2571 - 2572 - 2573 - 2574 - 2575 - 2576 - 2577 - 2578 - 2579 - 2580 - 2581 - 2582 - 2583 - 2584 - 2585 - 2586 - 2587 - 2588 - 2589 - 2590 - 2591 - 2592 - 2593 - 2594 - 2595 - 2596 - 2597 - 2598 - 2599 - 2600 - 2601 - 2602 - 2603 - 2604 - 2605 - 2606 - 2607 - 2608 - 2609 - 2610 - 2611 - 2612 - 2613 - 2614 - 2615 - 2616 - 2617 - 2618 - 2619 - 2620 - 2621 - 2622 - 2623 - 2624 - 2625 - 2626 - 2627 - 2628 - 26

6. 11. 1957 E. 22. 10. 1957

- 60-17 Cabaret -

2. The 'range' trait

1/2 - 1/2 - 1/2 - 1/2 - 1/2

[illegible]

275-500-1000

der Zeit korrigieren

The English Language

7-11-1914

Quarantine (10/11/19)

Handwritten signature: *James H. Smith*

[illegible]

10/10/10

7-6-10

1. May - 1901

10/9 - 68-109-2151

2-1 - ...

Chavez & Co.

Trinity - Oct 14/19

throat to

Start a Fair Game

1 2 3 4 5 6 7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100 101 102 103 104 105 106 107 108 109 110 111 112 113 114 115 116 117 118 119 120 121 122 123 124 125 126 127 128 129 130 131 132 133 134 135 136 137 138 139 140 141 142 143 144 145 146 147 148 149 150 151 152 153 154 155 156 157 158 159 160 161 162 163 164 165 166 167 168 169 170 171 172 173 174 175 176 177 178 179 180 181 182 183 184 185 186 187 188 189 190 191 192 193 194 195 196 197 198 199 200 201 202 203 204 205 206 207 208 209 210 211 212 213 214 215 216 217 218 219 220 221 222 223 224 225 226 227 228 229 230 231 232 233 234 235 236 237 238 239 240 241 242 243 244 245 246 247 248 249 250 251 252 253 254 255 256 257 258 259 260 261 262 263 264 265 266 267 268 269 270 271 272 273 274 275 276 277 278 279 280 281 282 283 284 285 286 287 288 289 290 291 292 293 294 295 296 297 298 299 300 301 302 303 304 305 306 307 308 309 310 311 312 313 314 315 316 317 318 319 320 321 322 323 324 325 326 327 328 329 330 331 332 333 334 335 336 337 338 339 340 341 342 343 344 345 346 347 348 349 350 351 352 353 354 355 356 357 358 359 360 361 362 363 364 365 366 367 368 369 370 371 372 373 374 375 376 377 378 379 380 381 382 383 384 385 386 387 388 389 390 391 392 393 394 395 396 397 398 399 400 401 402 403 404 405 406 407 408 409 410 411 412 413 414 415 416 417 418 419 420 421 422 423 424 425 426 427 428 429 430 431 432 433 434 435 436 437 438 439 440 441 442 443 444 445 446 447 448 449 450 451 452 453 454 455 456 457 458 459 460 461 462 463 464 465 466 467 468 469 470 471 472 473 474 475 476 477 478 479 480 481 482 483 484 485 486 487 488 489 490 491 492 493 494 495 496 497 498 499 500 501 502 503 504 505 506 507 508 509 510 511 512 513 514 515 516 517 518 519 520 521 522 523 524 525 526 527 528 529 530 531 532 533 534 535 536 537 538 539 540 541 542 543 544 545 546 547 548 549 550 551 552 553 554 555 556 557 558 559 560 561 562 563 564 565 566 567 568 569 570 571 572 573 574 575 576 577 578 579 580 581 582 583 584 585 586 587 588 589 590 591 592 593 594 595 596 597 598 599 600 601 602 603 604 605 606 607 608 609 610 611 612 613 614 615 616 617 618 619 620 621 622 623 624 625 626 627 628 629 630 631 632 633 634 635 636 637 638 639 640 641 642 643 644 645 646 647 648 649 650 651 652 653 654 655 656 657 658 659 660 661 662 663 664 665 666 667 668 669 670 671 672 673 674 675 676 677 678 679 680 681 682 683 684 685 686 687 688 689 690 691 692 693 694 695 696 697 698 699 700 701 702 703 704 705 706 707 708 709 710 711 712 713 714 715 716 717 718 719 720 721 722 723 724 725 726 727 728 729 730 731 732 733 734 735 736 737 738 739 740 741 742 743 744 745 746 747 748 749 750 751 752 753 754 755 756 757 758 759 760 761 762 763 764 765 766 767 768 769 770 771 772 773 774 775 776 777 778 779 780 781 782 783 784 785 786 787 788 789 790 791 792 793 794 795 796 797 798 799 800 801 802 803 804 805 806 807 808 809 810 811 812 813 814 815 816 817 818 819 820 821 822 823 824 825 826 827 828 829 830 831 832 833 834 835 836 837 838 839 840 841 842 843 844 845 846 847 848 849 850 851 852 853 854 855 856 857 858 859 860 861 862 863 864 865 866 867 868 869 870 871 872 873 874 875 876 877 878 879 880 881 882 883 884 885 886 887 888 889 890 891 892 893 894 895 896 897 898 899 900 901 902 903 904 905 906 907 908 909 910 911 912 913 914 915 916 917 918 919 920 921 922 923 924 925 926 927 928 929 930 931 932 933 934 935 936 937 938 939 940 941 942 943 944 945 946 947 948 949 950 951 952 953 954 955 956 957 958 959 960 961 962 963 964 965 966 967 968 969 970 971 972 973 974 975 976 977 978 979 980 981 982 983 984 985 986 987 988 989 990 991 992 993 994 995 996 997 998 999 1000 1001 1002 1003 1004 1005 1006 1007 1008 1009 1010 1011 1012 1013 1014 1015 1016 1017 1018 1019 1020 1021 1022 1023 1024 1025 1026 1027 1028 1029 1030 1031 1032 1033 1034 1035 1036 1037 1038 1039 1040 1

Memorandum from Department of Building Inspection, Portland, Maine

Expt. 5092D-I

554 Congress Street (117-123 Free Street)-Alteration of metal fire escape on the
Street front of this building for Honorable Percival P. Baxter by Meggister &
contractors - 9/2/44

To Owner and Contractor: Issuance of the above permit is delayed because of the
requirement of the Building Code that such an additional projection over the
sidewalk of Free Street as the new balconies would be requires the formal approval
upon the permit of the Municipal Officers. The formal order for the approval
building permit will before the board at the Council meeting on Wednesday, Sep

CC: Hon. Percival P. Baxter
562 Congress Street

(Signed) Warren McDonald
Inspector of Buildings

City of Portland, Maine

IN BOARD OF MUNICIPAL OFFICERS

September 6, 1944

ORDERED:

Pursuant to Section 211-e of the Building Code relating to projection over public sidewalk, that a building permit covering construction of extensions to certain fire escapes, balconies over the public sidewalk at 117-123 Free Street be and hereby is approved, subject to the condition that such projections over the public sidewalk shall be removed upon order of this Board if found contrary to the public interests.



GENERAL BUSINESS 2017
APPLICATION FOR PERMIT

Class of Building or Type of Structure Second Class

Permit No. 03-13

SEP 1 1944

Portland, Maine, August 25, 1944

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure, equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 554 Congress Street
(117-123 Free Street) Within Fire Limits? yes Dist. No. 1
Owner's or Lessee's name and address P.P. Baxter, 562 Congress Street Telephone _____
Contractor's name and address Mcquigier & Jones Co., 23 Pearl Street Telephone 2-6471
Architect _____ Plans filed _____ No. of sheets _____
Proposed use of building Store No. families _____
Other buildings on same lot _____
Estimated cost \$ 1000. Fee \$ 2.00

Memorandum from Department of Building Inspection, Portland, Maine

117-123 Free Street (554 Congress Street) - Alteration of fire escape on Free Street front for Percival P. Baxter by Mcquigier & Jones Company, contractors - 9/7/44

To Owner & Builder:

Because of the extension of the fire escape over the public sidewalk, approval of the Municipal Officers on a building permit is required. On September 6, the Board ordered: "pursuant to Section 211-e of the Building Code relating to projection over public sidewalk, that a building permit covering construction of extensions to certain fire escape balconies over the public sidewalk at 117-123 Free Street be and hereby is approved, subject to the condition that projections over the public sidewalk shall be removed upon order of this Board if found contrary to the public interest."

CC: Hon. Percival P. Baxter
562 Congress Street

(Signed) Warren McDonald
Inspector of Buildings

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Is any plumbing work involved in this work? no
Is any electrical work involved in this work? no Height average grade to top of plate _____
Size, front _____ depth _____ No. stories _____ Height average grade to highest point of roof _____
To be erected on solid or filled land? _____ earth or rock? _____
Material of foundation _____ Thickness, top _____ bottom _____ cellar _____
Material of underpinning _____ Height _____ Thickness _____
Kind of roof _____ Rise per foot _____ Roof covering _____
No. of chimneys _____ Material of chimneys _____ of lining _____
Kind of heat _____ Type of fuel _____ Is gas fitting involved? _____
Framing lumber—Kind _____ Dressed or full size? _____
Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
Material columns under girders _____ Size _____ Max. on centers _____
Joists (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____
Total number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? _____
Signature of owner P.P. Baxter
Mcquigier & Jones Co.

INSPECTION COPY

CHIEF OF FIRE DEPT.



GENERAL BUSINESS ZONE
APPLICATION FOR PERMIT

Class of Building or Type of Structure Second Class

Permit No. 0873

Portland, Maine, August 25, 1944

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 554 Congress Street Within Fire Limits? yes Dist. No. 1
(117-123 Free Street) P.P. Boxer, 552 Congress Street
Owner's or Lessee's name and address. Telephone _____
Contractor's name and address Veccular & Jones Co., 33 Pearl Street Telephone 2-6471
Architect _____ Plans filed _____ No. of sheets _____
Proposed use of building Store No. families _____
Buildings on same lot _____
cost \$ 1000. Fee \$ 2.00

Description of Present Building to be Altered

Brick No. stories 4 Heat _____ Style of roof _____ Roofing _____
Use _____ Store No. families _____

General Description of New Work

To alter erect metal fire escape on rear of building from third floor to ground as per plan.
This work is lengthening present balconies of existing fire escape

INSPECTION NOT COMPLETED

NOTIFICATION BEFORE LATHE
OR CLOSING-IN IS WAIVED

CERTIFICATE OF COMPLETION
REQUIREMENT IS WAIVED

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Is any plumbing work involved in this work? no
Is any electrical work involved in this work? no Height average grade to top of plate _____
Size, front _____ depth _____ No. stories _____ Height average grade to highest point of roof _____
To be erected on solid or filled land? _____ earth or rock? _____
Material of foundation _____ Thickness, top _____ bottom _____ cellar _____
Material of underpinning _____ Height _____ Thickness _____
Kind of roof _____ Rise per foot _____ Roof covering _____
No. of chimneys _____ Material of chimneys _____ of lining _____
Kind of heat _____ Type of fuel _____ Is gas fitting involved? _____
Framing lumber—Kind _____ Dressed or full size? _____
Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
Material columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____
Total number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes
Signature of owner P.P. Boxer
Megquier & Jones

INSPECTION COPY

CITY OF PORTLAND

Permit No. 44/873

Location: 1554 Congress St

Owner P. P. Baxter

Date of permit 9/7/44

Notif. closing-in

Inspn. closing-in

Final Notif.

Final Inspn.

Cert. of Occupancy issued

NOTES

04/26/45. Unable to get
in room to check
through ltr. Janette
out. O.H.



GENERAL BUSINESS ZONE
APPLICATION FOR PERMIT

PERMIT ISSUED
Permit No. 1548

Class of Building or Type of Structure Second Class MAY 20 1942
Portland, Maine May 14, 1942

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure equipn. in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 568 Congress Street P. P. Baxter Within Fire Limits? yes Dist. No. 1
Owner's or Lessee's name and address Puritan Candy & Tea Room Telephone none
Contractor's name and address George B. Williams, 97 State Street Telephone none
Architect _____ Plans filed yes No. of sheets 1
Proposed use of building Store and restaurant No. families _____
Other buildings on same lot _____ Fee \$1.00
Estimated cost \$ 572.

Description of Present Building to be Altered

Memorandum from Department of Building Inspection, Portland, Maine

568 Congress St.—New refrigeration room in basement for Puritan Candy and Tea Room
to be installed by George B. Williams—5/20/42

To Owner, Lessee and Installer:

I note a sprinkler pipe passing through the new room, and perhaps a sprinkler head may occur there. Unless this system is "dry pipe" precautions should be taken and adjustments made so there is no possibility of any part of the sprinkler system freezing.

In event the specifications for temperatures in the new room do not indicate freezing temperatures, but the system might possibly "run wild" and produce temperatures below those intended, then the system of sprinklers ought to be protected against the worst possible condition that might obtain.

cc Puritan Candy & Tea Room,
568 Congress
Hon. P. P. Baxter,

(Signed) Warren McDonald
Inspector of Buildings

Details of New Work

Is any plumbing work involved in this work? no
Is any electrical work involved in this work? no Height average grade to top of plate _____
Size, front _____ depth _____ No. stories _____ Height average grade to highest point of roof _____
To be erected on solid or filled land? _____ earth or rock? _____
Material of foundation _____ Thickness, top _____ bottom _____ cellar _____
Material of underpinning _____ Height _____ Thickness _____
Kind of roof _____ Rise per foot _____ Roof covering _____ of lining _____
No. of chimneys _____ Material of chimneys _____ Is gas fitting involved? _____
Kind of heat _____ Type of fuel _____ Is gas fitting involved? _____
Framing lumber—Kind _____ Dressed or full size? _____
Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
Material columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, height? _____
One story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____
Total number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes
Puritan Candy & Tea Room

INSPECTION COPY

Thomas J. McLaughlin, M.D.

Chief of Fire Dept.

Signature of owner By: Geo B Williams



GENERAL BUSINESS ZONE
APPLICATION FOR PERMIT

PERMIT ISSUED

Class of Building or Type of Structure Second Class

Permit No. 1342
MAY 20 1942

Portland, Maine, May 14, 1942

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 568 Congress Street P. P. Exter Within Fire Limits? yes Dist. No. 1
Owner or Lessee's name and address Puritan Candy & Tea Room Telephone ✓
Contractor's name and address George B. Williams, 87 State Street Telephone none
Architect _____ Plans filed yes No. of sheets 1
Proposed use of building Store and restaurant No. families _____
Other buildings on same lot _____
Estimated cost \$ 372. Fee \$ 1.00

Description of Present Building to be Altered

Material brick No. stories 5 Heat _____ Style of roof _____ Roofing _____
Use Store and restaurant No. families _____

General Description of New Work

To construct 8' x 8' refrigeration room in basement as per plan submitted.

RECEIVED OF SUBMITTER
RECEIVED BY PERMIT

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Is any plumbing work involved in this work? no
Is any electrical work involved in this work? no Height average grade to top of plate _____
Size, front _____ depth _____ No. stories _____ Height average grade to highest point of roof _____
To be erected on solid or filled land: _____ earth or rock? _____
Material of foundation _____ Thickness, top _____ bottom _____ cellar _____
Material of underpinning _____ Height _____ Thickness _____
Kind of roof _____ Rise per foot _____ Roof covering _____
No. of chimneys _____ Material of chimneys _____ of lining _____
Kind of heat _____ Type of fuel _____ Is gas fitting involved? _____
Framing lumber—Kind _____ Dressed or full size _____
Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
Material columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____

If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____
Total number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

INSPECTION COPY

Signature of owner By

Puritan Candy & Tea Room

Geo B Williams

Inspector of Buildings

NOTES

NOTES



FILL IN COMPLETELY AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Portland, Maine, April 12, 1980

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 566 Congress Street Use of Building Restaurant, etc. No. Stories 5 New Building
Existing "Existing"
Name and address of owner of appliance Puritan Tea Room, 566 Congress St.
Installer's name and address Portland Gas L. Co., 5 Temple St. Telephone 2-8721

General Description of Work

To install deep fat fryer

IF HEATER, POWER BOILER OR COOKING DEVICE

Is appliance or source of heat to be in cellar? no If not, which story 1st Kind of Fuel gas
Material of supports of appliance (concrete floor or what kind) wood - 2' above floor
Minimum distance to wood or combustible material, from top of appliance or casing top of furnace, 8'
from top of smoke pipe over 4' from front of appliance over 4' from sides or back of appliance 12"
Size of chimney flue vented to existing hood Other connections to same flue no enclosed burners produce not more
Name and type of burner IF OIL BURNER
Labeled and approved by Underwriters' Laboratories? Will operator be always in attendance?
Type of oil feed (gravity or pressure) Location oil storage
No. and capacity of tanks Will all tanks be more than seven feet from any flame?
How many tanks fireproofed?

Amount of fee enclosed? 1.00 (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)
Portland Gas Light Co.

INSPECTION COPY

Signature of Installer

By

Permit No. 40/368

Location 566 Congress St.

Owner Quintan Reg. Room

Date of Permit 4/13/40

Post Card sent

Notif. for insp. None

Approval Tag issued 4/18/40 OK

Oil-Burner Check List (date)

1. Kind of heat gas fired slip fast
2. Label Tag
3. Anti-siphon
4. Oil storage
5. Tank distance
6. Vent Pipe
7. Fill Pipe
8. Gauge
9. Rigidity
10. Feed safety
11. Pipe sizes and material
12. Control valve
13. Ash pit vent
14. Temp. or pressure safety
15. Instruction card
- 16.

NOTES

File

CITY OF PORTLAND, MAINE
DEPARTMENT OF BUILDING INSPECTION

Record of Inquiry

*52-578
10/1/39*

~~Verbal in person~~

By telephone *letter attached*

Date *9/6/39*

Location *129 Free St.*

Made by *Fraternity Co. - P. P. Baxter, Pres.*

Inquiry-1 *About security of outside ventilator
duct of Gunitan Tea Room.*

2 _____

3 _____

Answer-1 *Letter 9/6/39*

2 _____

3 _____

Reply by *mm*

PERCIVAL P. BAXTER
PORTLAND, MAINE

September
first
1939

RECEIVED

SEP 2 1939

DEPT. OF BLD'G. Insp.
CITY OF PORTLAND

Dear Mr. McDonald -

On the Free Street side of the BAXTER BUILDING, the Puritan Tea Room has erected a ventilator which extends from the street floor to a point somewhat above the roof. In looking over this ventilator it seems to me that it is not fastened to the building as securely as it should be and I write to ask you to inspect this and tell me just what you think should be done to make it entirely safe.

Yours very truly,

FRATERNITY COMPANY

By



Treasurer.

To-

Mr. Warren McDonald
Building Inspector
Portland

Inquiry 113 Free Street

September 6, 1922

P. P. Baxter, Trans.
Fraternity Co.,
22 Monument Square,
Portland, Maine

Dear Mr. Baxter:

Upon examination of the ventilator erected on Free Street for the Puritan Tea Room, called to my attention in your letter of September 1st, I would be unable to say that the ventilator duct is not safely fastened to the building.

I think one detail which gives the appearance of being unstable is the fact that the vertical duct has not been made parallel with the wall of the building below the cornice.

I suggest that at least one more strap iron brace be provided at the very top of the vertical run of pipe, just below the cornice of the building, where the angle occurs in the duct to get out beyond the cornice of the building.

I note that these strap iron braces to the building do not occur at every joint in the metal duct. Only the metal worker who manufactured the duct would know whether or not the fastenings of these joints of the sections of the duct are strong enough to withstand lateral pressure without being fastened to the building at each joint.

Very truly yours,

WCD/H

Inspector of Buildings

P.59/2537-1 -
B-1-25-53-41

January 3, 1939

George M. Booth,
Chief Engineer,
National Board of Fire Underwriters
85 John Street,
New York, N. Y.

Dear Mr. Booth:

A cooking device, new to me, has come to my attention. It consists of a broiler used in restaurant kitchens and fired by charcoal briquets. The particular one that I have seen has the fire apparently supported on a solid plate without any provision for ashes to drop, over the fire is the broiler grille and the compartment may be completely closed except for the vent by means of a sliding door when broiling is going on. This device is vented merely by extending a short vent pipe beneath the metal hood of a large restaurant range which happens to be gas-fired. The hood vented by means of a metal duct leading to the outside wall of the building, where is located an electric exhaust fan.

I think we have several of these devices in town, and our Code provides definitely that they shall be connected with a masonry chimney on the basis that they use some other fuel than gas or electricity. I do not wish to proceed against them, however, until I get your ideas as to what your feeling is concerning the venting of such a device. But for the complete enclosure feature, this device is somewhat similar to a forge which might use charcoal for a fuel, and in such a case of an open forge, usually equipped with a blower, we do not forbid the hood to merely be connected to a metal exhaust pipe.

May I have your opinion about this device?

Very truly yours,

WMH/H

Inspector of Buildings



PERMIT

Original Permit No. 38/1597

Amendment No. 2

AMENDMENT TO APPLICATION FOR PERMIT

Portland, Maine, October 27, 1938

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for an amendment to Permit No. 38/1597 pertaining to the building or structure comprised in the original application in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith, and the following specifications:

Location 561 Congress Street

Ward 5

Within Fire Limits? Yes

Dist. No. 1

Owner's name and address

Puritan Tea Room, 561 Congress Street

Contractor's name and address

Hendrick Fixture Co., Manchester, N. H.

Plans filed as part of this Amendment

no

No. of Sheets

Additional fee \$25

Increased cost of work

Description of Proposed Work

To construct dumb waiter 15' x 24' from first floor to basement.
To be hand controlled.

Puritan Tea Room
Hendrick Fixture Co.

Signature of Owner

[Signature]

101-26-9



Original Permit No. 1597
Amendment No. 1

AMENDMENT TO APPLICATION FOR PERMIT

OCT 10 1938

Portland, Maine, October 10, 1938

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for an amendment to Permit No. 1597 pertaining to the building or structure comprised in the original application in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith, and the following specifications:

Location 541 Congress Street Ward 5 Within Fire Limits? yes Dist. No. 1

Owner's or Lessee's name and address Puritan Tea Room, 551 Congress St.

Contractor's name and address Herndorf Fixture Co., Franklin & Auburn Sts., Portland, M.E.

Plans filed as part of this Amendment 20 No. of Sheets

Increased cost of work 00 Additional fee .25

Description of Proposed Work
To close four existing windows in Free Street wall with masonry (brick) tied to existing structure on four sides
To provide new ceiling in new dining room, 21' below existing ceiling, metal lath and plaster

Puritan Tea Room
By Herndorf Fixture Co.

Signature of Owner Walter L. McMillan
By

Approved:

10/16/38

Rept. 2345C-I

September 30, 1938

Harnsdorf Fixture Co.
Manchester,
N. H.

Gentlemen:

Enclosed is the building permit covering alterations in the first story of the building at 554-568 Congress Street for the Puritan Tea Room.

Please note the following:

The double-acting doors between the new dining room and the present dining room are required to be without locking device of any kind. These doors are counted as a means of egress from the new dining room through to Congress Street and also from the present dining room to Free Street. Over the head of the doors on both sides an exit sign is required with letter in the word exit no less than six inches high.

A similar sign is required over the door leading to Free Street from the new dining room, and this latter door is required to have such a lockset that the door may always be opened from the inside by merely turning a knob or pressing on a bar or plate.

The new cellar stairs in the new kitchen are required to be enclosed in the cellar with a minimum of wooden stud partitions (studs 16" from center to center) covered on both sides with plaster either on metal lath or perforated gypsum lath. A self-closing fire door is required at the foot of the stairway enclosure, and by the term self-closing is meant a fire door which is normally closed and kept closed by a door check or other suitable device. If desired, the enclosure partitions may be supported upon the stair stringers and similar fire resistive material provided under the soffit. No closet is permitted beneath the stairs. Unless a labelled fire door is proposed at this point, it would be well to get in touch with this office to find the minimum details allowable. The frame must be a fire door frame. This requirement of enclosure is because the building is more than two stories high.

Please be governed accordingly.

Very truly yours,

Inspector of Buildings

RMH/H
CC: Puritan Tea Room
554 Congress Street

APPLICATION FOR PERMIT

Permit No. 1597

Class of Building or Type of Structure Second Class

SEP 30 1938

Portland, Maine, September 29, 1938

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 554-556 Congress Street Within Fire Limits? Yes Dist. No. 1

Owner or Lessee's name and address Puritan Tea Room, 554 Congress Street Telephone _____

Contractor's name and address Herradurf Fixture Co., Manchester, N. H. Telephone _____

Architect _____ Plans filed Yes No. of sheets 2

Proposed use of building Restaurant and offices and vacant No. families _____

Other buildings on same lot _____

Estimated cost \$ 200. Fee \$.75

Description of Present Building to be Altered

Material Brick No. stories 4 Heat _____ Style of roof _____ Roofing _____

Last use Vacant and offices No. families _____

General Description of New Work

To construct 18' non-bearing partition (2x4 studs, 12" O.C., plaster and tile) to divide existing store space. The back part of this vacant store to be used for kitchen and front part is vacant.

To relocate rear exit. The door will be made to swing outward in such a way that no part of it will project over public sidewalk.

To relocate existing stairway from first floor to basement.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Size, front _____ depth _____ No. stories _____ Height average grade to top of plate _____

To be erected on solid or filled land? _____ earth or rock? _____

Material of foundation _____ Thickness, top _____ bottom _____ cellar _____

Material of underpinning _____ Height _____ Thickness _____

Kind of Roof _____ Rise per foot _____ Roof covering _____

No. of chimneys _____ Material of chimneys _____ of lining _____

Kind of heat _____ Type of fuel _____ Is gas fitting involved? _____

Framing Lumber—Kind _____ Dressed or Full Size? _____

Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____

Material columns under girders _____ Size _____ Max. on centers _____

Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.

Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____

On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____

Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____

If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____

Total number commercial cars to be accommodated _____

Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no

Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

Signature of owner Walter Q. Melhorn

Puritan Tea Room
Herradurf Fixture Co.

al Notif.

Final Inspn. 1/7/39 m. d.

Cert. of Occupancy issued

NOTES

[illegible]

7/15/94 - Gas appliance
sent merely into hood
vented by hood with
gas at trace lt. val.
but there is a 1/2 lb.
long exhaust
for venting kiln &
gas-fired boiler.
It has been changed
out to one fed
by charcoal briquets
in a new device
merely vent^{ed} into
hood as gas-fired
did - no connection
to masonry chimney.

1/9/57 - Letter to Int. USA

4/12/39 - Dec. 2nd -
The question sent
of the application
who - 12/2/39
chancel for a
as is, 12/2/39
12d. 12/2/39

STATEMENT ACCOMPANYING APPLICATION OF PORTLAND GAS LIGHT COMPANY FOR A PERMIT
TO COVER INSTALLATION OF A CERTAIN GAS-FIRED RESTAURANT RANGE AND OTHER HEATING
AND COOKING APPLIANCES IN THE BUILDING OF PURITAN TEA ROOM, 564 CONGRESS STREET

September 26, 1938

1. This statement is to be considered as much a part of the application for the permit as though written on the application form, but failure to mention any requirement of the building code or any laws relating to the same subject matter, herein, shall not relieve any person, firm or corporation from compliance therewith.

2. The enclosed burners of the restaurant range proposed to be installed will have a rated maximum demand in excess of 50,000 British Thermal Units per hour at maximum input rating, and is proposed to vent this appliance otherwise than to a legal masonry chimney. As provided in paragraph d of Section 285 of the Building Code of the City of Portland, the undersigned installing company certifies that the flue gas temperatures at the outlet of the flue connection of this appliance will never exceed 550 degrees Fahrenheit, and, after installation, if required by the Inspector of Buildings of the City of Portland, this installing company will run temperature tests to establish this maximum temperature. In event such temperature test show flue gas temperatures at the outlet of the flue connection of this device in excess of 550 degrees Fahrenheit, this installing company will be responsible for providing a suitable vent from this appliance to a legal masonry flue, all in accordance with the Building Code of the City of Portland.

Portland Gas Light Company

by: Allen R. Anderson



FILL IN COMPLETELY AND WITH INK

PERMIT 155610

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

SEP 27 1938

Portland, Maine, SEP 26, 1938

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 554 Congress Street Use of Building restaurant No. Stories 5
Name and address of owner Puritan Tea Room, 554 Congress Street Ward 5
Contractor's name and address Portland Gas Light Co., 5 Temple St. Telephone 2-8221
OR CHIMNEY IN WALL

General Description of Work

To install (relocate) gas range, fryer, bake oven and stove

IF HEATER, POWER BOILER OR COOKING DEVICE

Is heater or source of heat to be in cellar? yes no If not, which story 1st Kind of Fuel gas
Material of supports of heater or equipment (concrete floor or what kind) wood to be protected as required?
Minimum distance to wood or combustible material, from top of boiler or casing top of furnace, 10'
from top of smoke pipe 7' from front of heater 3' from sides or back of heater 3'
Size of chimney flue _____ Other connections to same flue _____

Hood to be provided over all

IF OIL BURNER

Statement attached _____ Labeled and approved by Underwriters' Laboratories? _____
Name and type of burner _____ Type of oil feed (gravity or pressure) _____
Will operator be always in attendance? _____ No. and capacity of tanks _____
Location oil storage _____ How many tanks fireproofed? _____
Will all tanks be more than seven feet from any flame? _____

Amount of fee enclosed? 2.50 (\$1.00 for one heater, etc., 50 cents additional for each additional heater building at same time.)
Portland Gas Light Co.

INSPECTION COPY

Signature of contractor

Wm. Bunting
134 69 20

Ward 5 Permit No. 38/1564

Location 564 Congress St

Owner Punitpa Tea Room

Date of permit 9/27/38.

Post Card sent _____

Notif for insp _____


Approval Tag issued _____

Oil Burner Check List (date) _____

1. Kind of heat _____
2. Label _____
3. Anti-siphon _____
4. Oil storage _____
5. Tank distance _____
6. Vent pipe _____
7. Fill pipe _____
8. Gauge _____
9. Rigidity _____
10. Feed safety _____
11. Pipe sizes and material _____
12. Control valve _____
13. Ash pit vent _____
14. Temp. or pressure safety _____
15. Instruction card _____
16. _____

NOTES

79880
one in file





APPLICATION FOR PERMIT

Class of Building or Type of Structure Second Class

Portland, Maine, February 16, 1937

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect alter install the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 588 Congress Street Ward 5 Within Fire Limits? yes Dist. No. 1
Owner's or Lessee's name and address Puritan Tea Room, 588 Congress St. Telephone _____
Contractor's name and address C. W. Hiles, 13 Atlantic Street Telephone no
Architect's name and address _____
Proposed use of building Stores and Offices No. families _____
Other buildings on same lot _____
Plans filed as part of this application? yes No. of sheets 1
Estimated cost \$ 20. Fee \$.25

Description of Present Building to be Altered

Material brick No. stories 5 1/2 Heat _____ Style of roof _____ Roofing _____
Last use Stores and Offices No. families _____

General Description of New Work

To remove studding and plaster in 14' bearing partition in rear of store (leaving iron columns as is) to enlarge existing kitchen, first floor,

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Height average grade to top of plate _____
Size, front _____ depth _____ No. stories _____ Height average grade to highest point of roof _____
To be erected on solid or filled land? _____ earth or rock? _____
Material of foundation _____ Thickness, top _____ bottom _____
Material of underpinning _____ Height _____ Thickness _____
Kind of Roof _____ Rise per foot _____ Roof covering _____
No. of chimneys _____ Material of chimneys _____ of lining _____
Kind of heat _____ Type of fuel _____ Is gas fitting involved? _____
Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
Material columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____

If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____
Total number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes
Puritan Tea Room

Signature of owner

INSPECTION COPY

By C. W. Hiles

72372

Ward 5 Permit No. 37/150
Location 566 Congress St.
Ow Puntana Tea Room
Date of permit 2/16/37
Notif. closing-in
Insp ing-in
Final Notif.
Final Inspn. 3/22/37
Cert. of Occupancy issued None

NOTES

2/22/37 - Protection
removed before
permit applied.
for - A.G.O.
3/2/37 - No change
since last inspec-
tion - A.G.O.
3/9/37 - Same A.G.O.



FILL IN COMPLETELY AND SIGN WITH INK

PERMIT NO. 152
FEE \$2.50

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

Portland, Maine, February 13, 1937

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location 566 Congress Street Use of Building Restaurant No. Stories 5
Name and address of owner Puritan Tea Room, 566 Congress Street Ward 5
Contractor's name and address Portland Gas Light Co., 5 Temple St. Telephone 2-8321

General Description of Work

To install gas fired bake oven and range
(relocation of gas appliances from one room to another on Free St. side of bldg.)

IF HEATER, POWER BOILER OR COOKING DEVICE

Is heater or source of heat to be in cellar? no If not, which story 1st Kind of Fuel gas
Material of supports of heater or equipment (concrete floor or what kind) wood oven 2' above floor
Minimum distance to wood or combustible material, from top of boiler or casing top of furnace protected
from top of smoke pipe 10' from front of heater over 4' from sides or back of heater 12"
Size of chimney flue with mechanical ventilation to outside Other connections to same flue IF OIL BURNER

Name and type of burner Labelled and approved by Underwriters' Laboratories?
Will operator be always in attendance? Type of oil feed (gravity or pressure)
Location oil storage No. and capacity of tanks
Will all tanks be more than seven feet from any flame? How many tanks fireproofed?

Amount of fee enclosed? 1.50 (\$1.00 for one heater, etc., 50 cents additional for each additional heater building at same time.)

INSPECTION COPY

Signature of contractor Portland Gas Light Co.

Ward 5 Permit No. 37/152^J
 Location 566 Congress St.
 Owner Quitandeg Room
 Date of permit 2/16/37
 Post Card sent _____
 Notif. for insp. _____
 Approval Tax _____
 Oil Burner Check List (date) 12/2/38 P.H.

1. Kind of heat	
2. Label	
3. Anti-siphon	
4. Oil storage	
5. Tank distance	
6. Vent pipe	
7. Fill pipe	
8. Gauge	
9. Rigidity	
10. Feed safety	
11. Pipe sizes and material	
12. Control valve	
13. Ash pit vent	
14. Temp. or pressure safety	
15. Instruction card	
16.	

NOTES

oven to be moved right
away and range later

2/15/37 - Installation of
 oven moved right
 permit. This is a
 very simple job
 at 566 Congress St.
 labor on oil burner
 and steel chimney
 to Niles is complete.
 To d.p. of release, and
 M.H. Co. to apply for
 permit to connect the
 furnace and that
 we will have permit
 in release.
 The installation of
 the oven is complete.
 2/2/37: Installation
 of oil made U.S.C.
 2/2/37: Oven moved.
 The permit stove
 is provided with
 a gas valve and
 is needed Range not
 moved. O.K.



(C) INDUSTRIAL ZONE

PERMIT ISSUED
Permit No. 1971

APPLICATION FOR PERMIT TO ERECT SIGN
OVER PUBLIC SIDEWALK OR STREET

Portland, Maine, November 9, 1936 19

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect the following described sign extending over a public sidewalk or street in accordance with the Building Code of the City of Portland, and the following specifications:

Location 588 Congress Street Ward 5 Within Fire Limits? yes Dist. No. 1

Owner of building to which sign is to be attached P. P. Baxter

Name and address of owner of sign Samson's Clothes, 588 Congress Street

Contractor's name and address Mack, The Signist, 44 Canal St. Lewiston Telephone 290

When does contractor's bond expire? August, 1937

Information Concerning Building

No. stories 4 Material of wall to which sign is to be attached brick

Details of Sign and Connections

Electric? yes Vertical dimension after erection 3'4" Horizontal 1'7"

Weight 600 lbs., Will there be any hollow spaces? yes Any rigid frame? yes

Material of frame angle iron No. advertising faces 1 material enamel iron

No. rigid connections 8 Are they fastened directly to frame of sign? yes

No. through bolts none Size _____, Location, top or bottom _____

No. guys no material _____, Size _____

Minimum clear height above sidewalk or street 12'

Maximum projection into street 1'7"

Mack, The Signist

Fec \$ 1.00

CHIEF OF FIRE DEPT.
INSPECTION COPY

Signature of contractor By A. Law

Ward 5 Permit No: 3611971

566 Congress St.

Owner: Sampson's Clothes

Date of permit 11/12/36

Contractor

Final Inspn. 11/12/36. C.B.

NOTES

11/12/36. Mr. McDonald
went over the method
of fastening this to the
face of the building.
Sampson's Clothes and
electrical inspector.
After erecting method
of fastening to building
could not be checked.
C.B.

ONE HUNDRED TWENTY MILK STREET
BOSTON

J. FREDERICK KROKYN
AMBROSE A. BROWNE
ARCHITECTS

October 17, 1936.

LIBERTY 6688

*A.P.S.
P.L. note and see if this
meets with your approval
10/19/36*

Mr. Warren McDonald,
Inspector of buildings,
City of Portland, Maine.

*Chief of Dept. of Bldg. Insp.
#1320- Samsons
Portland Me.*

Dear Mr. McDonald,-

Re- your letter of the 15th pertaining
to the alterations to 566 Congress Street, Portland, Maine.

The awning will not come closer than seven feet to the grade
of the sidewalk.

It is our plan to have one section of red glass in each
street bulkhead installed clear of any framing so that the
firemen can break this panel and have easy access to the
basement. The ceiling below will be cut for openings about
2 feet square. We would appreciate your approval of this
method as the unbroken red glass bulkhead is a feature of the
design of the store front.

Yours very truly,
Krokyn & Browne

by *Ambrose A. Browne*
Ambrose A. Browne

C.C. to Mr. Cohen, foreman at job.



File: Rec.6321B-I

October 15, 1936

Barnett Bros.
567 Harrison Avenue,
Boston, Mass.

Gentlemen:

Enclosed is the building permit covering alterations in the store at
568 Congress Street for Samson's Clothes Lessee.

A copy of this letter is being sent to Samson's Clothes, Krokyn & Brown, architects, and the owner of the building, calling the several attentions to the requirements of the Building Code of the City of Portland as pertains to clearances of awnings above sidewalks. The Building Code provides that no part of any awning shall be at any time closer than seven feet to the grade of the sidewalk beneath it. This interpreted to mean that the bottom of the fringe, if any, shall be at all points at least seven feet above all points of the grade of the sidewalk. In locating the new awning bar please see to it that it is placed high enough so that the type of awning intended will not violate the law.

I note that the new store front does not contemplate any openings leading to the cellar of the building beneath the show windows. A recent fire in the building next to this one proved baffling and exceedingly costly to quite an extent because the firemen could not get in to the cellar of the building from both ends and create a cross draft for ventilation. I realize that the building in which you are providing this store is equipped with an automatic sprinkler system which is, of course, a great help. This office has no intention of trying to compel you to put any ventilation openings beneath these new show windows, but I respectfully suggest that the prospective tenants and the owner of the building give consideration to providing either open grilles of incombustible material, or metal mesh and wire glass set in openings in such a way that they may be opened from the outside in case of need by the fire department so that there may be no possibility of a smoky fire in this basement hindering the fire department at bay while it does unnecessary damage.

Very truly yours,

WCB/H
CC: Hon. Percival P. Baxter
Samson's Clothes
Krokyn & Brown

Inspector of Buildings



GENERAL BUSINESS ZONE
APPLICATION FOR PERMIT

PERMIT ISSUED
1756

Class of Building or Type of Structure

OCT 15 1938

Portland, Maine,

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to ~~exam~~ alter install the following building ~~structure~~ equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 688 Congress Street Ward 5 Within Fire Limits? YES Dist. No. 1
Owner's or Lessee's name and address Samson's Clothes Telephone Liberty
Contractor's name and address Barnett Bros. 687 Harrison Ave. Boston Telephone 4831
Architect's name and address _____
Proposed use of building Stores No. families _____
Other buildings on same lot _____
Plans filed as part of this application? yes No. of sheets 2
Estimated cost \$ 1200. Fee \$ 3.75

Description of Present Building to be Altered

Material brick No. stories 5 Heat _____ Style of roof _____ Roofing _____
Last use Stores No. families _____

General Description of New Work

To remodel store front as per plan submitted - no structural change - no exposed woodwork
entrance doors to be double acting
Preliminary Permit given to Tear Out Only 10/14/38.

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately by and in the name of the heating contractor.

Details of New Work

Height average grade to top of plate _____
Size, front _____ depth _____ No. stories _____ Height average grade to highest point of roof _____
To be erected on solid or filled land? _____ earth or rock? _____
Material of foundation _____ Thickness, top _____ bottom _____
Material of underpinning _____ Height _____ Thickness _____
Kind of Roof _____ Rise per foot _____ Roof covering _____
No. of chimneys _____ Material of chimneys _____ of lining _____
Kind of heat _____ Type of fuel _____ Is gas fitting involved? _____
Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
Material columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____
Total number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes
By Samson's Clothes
By Barnett Bros.

INSPECTION OK Signature of owner _____
By _____
CHIEF OF FIRE DEPT.

Ward 5 Permit No. 36/1256

Location 555 Angu

Owner Samson Clothes

Date of permit 10/15/36

Notif. closing-in

Insp. 2-in


Final Notif.

Final Inspn. 6/17/37

Cert. of Occupancy issued None

NOTES

11/23/36 - Call of
glass above and
below stairs in
down not on 11/23



Ward 5 Permit No. 36/1456

Location 555 Anglin

Owner Samson Clothes

Date of permit 10/15/36

Notif. closing-in

Insp. in

Final Notif.

Final Inspn. 6/17/37

Cert. of Occupancy issued None

NOTES

11/23/36 All of
glass above door
broken chain in
door not on floor



FILL IN COMPLETELY AND SIGN WITH INK

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

PERMIT ISSUED

SEP 11 1936

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

Portland, Maine,

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location Puritan Tea Room, 588 Congress St.
Name and address of owner Portland Gas Light Co., 5 Temple St. Ward 2 5
Contractor's name and address _____ Telephone 2-28321

General Description of Work

To install

IF HEATER, POWER BOILER OR COOKING DEVICE

Is heater or source of heat to be in cellar? _____ If not, which story _____ Kind of Fuel gas
Material of supports of heater or equipment (concrete floor or what kind) wood
Minimum distance to wood or combustible material, from top of boiler or casing top of furnace, _____ side _____ back _____
from top of smoke pipe _____, from front of heater _____ no _____ from sides or back of heater _____
Size of chimney flue _____ Hood provided over ranges _____ Other connections to same flue _____

IF OIL BURNER

Name and type of burner _____ Labeled and approved by Underwriters' Laboratories? _____
Will operator be always in attendance? _____ Type of oil feed (gravity or pressure) _____
Location oil storage _____ No. and capacity of tanks _____
Will all tanks be more than seven feet from any flame? _____ How many tanks fireproofed? _____

Amount of fee enclosed? _____ (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)

INSPECTION COPY

Signature of contractor

By:

[Signature] 76743

Ward 5 Permit No. 36/1429
Location 566 Congress St.
Owner Puritan Tea Room
Date of permit 7/11/36

Post Card sent _____

Notif. for insp. _____

Approval Tag issued 11/25/36 note

Oil Burner Check List (date)

1. Kind of heat gas fired candy range
2. Label _____
3. Anti-siphon _____
4. Oil storage _____
5. Tank distance _____
6. Vent pipe _____
7. Fill pipe _____
8. Gauge _____
9. Rigidity _____
10. Feed safety _____
11. Pipe sizes and material _____
12. Control valve _____
13. Ash pit vent _____
14. Temp. or pressure safety _____
15. Instruction card _____
16. _____

NOTES

11/25/36. Mr. Sears covered this
while making another
section here.



GENERAL BUSINESS ZONE
APPLICATION FOR PERMIT

PERMIT ISSUED

1411

SEP 9 1936

Class of Building or Type of Structure Refrigeration

Portland, Maine, Sept. 8, 1936

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect, alter, install the following building-structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 162 Congress Street Ward 5 Within Fire Limits? yes Dist. No. 1
Owner's or Lessee's name and address Puritan Tea Room, 888 Congress St. Telephone _____
Contractor's name and address Geo. B. Williams Co., 10 Central Wharf Telephone 4-5764
Architect's name and address _____
Proposed use of building Stores and Offices No. families _____
Other buildings on same lot _____
Plans filed as part of this application? yes with five Dept. sheets
Estimated cost \$ 500. Fee \$.75

Description of Present Building to be Altered

Material brick No. stories 5 Heat _____ Style of roof _____ Roofing _____
Last use Stores and Offices No. families _____

General Description of New Work

To install refrigeration equipment for candy storage room in basement of building

It is understood that this permit does not include installation of heating apparatus which is to be taken out separately and the name of the heating contractor.

Details of New Work

Size, front _____ depth _____ No. stories _____ Height average grade to top of plate _____
To be erected on solid or filled land? _____ earth or rock? _____
Material of foundation _____ Thickness, top _____ bottom _____
Material of underpinning _____ Height _____ Thickness _____
Kind of Roof _____ Rise per foot _____ Roof covering _____
No. of chimneys _____ Material of chimneys _____ of lining _____
Kind of heat _____ Type of fuel _____ Is gas fitting involved? _____
Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
Material columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____
Total number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous


Will above work require removal or disturbing of any shade tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

INSPECTION CO. Geo. B. Williams Co.
Signature of owner Geo. B. Williams Co.
CHIEF OF FIRE DEPT.

Ward. 5 Permit No. 36/1411
Location 566 Cuyler St.
Owner P. J. T. P. P.
Date of permit 9/9/36
Notif. closing-in
Inspn. closing-in
Final Notif.
Final Inspn. 11/23/36
Cert. of Occupancy issued None

NOTES

11/23/36 Work done -
A. J.





GENERAL BUSINESS ZONE

APPLICATION FOR PERMIT

Permit No. 1405

Class of Building or Type of Structure Second Class

PERMIT ISSUED

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

Portland, Maine, September 8, 1936

The undersigned hereby applies for a permit to ~~erect~~ alter ~~install~~ the following building structure equipment in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith and the following specifications:

Location 588 Congress Street Ward 5 Within Fire Limits? yes Dist. No. 1
Owner's or Lessee's name and address Puritan Tea Room, 588 Congress St. Telephone _____
Contractor's name and address Portland Cabinet Works, 1019 1/2 Congress St. Telephone 3-6063
Architect's name and address _____
Proposed use of building Stores and Offices No. families _____
Other buildings on same lot no
Plans filed as part of this application? yes No. of sheets 1
Estimated cost \$ 150. Fee \$.75

Description of Present Building to be Altered

Material brick No. stories 7 Heat _____ Style of roof _____ Roofing _____
Last use Stores and offices No. families _____

General Description of New Work

To put in two partitions (2x5 studs, sheet rock on both sides) as shown on plan to provide two new toilets in restaurant, existing ventilating system to be used to vent same, doors to vestibules and toilets to be made self-closing in such a way that there will be little chance of both doors being open at the same time. New partitions to extend to ceiling.

It is understood that this permit does not include installation of heating apparatus which is to be taken care of separately by and to the name of the heating contractor.

Details of New Work

Size, front _____ depth _____ No. stories _____ Height average grade to top of plate _____
To be erected on solid or filled land? _____ earth or rock? _____ Height average grade to highest point of roof _____
Material of foundation _____ Thickness, top _____ bottom _____
Material of underpinning _____ Height _____ Thickness _____
Kind of Roof _____ Rise per foot _____ Roof covering _____
No. of chimneys _____ Material of chimneys _____ of lining _____
Kind of heat _____ Type of fuel _____ Is gas fitting involved? _____
Corner posts _____ Sills _____ Girt or ledger board? _____ Size _____
Material columns under girders _____ Size _____ Max. on centers _____
Studs (outside walls and carrying partitions) 2x4-16" O. C. Girders 6x8 or larger. Bridging in every floor and flat roof span over 8 feet. Sills and corner posts all one piece in cross section.
Joists and rafters: 1st floor _____, 2nd _____, 3rd _____, roof _____
On centers: 1st floor _____, 2nd _____, 3rd _____, roof _____
Maximum span: 1st floor _____, 2nd _____, 3rd _____, roof _____
If one story building with masonry walls, thickness of walls? _____ height? _____

If a Garage

No. cars now accommodated on same lot _____, to be accommodated _____
Total number commercial cars to be accommodated _____
Will automobile repairing be done other than minor repairs to cars habitually stored in the proposed building? _____

Miscellaneous

Will above work require removal or disturbing of any shade tree on a public street? no
Will there be in charge of the above work a person competent to see that the State and City requirements pertaining thereto are observed? yes

INSPECTION COPY

Signature of owner

Puritan Tea Room
Portland Cabinet Works

By:

John Nicholas


App'd by Rest. Insp.
9/9/36

76325

Ward 5 Permit No. 26/1405
Loc 566 Congress St.
Owner Quinton Tea Room
Date 9/9/36
Notif. closing-in
Inspn. closing-in
Final Notif.
Final Inspn. 11/23/36
Cert. of Occupancy issued None

NOTES

11/23/36 - Work done -
A.G.S.



PORTLAND GAS LIGHT COMPANY
PORTLAND, MAINE



June 7, 1976

Mr. Walter M. Donald
Inspector of Buildings
City Hall
Portland, Maine

Dear Sir:

We are today applying for a permit to install
one gas range, one gas oven and one gas heater at the
Puritan Tea Room, 500 Congress Street, Portland, Maine.

These appliances to be vented into a dome
shaped hood, with a six inch diameter vent pipe, extending ten
feet to an electric fan, which will draw all heat and
odors from appliances to the outside of the building. The
heat in this vent near fan will be less than 500° F. vent exit.

Very truly yours,

PORTLAND GAS LIGHT COMPANY

D. W. Lewis

D. W. Lewis

DTL:DP

IF ITS DONE WITH HEAT — YOU CAN DO IT BETTER WITH GAS



FILL IN COMPLETELY AND SIGN WITH INK

GENERAL BUSINESS ZONE

APPLICATION FOR PERMIT FOR HEATING, COOKING OR POWER EQUIPMENT

Permit No. 0250

PERMIT ISSUED

June 3, 1936 JUN 3 1936
Portland, Maine,

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location Puritan Candy Company, 888 Congress St. Use of Building Stores and Offices
Name and address of owner Portland Gas Light Co., 5 Temple St.
Contractor's name and address _____ Telephone 2-1221

General Description of Work
To install gas range, bake oven and hot water heater (gas)

IF HEATER, POWER BOILER OR COOKING DEVICE
Is heater or source of heat to be in cellar? 1st If not, which story _____ Kind of fuel gas
Material of supports of heater or equipment (concrete floor or what kind) tile - oven 12" water heater 8"
Minimum distance to wood or combustible material, from top of boiler or casing top of furnace, _____
from top of smoke pipe _____, from front of heater over 4' from sides or back of heater water heater 1' range & oven 8"
back will be 12"

Hood to be provided over range _____
Size of chimney _____

IF OIL BURNER
Name and type of burner _____ Labeled and approved by Underwriters' Laboratories? _____
Will operator be always in attendance? _____ Type of oil feed (gravity or pressure) _____
Location oil storage _____ No. and capacity of tanks _____
Will all tanks be more than seven feet from any flame? _____ How many tanks fireproofed? _____
2.00

Amount of fee enclosed? _____ (\$1.00 for one heater, etc., 50 cents additional for each additional heater, etc., in same building at same time.)
By: [Signature]
Signature of contractor [Signature]

INSPECTION COPY

W⁷ 5 Permit No. 36/750

Location 566 Congress St.

Owner Puritan Candy Co.

Date of permit 6/2/36

Post Card sent

Notif. for insp.


Approval tag issued 7/7/36


Oil Burner Check List (date)

1. Kind of heat
2. Label
3. Anti-siphon
4. Oil storage
5. Tank distance
6. Vent pipe
7. Fill pipe
8. Gauge
9. Rigidity
10. Feed safety
11. Pipe sizes and material
12. Control valve
13. Ash pit ve
14. Temp. or p. safety
15. Instruction card
- 16.

NOTES

1000







(C) GENERAL BUSINESS ZONE

PERMIT ISSUED
Permit No. 722

APPLICATION FOR PERMIT TO ERECT SIGN
OVER PUBLIC SIDEWALK OR STREET

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

Portland, Maine, May 21, 1936
Supersedes application of May 7, 1936

The undersigned hereby applies for a permit to erect the following described sign extending over a public sidewalk or street in accordance with the Building Code of the City of Portland, and the following specifications:

Location, 569 Congress Street Ward 5 Within Fire Limits? yes Dist. No. 1

Owner of building to which sign is to be attached P. P. Baxter

Name and address of owner of sign Puritan Candy Co., 570 Congress St.

Contractor's name and address United Neon Display 27 Monument Square Telephone 2-6895

When does contractor's bond expire? October, 1936

5/21/36. Permit issued as per to
adjustment of upper fastening
depending on actual found. P. P. O.
Information Concerning Building

No. stories 5 Material of wall to which sign is to be attached brick

Details of Sign and Connections

Electric? yes Vertical dimension after erection 57 1/2" Horizontal 18 1/2"

Weight 500 lbs. Will there be any hollow spaces? yes Any rigid frame? yes

Material of frame angle iron No. advertising faces 1 material sheet metal

No. rigid connections 6 Are they fastened directly to frame of sign? yes

No. through bolts None Size 1/2" Location, top or bottom both

No. guys no material Size

Minimum clear height above sidewalk or street 8'

Maximum projection into street 2'

Chas. V. Johnson

United Neon Display

Fee \$ 1.00


CHIEF OF FIRE DEPT.
INSPECTION COPY

Signature of contractor

By

Ralph C. Smith

57008





GENERAL BUSINESS CONCERN

Permit No. _____

APPLICATION FOR PERMIT TO ERECT SIGN OVER PUBLIC SIDEWALK OR STREET

Portland, Maine, May 7, 1938 19

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to erect the following described sign extending over a public sidewalk or street in accordance with the Building Code of the City of Portland, and the following specifications:

Location 588 Congress Street Ward 5 Within Fire Limits? yes Dist. No. 1
Owner of building to which sign is to be attached P. P. Baxter
Name and address of owner of sign Puritan Candy Co., 570 Congress St.
Contractor's name and address United Neon Display, 27 Monument Sq. Telephone 2-0695
When does contractor's bond expire? October, 1938

Information Concerning Building

No. stories 3 Material of wall to which sign is to be attached brick
On marquee yes
Details of Sign and Connections
Electric? yes Vertical dimension after erection 8' - 6" Horizontal 10' 2" - 3'
Weight 825 lbs. Will there be any hollow spaces? yes Any rigid frame? yes
Material of frame angle iron No. advertising faces 2 5, material metal
No. rigid connections 7 Are they fastened directly to frame of sign? yes
No. through bolts none, Size _____, Location, top or bottom _____
No. guys none, material _____, Size _____
Minimum clear height above sidewalk or street 15' 6"

Maximum projection into street none - on marquee

Wm. J. Sullivan
CHIEF OF FIRE DEPT.
INSPECTION COPY
Signature of contractor By United Neon Display

Fee \$ 1.00