

CUNNINGHAM
SECURITY SYSTEMS

October 22, 2019


Code Enforcement Office
City of Portland
389 Congress Street
Portland, ME 04101
(207) 874-8705
Fax#: (207) 874-8716

To Whom It May Concern:

This letter is to inform you that on October 18, 2019, we completed the installation, programming and testing of the new fire alarm devices in the newly renovated Diversified Communications space on the sixth floor of the building located at 562 Congress Street in Portland, Maine. These new fire alarm devices were tied into the building's existing fire alarm control panel and were tested to NFPA 72 standards with signals sent to and received at our central monitoring station. These new devices were all found to be fully functional at that time.

Should you have any questions or comments regarding this matter, please feel free to contact me at (207) 846-3350.

Sincerely,



Ronald S. Sneider, Manager

cc: Acct. File

Sprinkler Systems, Inc.

P.O. Box 1285

Lewiston, Maine 04243-1285

Ph. (207) 782-0104 Fax (207) 783-4865

Fire Protection Professionals Since 1973

October 23, 2019

Tony San Antonio
Wright-Ryan Construction, Inc
10 Danforth St
Portland, ME 04101


RE: Diversified Communications

Tony,

This letter is to certify that the sprinkler system in the affected areas of Diversified Communications Project located on the 6th floor at 121 Free St in Portland, ME is active and is installed in accordance with NFPA #13 and all other state and local codes.

Thank you again and please don't hesitate to contact us with any questions you may have.

Very truly yours,
Sprinkler Systems, Inc.



Jonathan Blanchard
Project Manager