

**CITY OF PORTLAND
Fire Department
380 Congress Street
Portland, Maine 041010011**

Fire Inspection Violations Listing

Business Name/Owner/Mgr/Location PICKWICK PROPERTIES LLC CHRISTOPHER CAMPBELL 0538 CONGRESS ST	Inspector BENJAMIN A WALLACE Shift: 005 Unit: C41		Inspection Date 1/12/2010
	Building Number 67357-0-2	CBL 037 H005001	Inspection Type FOOD SERVICE/ LIQUOR LICENSE

#	Type	Location	Notification Date	Target Compliance Date
1	DETECTION/ ALARM SYSTEMS	FIE ALARM SYSTEM SHALL BE INSPECTED BY APPROVED COMPANY. PROVIDE DOCUMENT.	1/12/2010	2/3/2010
2	EXTINGUISHMENT	SPRINKLER SYSTEM REQUIRES MAINTENANCE. PROVIDE DOCUMENTATION.	1/12/2010	2/3/2010
3	EXTINGUISHMENT	SPRINKLER HEAD MISSING IN BASEMENT STORAGE AREA AT SPACE GALLERY.	1/12/2010	2/3/2010
4	GENERAL	KNOX BOX REQUIRED AT FRONT ENTERANCE.	1/12/2010	2/3/2010