



1 Metal Stud Partition
NON-RATED




2 Metal Stud Partition
1-HOUR FIRE RATING - UL U465




3 Metal Stud Partition
2-HOUR FIRE RATING - UL U411

PARTITION NOTES:

- PARTITION CONSTRUCTION IS INDICATED BY DIMENSIONED THICKNESS AND ROOM FINISH SCHEDULE. ALL PARTITIONS NOT DIMENSIONED ARE CONSTRUCTED WITH 3 5/8" METAL STUDS.
- NEW PARTITION:
 - TO BE 3 5/8" 20 GAUGE METAL STUDS AT 16" O.C. WITH 1 (ONE) LAYER TYPE 'X' 5/8" GYPSUM WALLBOARD EACH SIDE, U.N.O.
 - WHERE WALL IS INFILL, OR ADJUSTMENT TO EXISTING WALL, MATCH EXISTING WALL THICKNESS.
 - EXTEND ALL PARTITIONS TO STRUCTURE ABOVE, U.N.O. PROVIDE SLIP-TRACK, OR OTHER ACCEPTABLE MEANS OF ALLOWING DEFLECTION IN THE ROOF, AT ALL FULL-HEIGHT PARTITIONS.
 - EXTEND NON-FULL HEIGHT PARTITIONS 3" ABOVE CEILING, MINIMUM, BRACE HORIZONTALLY TO STRUCTURE ABOVE AT 4'-0" O.C. STAGGERED.
- PROVIDE NON-COMBUSTIBLE FIRESTOPPING, AT THE CEILING, IN ALL PARTITIONS WHERE GYPSUM WALLBOARD ON BOTH SIDES OF THE PARTITION DOES NOT EXTEND TO THE ROOF DECK.
- PROVIDE 3 1/2" ACOUSTICAL INSULATION IN ALL NEW WALLS, U.N.O.



4 Metal Stud Furring at Existing Exterior Wall
Non Load Bearing / Non Rated Assembly



5 Sound Partitions- STC = 63 min.

Note: seal around all wall penetrations w/ UL approved firestop system(s)

RR A Richard Renner|Architects
133 South Main Street
Sharon, MA 01770
508.651.2385
508.651.0911 fax

35 Pleasant Street
Portland, ME 04101
207.773.9699
207.773.9699 fax

LICENSED ARCHITECT
CHARLES J. YOUNG
4118
STATE OF MAINE

PERMIT SUBMITTAL
AUGUST 07, 2014

MAINE COLLEGE OF ART
Lower Level Renovations
PHASE I
522 Congress Street
Portland, Maine

Wall Types
Drawn by: CY
File Name:
Scale: 1/2"=1'-0"
Date: 08.07.14
Project No. 2014-10.00
Revised:

MECA
LOWER LEVEL
Renovations
A3.2