1. PROVIDE FIRE ALARM DEVICES TO MATCH WITH THE EXITING SYSTEM. ALL WIRING SHALL BE PER MANUFACTURER'S REQUIREMENTS.
2. MODIFY EXISTING FIRE ALARM SYSTEM AS REQUIRED TO ACCOMMODATE NEW DEVICES.

FACP	FIRE ALARM CONTROL PANEL, MOUNT WITH TOP OF PANEL NOT MORE THAN 72"AFF
S	SMOKE DETECTOR
S E	SMOKE DETECTOR, "E" INDICATES CONNECTION FOR ELEVATOR RECALL
H	HEAT DETECTOR
H E	HEAT DETECTOR, "E" INDICATES CONNECTION FOR ELEVATOR RECALL
F	MANUAL PULL STATION, MOUNT 48" AFF
30 F	SPEAKER/STROBE NOTIFICATION APPLIANCE, CANDELA AS NOTED ON PLANS
15 O	STROBE ONLY NOTIFICATION APPLIANCE, CANDELA AS NOTED ON PLANS
30 F F	SPEAKER/STROBE WITH PULL STATION DIRECTLY BELOW
DH	MAGNETIC DOOR HOLD OPEN DEVICE
F	SPRINKLER SYSTEM WATER FLOW SWITCH, PROVIDED UNDER DIVISION 23, WIRED UNDER DIVISION 26
T	SPRINKLER SYSTEM TAMPER SWITCH, PROVIDED UNDER DIVISION 23, WIRED UNDER DIVISION 26

A1	FLOOR PLAN	A7	GENERAL NOTES	A9	SYMBOL LEGEND
SCALE: 1/8"=1'-0"					

160 Veranda Street
Portland, Maine 04103
T: 207.221.2260
F: 207.221.2266
Web: www.allied-eng.com

Allied Engineering
Structural Mechanical Electrical Commissioning

Reviewed for Code Compliance
Inspections Division
Approved: 10/03/14
Date: 10/03/14

MAINE LICENSED PROFESSIONAL ENGINEER
CATHERINE A. FAUCHER
No. 7375
PROFESSIONAL ENGINEER

REVISIONS

NUMBER	DATE	BY	DESCRIPTION

Date: AUG 2014
Drawn By: GMC
Checked By: KN
Project Mgr: AD
Project No: 14033
Cad File: 14033E.dwg
Graphic Scale: 0 1"

LOWER LEVEL FIRE ALARM PLAN

Maine College of ART
Lower Level- Phase 1
PORTLAND, MAINE

© COPYRIGHT 2012 ALLIED ENGINEERING, INC.

E-100

PERMIT SUBMITTAL ~ AUGUST 07, 2014

N:\Projects\2014\14033 ~ Maine College of ART - Lower Level Phase-1\00 Drawing Files\14033E.dwg Aug 07, 2014 - 1:26pm