



Mammoth Fire Alarms

Incorporated

176 Walker St., Lowell, MA 01854-3126

Tel. (978) 934-9130 Sales 1-800-995-9808 Fax (978) 934-9131

JOB NAME: MAINE COLLEGE OF ART - BASEMENT RENOVATION

CONTRACTOR: MANCINI ELECTRIC

DATE: 3/13/2015 11:47

LOOP # 5

ADDRESS	MODULE	# OF DEVICES	LOCATION/DEVICES	TYPE	LOGIC OUTPUTS
L5S001	2251	1	BASEMENT SMOKE OVER FACP		GENERAL ALARM
L5S002	2251	1	BASEMENT SMOKE ART GALLERY		GENERAL ALARM
L5S003	2251	1	BASEMENT SMOKE ART GALLERY		GENERAL ALARM
L5S004	2251	1	BASEMENT SMOKE ART GALLERY		GENERAL ALARM
L5S005	2251	1	BASEMENT SMOKE ART GALLERY		GENERAL ALARM
L5S006	2251	1	BASEMENT SMOKE MAIN STAIRS		GENERAL ALARM
L5S007	2251	1	BASEMENT SMOKE GALLERY STORAGE		GENERAL ALARM
L5S008	2251	1	BASEMENT SMOKE GALLERY STORAGE		GENERAL ALARM
L5S009	2251	1	BASEMENT SMOKE UTILITY ROOM		GENERAL ALARM
L5S010	2251	1	BASEMENT SMOKE PUMP ROOM		GENERAL ALARM
L5S011	2251	1	BASEMENT SMOKE FRT ELEV LOBBY		GENERAL ALARM
L5S012	2251	1	BASEMENT SMOKE HALL 3		GENERAL ALARM
L5S013	2251	1	BASEMENT SMOKE HALL 3		GENERAL ALARM
L5S014	2251	1	BASEMENT SMOKE HALL 3		GENERAL ALARM
L5S015	2251	1	BASEMENT SMOKE HALL 1		GENERAL ALARM
L5S016	2251	1	BASEMENT SMOKE HALL 1		GENERAL ALARM
L5S017	2251	1	BASEMET SMOKE BY COMP LAB		GENERAL ALARM
L5S018	2251	1	BASEMET SMOKE BY NEW STAIRS		GENERAL ALARM
L5S019	2251	1	BASEMENT SMOKE HALL 2		GENERAL ALARM
L5S020	2251	1	BASEEMENT SMOKE HALL 2		GENERAL ALARM
L5S021	2251	1	BASEMENET SMOKE ELEV LOBBY		GENERAL ALARM
L5S022	2251	1	BASEMENT SMOKE GALLERY LOBBY		GENERAL ALARM
L5S023	2251	1	BASEMENT SMOKE STORAGE		GENERAL ALARM
L5S024	2251	1	BASEMENT SMOKE REAR STAIR		GENERAL ALARM
L5S025	2251	1	BASEMENT SMOKE DET TBD		GENERAL ALARM
L5M101	710	1	BASEMENT PULL BY MAIN STAIRS		GENERAL ALARM
L5M102	710	1	BASEMENT PULL BY NEW STAIRS		GENERAL ALARM
L5M103	710	1	BASEMENT PULL BY REAR STAIRS		GENERAL ALARM
L5M104	710	1	BASEMENT PULL BY FREIGHT ELEV		GENERAL ALARM
L5M112	M500R	1	PRIMARY ELEV RECALL		Elev Recall Sequence to be Det on Site
L5M113	M500R	1	ALT ELEVATOR RECALL		Elev Recall Sequence to be Det on Site
L5M114	M500R	1	FIRE HAT		Elev Recall Sequence to be Det on Site

