#### DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

MAINE COLLEGE OF ART

Located at

**522 CONGRESS ST** 

**PERMIT ID:** 2017-00748

**ISSUE DATE:** 07/19/2017

CBL: 037 H006001

has permission to

Phase 2 Lower Level - construct new demising walls to create photo lab and office. New finishes, lights, and electrical. Fire and sprinkler systems to be modified as needed.

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 hour notice is required.

A final inspection must be completed before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Jason Grant

/s/ Jeanie Bourke

Fire Official

**Building Official** 

### THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

**Building Inspections** 

MUBEC/IBC 2009

Fire Department

Maine College of Art; artist studios

Use Group: B, A-3 & Type: 3A

S-1

Business - College photo lab/classrooms & Art Gallery Occupant Load = 280 + 35(phase 2) = 315 NFPA 13 sprinkler system Lower level-phase 2

## BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703

or email: buildinginspections@portlandmaine.gov

# Check the Status of Permit or Schedule an Inspection at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Division for the inspections listed below. Appointments must be requested 48 to 72 hours in advance. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that are attached to this permit.
- Permits expire in 6 months if the project is not started or ceases for 6 months.
- If the inspection requirements below are not followed, then additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC), one set of printed approved stamped construction documents will be kept at the site of work and open to inspection by building officials.

### **REQUIRED INSPECTIONS:**

Electrical Close-in w/Fire & Draftstopping Framing Only

**Above Ceiling Inspection** 

Certificate of Occupancy/Final Inspection

Final - Electric

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue.

If the permit requires a certificate of occupancy, it must be paid and issued to the owner or designee before the space may be occupied.

City of Portland, Maine - Building or Use Permit		Permit No:	Date Applied For:	CBL:
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874	4-8716	2017-00748	05/16/2017	037 H006001
posed Use:  Proposed Project Description:				
Maine College of Art	Phase 2 lab and	Lower Level - co	nstruct new demising nes, lights, and electri odified as needed.	
Dept: Historic Status: Approved w/Conditions Re	viewer:	Robert Wiener	Approval Da	ite: 07/19/2017
Note:	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,			Ok to Issue:
Conditions:				
1) No exterior alterations are approved with this permit.				
Dept: Zoning Status: Approved w/Conditions Re	viewer:	Christina Stacey	Approval Da	ite: 05/31/2017
Note:				Ok to Issue:
Conditions:				
1) This permit is approving interior work only.				
2) ANY exterior work requires a separate review and approval thru Historic Preservation. This property is located within an Historic District.				
3) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.				
Dept: Building Inspecti Status: Approved w/Conditions Re	viewer:	Jeanie Bourke	Approval Da	ite: 07/19/2017
Note:				Ok to Issue: 🔽
Conditions:				
1) Ventilation of this space is required per ASHRAE 62.2 or 62.1, 2007 edition.				
2) Equipment installation shall comply with the Manufacturers' Listing, and MUBEC codes and standards.				
3) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
4) All penetrations shall maintain the fire resistance rating of walls and ceilings with approved firestop materials, including electrical fixtures and exhaust vents per IBC Sec. 713 and IRC Sec. R302.4				
5) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept: Engineering DPS Status: Not Applicable Re	viewer:	Rachel Smith	Approval Da	ite: 05/24/2017
Note:				Ok to Issue: 🔽
Conditions:				
1) This approval is non-applicable to Engineering DPW as it relates Grease Program. If approval is needed for this project by the Eng FOG, please contact 874-8801.				
Dept: Fire Status: Approved w/Conditions Re	viewer:	Jason Grant	Approval Da	ite: 07/19/2017
Note:				Ok to Issue: 🔽
Conditions:				
<ol> <li>A separate City of Portland Water-Based Fire Suppression Syste standpipe systems, and sprinkler work effecting more than 20 hear installation.</li> </ol>		-	-	_

2) All construction shall comply with City Code, Chapter 10.

All construction shall comply with 2009 NFPA 101 Life Safety Code, Chapter # 43 and other applicable chapters

All construction shall comply with 2009 NFPA 1, Fire Code.

This review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code. NFPA 1 (section 1.14.4).

All means of egress to remain accessible at all times.

If applicable, all outstanding code violations shall be corrected prior to final inspection