

City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 516 Congress St		Owner: Pachios, Harold		Phone:		Permit No: 970571	
Owner Address:		Lessee/Buyer's Name: Levinsky's, Inc. Attn:		Phone: E. Levinsky		Business Name: 278 Congress ST	
Contractor Name:		Address:		Phone: Portland, ME 04101 774-6648		Permit Issued: JUN 10 1997	
Past Use: Retail		Proposed Use: Same		COST OF WORK: \$		PERMIT FEE: \$ 48.60	
				FIRE DEPT. <input type="checkbox"/> Approved <input type="checkbox"/> Denied		INSPECTION: Use Group: Type:	
Proposed Project Description: Erect Signage				Signature:		Signature:	
				PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)		Zoning Approval: B-3 CBL: 037-H-009	
				Action: Approved <input type="checkbox"/> Approved with Conditions: <input checked="" type="checkbox"/> Denied <input type="checkbox"/>		Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>	
Permit Taken By: Mary Gresik		Date Applied For: 20 May 1997		Signature: J. Andrews Date: 6/6/96			

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

PERMIT ISSUED WITH REQUIREMENTS

3 Property Box sign not approved

1) Large wooden sign approved for Congress Street

2) Individual letter sign on free st approved subject to approval of location and placement

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT <i>Phil Levinsky</i>		ADDRESS:		DATE: 20 May 1997		PHONE:	
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE						PHONE:	

Zoning Appeal

Variance
 Miscellaneous
 Conditional Use
 Interpretation
 Approved
 Denied

Historic Preservation

Not in District or Landmark
 Does Not Require Review
 Requires Review

Action:

Approved
 Approved with Conditions
 Denied

Date: 6/6/92

TA

CEO DISTRICT 2

A. Rose


BUILDING PERMIT REPORT

DATE: 6/6/97 ADDRESS: 516 Congress ST
REASON FOR PERMIT: To erect signage
BUILDING OWNER: Harold Pachios
CONTRACTOR: _____
PERMIT APPLICANT: Phil Keivinsky APPROVAL: X/ DENIED

CONDITION(S) OF APPROVAL

- X1. This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.
 2. Before concrete for foundation is placed, approvals from the Development Review Coordinator and Inspection Services must be obtained. (A 24 hour notice is required prior to inspection)
 3. Precaution must be taken to protect concrete from freezing.
 4. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify that the proper setbacks are maintained.
 5. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of ½ inch gypsum board or the equivalent applied to the garage means of ½ inch gypsum board or the equivalent applied to the garage side. (Chapter 4 Section 407.0 of the BOCA/1996)
 6. All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993) U.L. 103.
 7. Guardrail & Handrails A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42", except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-1, I-2 M and R and public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect.
 8. Headroom in habitable space is a minimum of 7'6".
 9. Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 3/4" maximum rise. All other Use group minimum 11" tread. 7" maximum rise.
 10. The minimum headroom in all parts of a stairway shall not be less than 80 inches.
 11. Every sleeping room below the fourth story in buildings of use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft.
 12. Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units.
 13. All vertical openings shall be enclosed with construction having a fire rating of at least one (1) hour, including fire doors with self closer's.
 14. The boiler shall be protected by enclosing with (1) hour fire-rated construction including fire doors and ceiling, or by providing automatic extinguishment.
 15. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9, Section 19, 920.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 18 & 19. (Smoke detectors shall be installed and maintained at the following locations):
 - In the immediate vicinity of bedrooms
 - In all bedrooms
 - In each story within a dwelling unit, including basements
- In addition to the required AC primary power source, required smoke detectors in occupancies in Use Groups R-2, R-3 and I-1 shall receive power from a battery when the AC primary power source is interrupted. (Interconnection is required)

- 16. A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved type.
- 17. The Fire Alarm System shall be maintained to NFPA #72 Standard.
- 18. The Sprinkler System shall maintained to NFPA #13 Standard.
- 19. All exit signs, lights, and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023. & 1024. Of the City's building code. (The BOCA National Building Code/1996)
- 20. All construction and demolition debris must be disposed at the City's authorized reclamation site. The fee rate is attached. Proof of such disposal must be furnished to the office of Inspection Services before final Certificate of Occupancy is issued or demolition permit is granted.
- 21. Section 25-135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".
- 22. The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification to the Division of Inspection Services.
- 23. This permit does not excuse the applicant from obtaining any license which may be needed from the City Clerk's office.
- 24. Ventilation shall meet the requirements of Chapter 12 Sections 1210. of the City's Building Code.
- 25. All electrical and plumbing permits must be obtained by a Master Licensed holders of their trade.
- 26. Please submit The structural plans for hanging signs before for approval before work begins
- 27. (a) Large wooden sign approved for Congress St, (b) Individual Letter sign on Free St, approved subject to approval of location and placement, (c) Projecting Cox sign Not Approved.
- 28. _____

 P. Samuel Hollars, Chief of Code Enforcement

cc: Lt. McDougall, PFD
 Marge Schymuckal
 D. Andrews SP

Please see both sides

SIGNAGE

PLEASE ANSWER ALL QUESTIONS

B3

Address: 516 CONGRESS ST. Zone: 04101
Owner: HAROLD PACHIOS Assessors #: 037-H-009
Applicant: LEVINSKY'S INC.

Single Tenant Lot?: Yes No

Multi Tenant Lot?: Yes No

Freestanding (Ext pole sign)? Yes No Dimensions see attached

More than (1) one sign?: Yes No Dimensions 2 on Free St

Bldg Wall Sign (att to bldg)? Yes No Dimensions 1 on Congress

List all existing signage and their dimensions:

Congress St 30" X 30'
Free St ① 2' X 8' & ② 1.5' X 18'

Lot Frontage(feet): _____ Tenant Frontage(feet): _____

56' Along Free St.
55' Along Congress St

AWNINGS


Awning?: Yes No Is Awning Backlit?: Yes No

Is there any communication, message, trademark or symbol on awning? _____

Height of Awning?: _____

PLEASE NOTE: Approvals for signs on the Public Sidewalk and temporary signs come under different requirements and regulations.

ALSO: See reverse side for additional information, requirements and materials needed for signage application submittal.





PRETI, FLAHERTY, BELIVEAU & PACHIOS, LLC

ATTORNEYS AT LAW

443 CONGRESS STREET
P.O. BOX 11410
PORTLAND, MAINE 04104-7410

(207) 791-3000

TELEFAX (207) 791-3111

Internet: www.pfbpnet.com

E-Mail: admin@pfbpnet.com



AUGUSTA OFFICE
45 MEMORIAL CIRCLE
P.O. BOX 1058
AUGUSTA, MAINE 04332-1058
(207) 623-5300
TELEFAX (207) 623-2914

SENIOR COUNSEL TO THE FIRM

HON. GEORGE J. MITCHELL

COUNSEL

ROBERT F. PRETI
ALBERT J. BELIVEAU, JR.
ROBERT W. SMITH

JEANNE T. COHN-CONNOR
ROBERT O. NEWTON
CARRIE A. GREEN
GREGORY P. HANSEL

ASSOCIATE COUNSEL

JAMES E. PHIPPS
SCOTT T. RODGERS
KEVIN J. BEAL
PENNY LITTELL
TIMOTHY J. BRYANT
ELIZABETH J. WYMAN
JOHN S. RUDD

ERIN RODRIGUEZ
LESLIE F. MENCHER*
BONNIE L. MARTINOLICH
DONALD J. SIPE
CHARLES J. GLASSER
ELIZABETH A. CAMPBELL
MATTHEW J. LaMOURIE

* Admitted to practice law only in Texas.

SEVERIN M. BELIVEAU
HAROLD C. PACHIOS
MICHAEL J. GENTILE
KEITH A. POWERS
CHRISTOPHER D. NYHAN
ERIC P. STAUFFER
JONATHAN S. PIPER
DANIEL RAPAPORT
JOHN P. DOYLE, JR.
BRUCE C. GERRITY
ANTHONY W. BUXTON
JEFFREY T. EDWARDS
MICHAEL G. MESSERSCHMIDT
RANDALL B. WEILL
JAMES C. PITNEY, JR.
EVAN M. HANSEN
VIRGINIA E. DAVIS
EDWARD R. BENJAMIN, JR.

LEONARD M. GULINO
DENNIS C. SBREGA
GEOFFREY K. CUMMINGS
ESTELLE A. LAVOIE
SUSAN E. LoJUDICE
MICHAEL KAPLAN
MICHAEL L. SHEEHAN
JOSEPH G. DONAHUE
DAVID B. VAN SLYKE
ANN R. ROBINSON
STEPHEN E. F. LANGSDORF
JOHN P. McVEIGH
ELIZABETH A. OLIVIER
CHARLES F. DINGMAN
MARK B. LEDUC
NELSON J. LARKINS
DEIRDRE M. O'CALLAGHAN

JOHN J. FLAHERTY (1929 - 1995)

May 20, 1997


Mr. Philip Levinsky
39 Pya Road
Portland, ME 04103

Dear Phil:

This will confirm our discussions regarding signage on the former Porteous annex building. You propose to utilize over the Congress Street entrance to your store the long black and gold sign now located on the Congress Street side of your existing store at the corner of Congress and India Streets. We consent to the utilization of this sign. In addition, you intend to use over the Free Street entrance to the Porteous annex the gold-burnished metal letters which are now found at the entrance to your existing store from the corner of Congress and India Streets. The exact location of the signs is something that we need to discuss in order to make sure it enhances (or at least does not detract from) the aesthetics of the Porteous annex building.

I look forward to discussing this with you or Eric when it is time to put up the signs. Perhaps we can walk the site together.

Sincerely,



Harold C. Pachios

HCP/ldr

HCP\d:\a-hcp\corres\1997\levi0520.doc

Received
5/23/97