

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND

BUILDING PERMIT

This is to certify that HIGH TECH FIRE PROTECTION
of PO Box 156, Minot, ME 04258

For installation at 510 CONGRESS ST, FLR 3
City Center Plaza


Job ID: 2011-08-1924-FAFS

CBL: 037 - - H - 010 - 001 - - - -

has permission to install a partial sprinkler fit up of 3rd floor
provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of
the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of
the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured
before this building or part thereof is lathed or otherwise
closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner
before this building or part thereof is occupied. If a
certificate of occupancy is required, it must be

 (58)

Fire Prevention Officer

Code Enforcement Officer / Plan Reviewer

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
PENALTY FOR REMOVING THIS CARD**

BUILDING PERMIT INSPECTION PROCEDURES

Please call 874-8703 or 874-8693 (ONLY)

or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.



PORTLAND MAINE

Strengthening a Remarkable City, Building a Community for Life • www.portlandmaine.gov

Director of Planning and Urban Development
Penny St. Louis

Job ID: 2011-08-1924-FAFS
Partial sprinkler fit up of the 3rd floor

For installation at:
510 CONGRESS ST, FLR 3
City Center Plaza

CBL: 037 - - H - 010 - 001 - - - -

Conditions of Approval:

Fire

The sprinkler system shall be installed in accordance with NFPA 13.

Sprinkler protection shall be maintained. Where the system is to be shut down for maintenance or repair, the system shall be checked at the end of each day to insure the system has been placed back in service.

The Fire Department will require Knox locking caps on all Fire Department Connections on the exterior of the building.

System acceptance and commissioning must be coordinated with alarm and suppression system contractors and the Fire Department. Call 874-8703 to schedule.

Installation of a sprinkler or fire alarm system requires a Knox Box to be installed per city ordinance.



Fire Suppression System Permit

2011 08 1924 RECEIVED

AUG - 4 2011

If you or the property owner owes real estate or property taxes or user charges on any property within the city, payment arrangements must be made before permits of any kind are accepted.

Dept. of Building Inspections
City of Portland Maine

Installation address: 510 Congress Street CBL: 089 H01U

Exact location: (within structure) 3rd floor

Type of occupancy(s) (NFPA & ICC): Light

Building owner: _____

Managing Supervisor: Ed Poulon License No: 515

Supervisor phone: 207-998-2551 E-mail: epoulon@fairpoint.net

Installing contractor: High Tech Fire Protection License No: 102

Contractor phone: 207-998-2551 E-mail: htfp@fairpoint.net

The suppression work to be done will be: New: Renovation: Addition to existing system:

This is an amendment to an existing permit: Yes: NO Permit no: _____

NFPA Standard will this system is designed to: 13 Edition: 2007

*Non-NFPA systems are not approved for use within the City of Portland.

Download a new copy of this document from Inspection Division on-line at www.portlandmaine.gov for every submittal. Attach all design information and complete approved submittals as may be required by the State Fire Marshal's Office on 11X17 copies or electronic PDF's in addition to full sized plans.

Contractor shall verify location and type of all FDCs shall be approved in writing by the Fire Prevention Bureau.

Submit all information to the Building Inspections Department, 389 Congress Street, Room 315, Portland, Maine 04101.

Prior to acceptance of any fire protection system, a complete commissioning and acceptance test must be coordinated with all fire system contractors and the Fire Department, and proper documentation of such test(s) provided.

All installation(s) must comply with NFPA and the Fire Department Technical Standard(s).

COST OF WORK:	<u>\$4000</u>
PERMIT FEE:	<u>\$60</u>
(\$10 PER \$1,000 + \$30 FOR THE FIRST \$1,000)	

Applicant signature: Edward Poulon Date: 8-1-11



CITY OF PORTLAND, MAINE

Department of Building Inspections

Original Receipt

August 9 2011

Received from Handyman

Location of Work 515 Maple St

Cost of Construction \$ _____ Building Fee: _____

Permit Fee \$ _____ Site Fee: _____

Certificate of Occupancy Fee: _____

Total: _____

Building (IL) Plumbing (I5) _____ Electrical (I2) _____ Site Plan (U2) _____

Other _____

CBL: 037 H016

Check #: 1115 Total Collected \$ 10.00

**No work is to be started until permit issued.
Please keep original receipt for your records.**

Taken by: [Signature]

WHITE - Applicant's Copy
YELLOW - Office Copy
PINK - Permit Copy