



T = NEW THERMOSTAT TO BE : ROBERT SHAW 9701i2

1 THERMOSTAT REPLACEMENT PLAN
3/32" = 1'-0"

- THERMOSTAT NOTES**
- 1.) PROVIDE ALL WIRING, BATTERIES AND CONNECTIONS AS REQUIRED FOR FULLY OPERATIONAL THERMOSTATS.
 - 2.) PROVIDE SET UP AND CALIBRATION WITH EXISTING MECHANICAL EQUIPMENT.
 - 3.) SET THERMOSTATS PER OWNER REQUEST. TRAIN OWNER IN OPERATION OF THERMOSTATS.