T = NEW THERMOSTAT TO BE : ROBERT SHAW 9701i2

1 THERMOSTAT REPLACEMENT PLAN
3/32" = 1'-0"

THERMOSTAT NOTES	
1.)	PROVIDE ALL WIRING, BATTERIES AND CONNECTIONS AS REQUIRED FOR FULLY OPERATIONAL THERMOSTATS.
2.)	PROVIDE SET UP AND CALIBRATION WITH EXISTING MECHANICAL EQUIPMENT.
3.)	SET THERMOSTATS PER OWNER REQUEST. TRAIN OWNER IN OPERATION OF THERMOSTATS.

REGISTERED ARCHITECT RYAN J. SENATORE No. 3322 STATE OF MAINE

© 2014 RYAN SENATORE ARCHITECTURE

MEPS
510 CONGRESS STREET
PORTLAND, MAINE

RSA
RYAN SENATORE
ARCHITECTURE
565 CONGRESS STREET
SUITE 304
PORTLAND, MAINE 04101
207-650-6414
senatorearchitecture.com

CONSULTANTS:

REVISIONS:

DATE: OCTOBER 30, 2014
PROJECT No.
DRAWN BY: RRT / RJS
CHECKED BY: RJS
SCALE: AS NOTED

SHEET TITLE:
THERMOSTAT REPLACEMENT PLAN

A1-9