RESURGAM. MAINE. CITY OF PORTLAND
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 07/21/14

15 Brown St. - Basement

Exterior walls of unit - Fire rated drywall with Fire rated caulk at penetrations