

LINTEL SCHEDULE LINTEL SIZE DPENING UP TO 3'-0" L3 1/2x3 1/2x5/16 3'-1"-4'-6" L4x3 1/2x5/16 (4" LEG VERT.) 4'-7'-6'-0' L5x3 1/2x5/16 (5' LEG VERT.) 6'-1'-8'-0' L6x3 1/2x5/16 (6' LEG VERT.)

NOTES:

1. PROVIDE LINTELS OVER ALL OPENINGS EXCEPT WHERE LINTEL BLOCKS ARE PROVIDED.

2. PROVIDE ONE ANGLE FOR EACH 4" OF WALL THICKNESS. FOR 6" WALLS, PROVIDE WT OR BUILT-UP SECTION WITH PROPERTIES EQUAL TO OR GREATER THAN 1 1/2 TIMES THE ANGLE PROPERTIES FOR A 4" WALL THICKNESS.

3. PROVIDE 8" OF BEARING @ EACH END OF ALL LINTELS.

4. ALL EXTERIOR LINTELS SHALL BE HOT-DIPPED GALVANIZED.

490 Congress Street Portland, Maine FOR PERMIT ONLY NOT FOR CONSTRUCTION Kimball Building, LLC Portland, Maine James Sterling AIA

Architect 142 High Street Portland, Maine

SCALE: 1/8" = 1'-0"

FOUNDATION PLAN

May 26, 2005

S-1.1

NOTES: 1. (*) - INDICATES EXISTING GRANITE FOOTINGS TO BE REMOVED 2. (**) - INDICATES NEW STEEL ENCASED CONCRETE
PILE

OF L&L STRUCTURAL ENGINEERING SERVICES, INC.