

**City of Portland, Maine - Building or Use Permit**

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

<b>Permit No:</b> 03-0364	<b>Date Applied For:</b> 04/10/2003	<b>CBL:</b> 037 I002001
------------------------------	--	----------------------------

<b>Location of Construction:</b> 490 Congress St	<b>Owner Name:</b> Kojie Corporation	<b>Owner Address:</b> 492 Congress St	<b>Phone:</b> ( ) 671-7550
<b>Business Name:</b>	<b>Contractor Name:</b> Leavitt & Parris Inc.	<b>Contractor Address:</b> 256 read St. Portland	<b>Phone</b> (207) 797-0100
<b>Lessee/Buyer's Name</b>	<b>Phone:</b>	<b>Permit Type:</b> Awning, with signage	

Salon/Spa	Erect 29'6" x 3'10" Stationary Awning
-----------	---------------------------------------

<b>Dept:</b> Historical	<b>Status:</b> Not Applicable	<b>Reviewer:</b> Deborah Andrews	<b>Approval Date:</b> 05/07/2003
<b>Note:</b>			<b>Ok to Issue:</b> <input checked="" type="checkbox"/>

<b>Dept:</b> Zoning	<b>Status:</b> Approved	<b>Reviewer:</b> Marge Schmuckal	<b>Approval Date:</b> 05/05/2003
<b>Note:</b>			<b>Ok to Issue:</b> <input checked="" type="checkbox"/>

<b>Dept:</b> Building	<b>Status:</b> Approved with Conditions	<b>Reviewer:</b> Mike Nugent	<b>Approval Date:</b> 05/16/2003
<b>Note:</b>			<b>Ok to Issue:</b> <input type="checkbox"/>
1) Lowest part of the awning must be at least 7 feet above the side walk			

**Comments:**  
5/8/2003-mjn: need structurals, height above the sidewalk, Carl Rickett at Leavitt & Parris notified  
Received 5/12/03 mjn

7/27/04

closed

AR