

**City of Portland, Maine – Building or Use Permit Application** 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 486 Congress St.		Owner: Donna Barthe		Phone:		Permit No: 37-I-005	
Owner Address: 367 SS Rte. 1, Falmouth 04109		Lessee/Buyer's Name: Robert Whisnant		Phone: 761-2911		Business Name: Latte Cafe	
Contractor Name:		Address:		Phone:		Permit Issued: 020161	
Past Use: Restaurant		Proposed Use: Same w/interior reno		COST OF WORK: \$4,000.00		PERMIT FEE: \$40.00	
				FIRE DEPT. <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied		INSPECTION: Use Group 83 Type: 7R	
Proposed Project Description: Interior renovation as per plans				Signature: [Signature]		Signature: [Signature]	
				PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)		Zoning Approval:	
				Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied		Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>	
Permit Taken By: Vicki Dover		Date Applied For: 2/26/97				Zoning Appeal: <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied	

**PERMIT ISSUED**  
**FEB 28 1997**

**CITY OF PORTLAND**

**PERMIT ISSUED WITH REQUIREMENTS**

Call 828-8755 or 761-2911 for P/U

**CERTIFICATION**

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

486 Congress St., Portland 04101      2/26/97

SIGNATURE OF APPLICANT Robert Whisnant ADDRESS: \_\_\_\_\_ DATE: \_\_\_\_\_ PHONE: \_\_\_\_\_

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE \_\_\_\_\_ PHONE: \_\_\_\_\_

White-Permit Desk   Green-Assessor's   Canary-D.P.W.   Pink-Public File   Ivory Card-Inspector

CEO DISTRICT [Signature]

A. F. CLOVE

**City of Portland, Maine – Building or Use Permit Application** 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 486 Congress St.		Owner: Donna Barthe		Phone:		Permit No: <b>970161</b>	
Owner Address: 367 US Rte. 1, Falmouth 04105		Lessee/Buyer's Name: Robert Whisnant		Phone: 761-2911		Business Name: Latte Cafe	
Contractor Name:		Address:		Phone:		Permit Issued: <b>FEB 28 1997</b> CITY OF PORTLAND	
Past Use: Restaurant		Proposed Use: Same w/interior reno		COST OF WORK: \$4,000.00		PERMIT FEE: \$40.00	
				FIRE DEPT. <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied		INSPECTION: Use Group: <i>B3</i> Type: <i>3B</i> <i>BOCA 96</i>	
				Signature: <i>[Signature]</i>		Signature: <i>[Signature]</i>	
Proposed Project Description: Interior renovation as per plans		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) <i>4B</i>		Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied		Zoning Approval: <i>sep. permit needed for any new signage</i> Special Zone of Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <i>dk 2/26/97</i> <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>	
Permit Taken By: Vicki Dover		Date Applied For: 2/26/97		Signature: <i>D. Andrews</i>		Date: <i>2/26/97</i>	

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

*signage & awning must be reviewed separately*

**PERMIT ISSUED WITH REQUIREMENTS**

Call 828-8755 or 761-2911 for P/U

**CERTIFICATION**

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

*[Signature]*

SIGNATURE OF APPLICANT Robert Whisnant ADDRESS: 486 Congress St., Portland 04101 DATE: 2/26/97 PHONE:

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE PHONE:

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

- Zoning Appeal**
- Variance
  - Miscellaneous
  - Conditional Use
  - Interpretation
  - Approved
  - Denied

- Historic Preservation**
- Not in District or Landmark
  - Does Not Require Review
  - Requires Review

- Action:**
- Approved
  - Approved with Conditions
  - Denied

Date: \_\_\_\_\_

CEO DISTRICT *#2*  
*A. ROWE*

# ELECTRICAL PERMIT

## City of Portland, Me.



To the Chief Electrical Inspector, Portland Maine:  
 The undersigned hereby applies for a permit to make electrical installations  
 in accordance with the laws of Maine, the City of Portland Electrical Ordinance,  
 National Electrical Code and the following specifications:

Date 9/5/97

LOCATION: 435 Congress St

Permit # \_\_\_\_\_

OWNER J B Brown Co ADDRESS \_\_\_\_\_

37-I.005

							TOTAL EACH FEE		
<b>OUTLETS</b>		Telephone		Data		CATV		.20	
	10	Receptacles	4	Switches		Smoke Detector	14	.20	
<b>FIBER OPTICS</b>								15.00	
<b>FIXTURES</b>	2	incandescent	13	fluorescent			15	.20	
		fluorescent strip						.20	
<b>SERVICES</b>		Overhead				TTL AMPS TO	800	15.00	
		Underground					800	15.00	
<b>Temporary Service</b>		Overhead				AMPS OVER	800	25.00	
		Underground					800	25.00	
<b>METERS</b>		(number of)						1.00	
<b>MOTORS</b>		(number of)						2.00	
<b>RESID/COM</b>		Electric units						1.00	
<b>HEATING</b>		oil/gas units		Interior		Exterior		5.00	
<b>APPLIANCES</b>		Ranges		Cook Tops		Wall Ovens		2.00	
		Insta-Hot		Water heaters		Fans		2.00	
		Disposals		Dishwasher		Compactors		2.00	
<b>MISC. (number of)</b>		Air Cond/win						3.00	
		Air Cond/cent				Pools		10.00	
	1	HVAC		EMS		Thermostat	1	5.00	
		Signs						10.00	
		Alarms/res						5.00	
		Alarms/com						15.00	
		Heavy Duty(CRKT)						2.00	
		Circus/Carnv						25.00	
		Alterations						5.00	
		Fire Repairs						15.00	
	3	E Lights					3	1.00	
		E Generators						20.00	
<b>PANELS</b>		Service		Remote	1	Main	1	4.00	
<b>TRANSFORMER</b>		0-25 Kva						5.00	
		25-200 Kva						8.00	
		Over 200 Kva						10.00	
							TOTAL AMOUNT DUE		
<b>MINIMUM FEE/COMMERCIAL 35.00</b>							<b>MINIMUM FEE</b>	<b>25.00</b>	<b>35</b>

INSPECTION: Will be ready 9/5- am or will call \_\_\_\_\_

CONTRACTORS NAME Place Elect - Chuck Place MASTER LIC. # 10526  
 ADDRESS 156 Summit St- Ptl'd LIMITED LIC. # \_\_\_\_\_  
 TELEPHONE 797-9954

SIGNATURE OF CONTRACTOR Chuck Place

# BUILDING PERMIT REPORT

DATE: 2/26/97 ADDRESS: 486 Congress St

REASON FOR PERMIT: Renovation

BUILDING OWNER: Dennis Barth

CONTRACTOR: \_\_\_\_\_

PERMIT APPLICANT: Robert Whisnand APPROVAL: \*1 \*7 \*8 \*9 \*10 \*14

DENIED: 7/6 \*19

## CONDITION OF APPROVAL ORDINANCE

1. This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.
  2. Before concrete for foundation is placed, approvals from the Development Review coordinator and Inspection Services must be obtained. (A 24 hour notice is required prior to inspection)
  3. Precaution must be taken to protect concrete from freezing.
  4. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify that the proper setbacks are maintained.
  5. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of ½ inch gypsum board or the equivalent applied to the garage means of ½ inch gypsum board or the equivalent applied to the garage side. (Chapter 4 Section 407.0 of the BOCA/1996)
  6. All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993) UL 103.
  7. Guardrail & Handrails A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42", except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-1, I-2 M and R and public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect.
  8. Headroom in habitable space is a minimum of 7'6".
  9. Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 3/4" maximum rise. All other Use group minimum 11" tread. 7" maximum rise.
  10. The minimum headroom in all parts of a stairway shall not be less than 80 inches.
  11. Every sleeping room below the fourth story in buildings of use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft.
  12. Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units.
  13. All vertical openings shall be enclosed with construction having a fire rating of at least one (1) hour, including fire doors with self closer's.
  14. The boiler shall be protected by enclosing with (1) hour fire-rated construction including fire doors and ceiling, or by providing automatic extinguishment.
  15. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's building code Chapter 9, Section 19, 920.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 18 & 19. (Smoke detectors shall be installed and maintained at the following locations):
    - In the immediate vicinity of bedrooms
    - In all bedrooms
    - In each story within a dwelling unit, including basements
- In addition to the required AC primary power source, required smoke detectors in occupancies in Use Groups R-2, R-3 and


I-1 shall receive power from a battery when the AC primary power source is interrupted. (Interconnection is required)

- 16. A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved type.
- 17. The Fire Alarm System shall be maintained to NFPA #72 Standard.
- 18. The Sprinkler System shall maintained to NFPA #13 Standard.
- 19. All exit signs, lights, and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023. & 1024. Of the City's building code. (The BOCA National Building Code/1996)
- 20. All construction and demolition debris must be disposed at the City's authorized reclamation site. The fee rate is attached. Proof of such disposal must be furnished to the office of Inspection Services before final Certificate of Occupancy is issued or demolition permit is granted.
- 21. Section 25-135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".
- 22. The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification to the Division of Inspection Services.
- 23. This permit does not excuse the applicant from obtaining any license which may be needed from the City Clerk's office.
- 24. Ventilation shall meet the requirements of Chapter 12 Sections 1210. of the City's Building Code.
- 25. \_\_\_\_\_
- 26. \_\_\_\_\_
- 27. \_\_\_\_\_




\_\_\_\_\_  
P. Samuel Hoffses, Chief of Code Enforcement

cc: Lt. McDougall, PFD  
Marge Schmuackal




Little Cafe  
New Layout

Upper Level



Past Layout



Lower Level

