Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 01/28/16

ROOF PLAN

SCALE: 1/8"=1'-0"

2 EXISTING FLOOR/CEILING ASSEMBLY-1 HOUR
UL: L501 SIM STC 50 MIN.

1 PROPOSED FLOOR/CEILING ASSEMBLY-1 HOUR
UL: L507sim. STC 50 MIN.

2 EXISTING FLOOR/CEILING ASSEMBLY-1 HOUR
UL: L501 SIM STC 50 MIN.

3 PROPOSED FLOOR/CEILING ASSEMBLY-2 HOUR
UL: L507sim. STC 50 MIN.

WALL AND FLOOR SYSTEM DETAIL

WALL LEGEND

- NEW WALL
- EXISTING WALL
- DEMOLISHED WALL

LIFE SAFETY LEGEND:

- EMERGENCY BACKUP LIGHT
- EXIT LIGHT
- EXIT/EMERGENCY BACKUP LIGHT COMBO
- SD — SMOKE DETECTOR
- SD/CO — SMOKE & CO DETECTOR
- HORN/STROBE
- STROBE
- FIRE EXTINGUISHER IN RECESSED CABINET
- PS — PULL STATION

LIFE SAFETY NOTES:

LIFE SAFETY AND FIRE ALARM SYSTEMS SHALL BE DESIGNED AND INSTALLED PER NFPA 72, BY A CITY/ STATE APPROVED CONTRACTOR WITH A SEPERATE PERMIT.

ALL STROBES TO BE 30 CANDELA UNLESS OTHERWISE NOTED.

SYSTEM SHALL BE SUPERVISED BY AN OFF-SITE CERTIFIED BY THE CITY OF PORTLAND THIRD PARTY

PERMITTING AND INSTALLTION OF THE LIFE SYSTEM SHALL BE PERMITTED AND PERFORMED BY A CITY APPROVED CONTRACTOR

FOURTH FLOOR PLAN

SCALE: 1/8"=1'-0"

THIRD FLOOR PLAN

SCALE: 1/8"=1'-0"

REVISED: JANUARY 25, 2016
BUILDING PERMIT: OCTOBER 20, 2015

FOR CONSTRUCTION

LICENSED ARCHITECT MARK L. MUELLER No. 2737

MARK MUELLER ARCHITECTS A.I.A.
100 Commercial Street
Suite 205
Portland, Maine 04101
Phone: 207.774.9057
Email: rfi@muellerarchitects.com

© COPYRIGHT 2015 MARK MUELLER ARCHITECTS

EASTMAN BLOCK CONDOS

11 BROWN STREET
PORTLAND, MAINE

THIRD/FOURTH FLOOR PLANS

REVISIONS	
DATE	11.10.15
PROJECT	11 BROWN STREET
DRAWN BY	MLM/TJD
CHECK BY	MLM

A-1.2