



CUNNINGHAM
SECURITY SYSTEMS

October 21, 2016

Fire Prevention Bureau
Portland Fire Department
380 Congress Street
Portland, ME 04101
Fax#: (207) 874-8410

To Whom It May Concern:

This letter is to inform you that on October 17th, 2016, we completed the installation, programming and testing of the new fire alarm devices on the 2nd, 3rd and 4th floors as well as the new fire alarm control panel in the basement of the building located at 11 Brown Street, Portland, ME. These new devices and control panel were installed, programmed and test to NFPA 72 standards with all signals sent to and received at our central monitoring station. All these devices were found to be fully functional at that time.

Should you have any questions or comments regarding this matter, please feel free to contact me at (207) 846-3350.

Sincerely,

Ronald S. Snieder, Manager

cc: Acct. File