Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 11/13/15

Good morning Rob,

Per our discussion on Thursday, here are the dimensions of the air vent intake as well as a proposed exhaust vent for the furnace.

The fresh air intake that will be to the right side of the door will be a 14" x 14" flush mounted, louvered vent (black) that will fit perfectly inside the existing upper wooden panel detail. This dimension will allow us to add the necessary rail piece of trim to match the cross portions of the other panels and window units. As to the furnace exhaust, our best option for minimizing pipe and elbows is a 4 1/2" concentric vent which comes straight out of the building and has a cap like end on it resembling and old style fire alarm bell. It allows not only exhaust out but fresh air in. A pipe within a pipe. Images are readily available online.

I hope this is enough information for now. Please let me know when Tom may come in to pick up his permit.

Thank you,

Nat

nat towl
nmt woodworking inc.
207-321-9038