Attachment #2

Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 11/13/15

10 FREE STREET

MODIFICATIONS TO EXISTING STOREFRONT TO MOVE ENTRY DOOR AND CREATE MECHANICAL SCREEN TO CONCEAL OUTDOOR MECHANICAL EQUIPMENT

09-08-2015

Boiler vent to be a single concentric vent cap, painted to match background brick, and not projecting more than 8" from wall.

Note # Venting
3" Heater Vent PVC
Terminate Above Lover

Louvered vent to be 14"x14", painted black to match, with panel below.

CANAL 5 STUDIO

PROPOSED ENTRY MODIFICATIONS

Note #
To Be hung below & behind
HVAC unit. Condenser 9-17-15