



Reviewed for Code Compliance  
Inspections Division  
Approved with Conditions  
Date: 03/06/18



## FIRE SPRINKLER CONTRACTORS AND DESIGNERS

### MEMO

DATE: 2/22/2018

TO: Chief

From: Joe Derocher

Subject: 98 Cross Street Portland, Maine

Chief,

This memo is to inform you that no hydraulic calculations were performed on the 98 Cross Street renovation project due to the scope of the project which was removing the existing sprinkler system line piping and installing new line piping (less the  $\frac{3}{4}$ "") at the same locations to accommodate the new finishes.

Sincerely,

Joe Derocher

Manager, Accendo Fire Protection

TOTAL PAGES: 1