


City of Portland, Maine – Building or Use Permit Application 382 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 20 Free St. - 2nd flr		Owner: Free Street Associates		Phone: 773-8416	Permit No: 941114
Owner Address: 302 7325 - 21st, 40 01112		Leasee/Buyer's Name:		Phone:	Business Name:
Contractor Name: owner		Address:		Phone:	
Past Use: office	Proposed Use: office w/ lat renov	COST OF WORK: \$ 300		PERMIT FEE: \$ 25	
		FIRE DEPT. <input type="checkbox"/> Approved <input type="checkbox"/> Denied		INSPECTION: Use Group: B Type: 3B Boca 93	
Proposed Project Description: Interior renovations - 2nd flr officespace		Signature:		Signature: [Signature]	
		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)		Zoning Approval: 038-A-005	
		Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied		Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan <input type="checkbox"/> maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>	
Permit Taken By: L Chase		Date Applied For: 10/6/94			



1. This permit application doesn't preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT: [Signature] ADDRESS: DATE: PHONE:

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE: PHONE:

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

- Zoning Appeal**
- ☐ Variance
 - ☐ Miscellaneous
 - ☐ Conditional Use
 - ☐ Interpretation
 - ☐ Approved
 - ☐ Denied

- Historic Preservation**
- ☐ Not in District or Landmark
 - ☐ Does Not Require Review
 - ☐ Requires Review

- Action:**
- ☐ Approved
 - ☐ Approved with Conditions
 - ☐ Denied

Date: [Signature]

CEO DISTRICT 2
Ms. Manson

Inspection Services
Samuel P. Hoffses
Chief



Planning and Urban Development
Joseph E. Gray Jr.
Director

CITY OF PORTLAND

October 13, 1994

Free Street Associates
Box 7525
Portland, ME 04112

Re: 22 Free Street - 2nd Floor

Dear Sir:

Your application to make interior renovations (office space) has been reviewed and a permit is herewith issued subject to the following requirement(s): This permit doesn't preclude the applicant from meeting applicable State and Federal laws.

No Certificate of Occupancy can be issued until all requirements of this letter are met.

- 1) The sprinkler system shall be maintained to NFPA 13 standards.
- 2) Portable fire extinguishers shall be provided in accordance with NFPA 10.
- 3) All exit signs, lights and means of egress lighting shall be done in accordance with Chapter 10, section & subsections 1023. & 1024.0 of the City's building code.
- 4) This permit is being issued with the understanding that no exterior work is to be done.

If you have any questions regarding these requirement(s), please do not hesitate to contact this office.

Sincerely,


A handwritten signature in black ink, appearing to read "P. Hoffses", written over a horizontal line.

P. Samuel Hoffses
Chief of Building Inspection Services

cc: Lt. Gaylen MacDougal, Fire Prevention

COMMENTS

12-5-94 - Fire separation enclosure not constructed yet - the proper fire separation does not exist right now.

Jan 95 - Work completed 

Inspection Record

Type

Foundation: _____

Framing: _____

Plumbing: _____

Final: _____

Other: _____

Date