

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

JB BROWN & SONS

Located at

22 FREE ST (Suite 203)

PERMIT ID: 2015-02129

ISSUE DATE: 10/13/2015

CBL: 038 A005001

has permission to **Interior Alterations - For the interior office build-out of the existing office suite (Suite 203).**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Jonathan Rioux

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

**Check the Status or Schedule an Inspection On-Line at
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Site VISIT

Close-in Plumbing/Framing

Electrical - Commercial

Fire Inspection

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2015-02129	Date Applied For: 09/01/2015	CBL: 038 A005001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: Same: First Floor - Retail, personal services and offices and Second Floor - Offices (Suite 203)		Proposed Project Description: Interior Alterations - For the interior office build-out of the existing office suite (Suite 203).		
Dept: Zoning		Status: Approved w/Conditions	Reviewer: Tammy Munson	Approval Date: 09/10/2015
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) This permit approves interior work only.				
Dept: Building Inspecti		Status: Approved w/Conditions	Reviewer: Jonathan Rioux	Approval Date: 10/09/2015
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) Concealed spaces shall comply with section 717 of the IBC, 2009 (MUBEC).				
2) Ventilation of this space is required per ASRAE 62.2 , 2007 edition.				
Insulation shall comply with the IECC, 2009 (Maine State Energy Codes).				
3) This permit is approved based upon information provided by the design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
4) Separate permits are required for any electrical: plumbing, sprinkler, fire alarm, HVAC systems, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
Dept: Engineering DPS		Status: Not Applicable	Reviewer: Benjamin Pearson	Approval Date: 09/02/2015
Note:		Ok to Issue: <input type="checkbox"/>		
Conditions:				
1) This approval is non-applicable to Engineering DPS as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Services for any other reason than FOG, please contact David Margolis-Pineo at 207-874-8850 or dmp@portlandmaine.gov				
Dept: Fire		Status: Approved w/Conditions	Reviewer: Craig Messinger	Approval Date: 10/06/2015
Note:		Ok to Issue: <input checked="" type="checkbox"/>		
Conditions:				
1) A separate Fire Alarm Permit is required for new systems; or for work effecting more than 5 fire alarm devices; or replacement of a fire alarm panel with a different model. This review does not include approval of fire alarm system design or installation.				
2) A separate Suppression System Permit is required for all new suppression systems, including standpipe systems, and sprinkler work effecting more than 20 heads. This review does not include approval of system design or installation.				
3) Shall comply with NFPA 101, Chapter 19, Existing Health Care Occupancies.				
4) Construction or installation shall comply with City Code Chapter 10.				
5) Emergency lights and exit signs are required. Emergency lights and exit signs are required to be labeled in relation to the panel and circuit and on the same circuit as the lighting for the area they serve				
6) Shall meet the requirements of 2009 NFPA 1 Fire Code.				