



## EL RAYO - 26 FREE STREET PORTLAND, MAINE

## PROJECT DESCRIPTION AND GENERAL SCOPE OF WORK

RENOVATION OF EXISTING INTERIOR SPACE FORMERLY OCCUPIED BY STATIONARY RETAILER TO BECOME "EL RAYO" RESTAURANT AND BAR PROVIDING EAT-IN, BAR, TAKE-OUT SERVICE AND CONSTRUCTION OF NEW ELEVATED OUTDOOR DECK FOR SEASONAL OUTDOOR SEATING.

RENOVATED INTERIOR AREA: 1,770 SF NEW OUTDOOR DECK AREA: 570 SF

EXISTING SPRINKLER SYSTEM WILL BE MODIFIED TO SUIT NEW INTERIOR LAYOUT AND FOR COMPLIANCE WITH NFPA 13.

## IBC 2009 CODE REVIEW

CONSTRUCTION TYPE: III-B

SECTION 303 ASSEMBLY GROUP A A-2: RESTAURANTS, TAVERNS AND BARS

- OCCUPANT LOAD FACTORS (1004.1.1): ASSEMBLY CONCENTRATED 7 SF/PERSON ASSEMBLY STANDING 5 SF/PERSON ASSEMBLY UNCONCENTRATED 15 SF/PERSON COMMERCIAL KITCHENS 200 SF/PERSON
- EXIT ACCESS TRAVEL DISTANCE (1016.1): 250 FT (SPRINKLERED)

NUMBER OF EXITS (1021.1): 1-500 OCCUPANTS: 2


## NFPA 101 LIFE SAFETY CODE REVIEW

CONSTRUCTION TYPE (NFPA 22TYPE III (200)

- CLASSIFICATION OF OCCUPANCY: NEW ASSEMBLY (RESTAURANT)/ MERCANTILE
- SPRINKLER SYSTEM:
- FULLY SPRINKLERED (SUPERVISED PER NFPA 13)
- OCCUPANT LOAD FACTORS (7.3.1.2): ASSEMBLY CONCENTRATED 7 SF/PERSON ASSEMBLY LESS CONCENTRATEC15 SF/PERSON KITCHENS 100 SF/PERSON BUSINESS USE 100 SF/PERSON
- NUMBER OF EXITS (CH12 & CH36): 2
- COMMON PATH OF TRAVEL (12.2.5.1.2 ): 75' (FEWER THAN 50 OCCUPANTS)
- 20' (MORE THAN 50 OCCUPANTS)
- TRAVEL DISTANCE TO EXISTS (12.2.6): 250 FT (SPRINKLERED)
- 12.3.3.3 ASSEMBLY AREAS. INTERIOR WALL AND CEILING FINISH MATERIALS COMPLYING WITH SECTION 10.2 SHALL BE CLASS A, B OR C IN GENERAL ASSEMBLY AREAS HAVING OCCUPANT LOADS OF FEWER THAN 300.


DRAWING LIST		
NUMBER	SHEET TITLE	
A001	COVER SHEET	
A101	FLOOR PLANS & REFLECTED CEILING PLAN	
A201	EXTERIOR ELEVATIONS	
A301	<b>BUILDING SECTIONS &amp; ELEVATION DETAIL</b>	
A401	ENLARGED BATHROOM PLAN & DETAILS	

SYMBOL LEGEND			
1 SIM	– DETAIL NUMBER BUILDING SECTION – DRAWING NUMBER		
A101	– DETAIL NUMBER CALL OUT – DRAWING NUMBER		
Ę	CENTERLINE		
(101)	DOOR TAG		
$\bullet$	ELEVATION INDICATOR		
Ref 1 1 1 1 1 1 Ref	ELEVATION TAG		
Ref View Name	ELEVATION TAG		
	NORTH ARROW		
<u>_1</u>	REVISION		
Room name	ROOM TAG WITH NUMBER		
0	STRUCTURAL GRID BUBBLE		
(1i)	WALL TAG		
(1t)	WINDOW TAG		



EL RAYO - FREE STREET PORTLAND, MAINE

architecture for life



ACOOL

DATE of APPROVAL 4-4-16 PLANNER BATDATA BATTAY PROJECT NO. #2016-044