

Symbol	Label	Quantity	Manufacturer	Catalog Number	Description	Lumens Per Lamp	Light Loss Factor	Number Lamps	Lamp	Wattage
	A	55	Lithonia Lighting	LDN4 35/05 LO4AR LS	4IN LDN, 3500K, 500LM, 80 CRI, CLEAR, SPECULAR REFLECTOR	689	0.9	1	LED	8.52
	A1	12	Lithonia Lighting	LDN4 35/15 LW4AR LS	4IN LDN WALLWASH, 3500K, 1500LM, 80 CRI, CLEAR, SPECULAR REFLECTOR	1775	0.9	1	LED	23.6
	A2	28	Lithonia Lighting	LDN4 35/20 LO4AR LS	4IN LDN, 3500K, 2000LM, 80 CRI, CLEAR, SPECULAR REFLECTOR	1993	0.9	1	LED	22.52
	B	0	iGuzzini	NOT USED		1006	0.9	1		35
	C	0	LumenWerx	NOT USED		4576.035	0.9	1		43.13
	C1	8	Atlantic Lighting	QSS-54-DI-SNW-FW-LED1100-35K-6FT	Quatro LED 54 Series 6' direct/indirect pendant, 20% down/80% up, 3500K, dimmable.	3021	1.35	1	LED	43.26
	C2	3	Atlantic Lighting	QSS-54-DI-SNW-FW-LED1100-35K-8FT	Quatro LED 54 Series, 8' direct/indirect pendant, 20% down/80% up, 3500K, dimmable.	3021	0.9	1	LED	43.26
	D	QTY TBD		EXISTING TO REMAIN		2770	0.9	1		22.3
	D1	17		EXISTING 2X WITH DIMMING	ALL EXISTING 2X2 "D1" FIXTURES TO BE RELOCATED AND RETROFITTED WITH A DIMMING PACKAGE.	2770	0.9	1		22.3
	F	0	DECO LIGHTING	NOT USED		Absolute	0.9	1	LED	20.7
	G	6	Brownlee Lighting	2340 24 C37LED XX 35K DIM	24" flush mount drum, 3837 lms, 3500K, 82CRI; dimmable.	3258.909	0.9	1	LED	36.9
	H	0	Brownlee Lighting	NOT USED	19" drum pendant, 3837 lms, 3500K, 82CRI; dimmable.	2766.22	0.9	1	LED	36.88
	I	0	Winona Lighting	NOT USED		3189.241	0.9	1	LED	66
	J	1	Winona Lighting	WFP5818 30DIA SSTM A/60A19 XXV FABX XX	Giselle 30" drum pendant.	3189.241	1.8	1	(8) 60W A19	66
	J2	0	Winona Lighting	NOT USED		3189.241	0.9	1	(4) 60W A19	66
	K	1	Tech Lighting	700LSRVL X X LED830	Revel 50" linear pendant, 3500 lms, 3000K 80CRI; dimmable	3915	0.9	1	LED	40
	L	2	Juno Lighting	UPS30 30K 90CRI XX	Juno 30" soft task undercabinet, 844 lms, 3000K, 90CRI; dimmable.	844	0.9	1	LED	12.5
	M	0	Tech Lighting	NOT USED		500	0.54	1		6.3

**Note**  
MODEL NUMBERS MAY NOT BE COMPLETE.  
DISREGARD QUANTITY FOR TYPE C2 - MANUFACTURER'S SYMBOL IS A 4' FIXTURE. TYPE C2 IS AN 8' LINEAR PENDANT, QUANTITY (3).

Description	Symbol	Avg	Max	Min	Max/Min	Avg/Min
100 RECEPTION	+	16 fc	34 fc	5 fc	6.8:1	3.2:1
100 RECEPTION DESK	+	30 fc	77 fc	4 fc	19.3:1	7.5:1
100 RECEPTION WHALE	+	11 fc	15 fc	6 fc	2.5:1	1.8:1
101 CONFERENCE	+	20 fc	29 fc	11 fc	2.6:1	1.8:1
103 HALL	+	19 fc	40 fc	3 fc	13.3:1	6.3:1
104 OFFICE	+	51 fc	65 fc	36 fc	1.8:1	1.4:1
105 OFFICE	+	54 fc	72 fc	30 fc	2.4:1	1.8:1
106 OFFICE	+	50 fc	59 fc	33 fc	1.8:1	1.5:1
107 OFFICE	+	47 fc	59 fc	26 fc	2.3:1	1.8:1
108 OFFICE	+	48 fc	56 fc	37 fc	1.5:1	1.3:1
109 OFFICE	+	51 fc	64 fc	37 fc	1.7:1	1.4:1
110 OFFICE	+	51 fc	65 fc	37 fc	1.8:1	1.4:1
111 OFFICE	+	42 fc	64 fc	14 fc	4.6:1	3.0:1
112 OFFICE	+	53 fc	68 fc	37 fc	1.8:1	1.4:1
113 HALL	+	13 fc	21 fc	5 fc	4.2:1	2.6:1
114 CONFERENCE	+	28 fc	39 fc	20 fc	2.0:1	1.4:1
115 RESEARCH	+	42 fc	58 fc	21 fc	2.8:1	2.0:1
116 OFFICE	+	53 fc	68 fc	37 fc	1.8:1	1.4:1
117 CONFERENCE	+	32 fc	80 fc	11 fc	7.3:1	2.9:1
118 OFFICE	+	51 fc	68 fc	35 fc	1.9:1	1.5:1
119 OFFICE	+	51 fc	67 fc	35 fc	1.9:1	1.5:1
120 OFFICE	+	49 fc	57 fc	38 fc	1.5:1	1.3:1
121 OFFICE	+	48 fc	60 fc	27 fc	2.2:1	1.8:1
122 OFFICE	+	50 fc	60 fc	34 fc	1.8:1	1.5:1
123 OFFICE	+	54 fc	72 fc	30 fc	2.4:1	1.8:1
124 OFFICE	+	51 fc	65 fc	37 fc	1.8:1	1.4:1
125 OFFICE	+	51 fc	66 fc	37 fc	1.8:1	1.4:1
126 OFFICE	+	51 fc	66 fc	36 fc	1.8:1	1.4:1
127 OFFICE	+	51 fc	68 fc	34 fc	2.0:1	1.5:1
128 HALL	+	21 fc	44 fc	15 fc	2.9:1	1.4:1
129 OFFICE	+	51 fc	67 fc	35 fc	1.9:1	1.5:1
130 OFFICE	+	51 fc	68 fc	34 fc	2.0:1	1.5:1
131 OFFICE	+	51 fc	66 fc	35 fc	1.9:1	1.5:1
132 OFFICE	+	33 fc	59 fc	7 fc	8.4:1	4.7:1
133 OFFICE	+	36 fc	64 fc	6 fc	10.7:1	6.0:1
134 OFFICE	+	35 fc	64 fc	10 fc	6.4:1	3.5:1
135 OFFICE	+	37 fc	64 fc	11 fc	5.8:1	3.4:1
136 OFFICE	+	37 fc	62 fc	14 fc	4.4:1	2.6:1
137 OFFICE	+	34 fc	58 fc	11 fc	5.3:1	3.1:1
138 OFFICE	+	35 fc	64 fc	9 fc	7.1:1	3.9:1
139 OFFICE	+	60 fc	79 fc	41 fc	1.9:1	1.5:1
141 OPEN OFFICE	+	34 fc	77 fc	2 fc	38.5:1	17.0:1
143 CAFE CTR	+	27 fc	98 fc	3 fc	32.7:1	9.0:1
146 COPY CTR	+	22 fc	29 fc	16 fc	1.8:1	1.4:1
147 OPEN OFFICE	+	39 fc	69 fc	5 fc	13.8:1	7.8:1
148 OFFICE	+	36 fc	68 fc	18 fc	3.8:1	2.0:1
149 OFFICE	+	35 fc	69 fc	17 fc	4.1:1	2.1:1
150 OFFICE	+	35 fc	70 fc	18 fc	3.9:1	1.9:1
151 OFFICE	+	33 fc	69 fc	14 fc	4.9:1	2.4:1
152 OFFICE	+	33 fc	67 fc	13 fc	5.2:1	2.5:1
153 OFFICE	+	35 fc	67 fc	18 fc	3.7:1	1.9:1
154 OFFICE	+	25 fc	34 fc	18 fc	1.9:1	1.4:1
155 COPY	+	33 fc	42 fc	27 fc	1.6:1	1.2:1
155 COPY CTR	+	36 fc	54 fc	13 fc	4.2:1	2.8:1
155 COPY CTR	+	36 fc	54 fc	14 fc	3.9:1	2.6:1
156 OFFICE	+	35 fc	70 fc	17 fc	4.1:1	2.1:1
157 ART WALL	+	19 fc	30 fc	5 fc	6.0:1	3.8:1
157 HALL	+	48 fc	60 fc	27 fc	2.2:1	1.8:1

REVISED: OCTOBER 02, 2017  
PERMIT SET: JULY 14, 2017