



OWNER REVIEW
NAME _____ DATE _____

NO.	DATE	DESCRIPTION
1	2/5/2010	PERMIT SET
ISSUE LOG		
△		= CLOUED CHANGE

TD BANK
TENANT RENOVATION
1 PORTLAND SQUARE
CAMBRIDGE, MA 02110

**LOWER LEVEL
ELEC./TEL DATA
COORDINATION PLAN**

SCALE 1/8"=1'-0"
DRAWN BY AAB
CHECKED BY AAB
PROJ. ARCH./ENGR. AAB
PROJ. MGR. SFD
JOB NO. 090593 09065.01
SYMMES MAINI & MCKEE ASSOCIATES, INC. 2010

A1.21

RECEPTACLE SYMBOLS		COMMUNICATION AND SIGNAL SYMBOLS		FIRE ALARM SYMBOLS	
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION
○	DUPLEX RECEPTACLE - GROUNDING TYPE - MOUNTED 18" A.F.F. UNLESS OTHERWISE INDICATED.	▼	TELEPHONE OUTLET: MOUNTED 18" A.F.F., 4" SQUARE BOX "M" INDICATES MOUNTED 54" A.F.F. "P" INDICATES PIV PHONE "C" INDICATES MOUNTED 42" A.F.F. OR 6" ABOVE COUNTER.	Ⓢ	FIRE ALARM PULL STATION MOUNT BOTTOM OF DEVICE AT 4"-0" A.F.F.
Ⓢ	DUPLEX RECEPTACLE - GROUNDING TYPE - GROUND FAULT INTERRUPTING TYPE - MOUNTED 18" A.F.F. UNLESS OTHERWISE INDICATED.	▷	DATA OUTLET: MOUNTED 18" A.F.F., 4" SQUARE BOX "M" INDICATES MOUNTED 54" A.F.F. "C" INDICATES MOUNTED 42" A.F.F. OR 6" ABOVE COUNTER.	Ⓢ	FIRE ALARM HORN / STROBE COMBINATION MOUNT BOTTOM OF DEVICE AT 6"-8" A.F.F. OR 6" BELOW CEILING, WHICHEVER IS LOWER. "100d" DENOTES STROBE CANDELA RATING, NO "cd" VALUE INDICATES PROVIDE 75cd STROBE.
Ⓢ	DUPLEX RECEPTACLE - GROUNDING TYPE - MOUNTED AT 42" A.F.F. OR 6" ABOVE COUNTER TOP OR BACK SPLASH WHERE EXISTENT.	◀	COMBINATION DATA/TELEPHONE OUTLET: MOUNTED 18" A.F.F., 4" SQUARE BOX "M" INDICATES MOUNTED 54" A.F.F. "C" INDICATES MOUNTED 42" A.F.F. OR 6" ABOVE COUNTER.	Ⓢ	FIRE ALARM STROBE ONLY: MOUNT BOTTOM OF DEVICE AT 6"-8" A.F.F. OR 6" BELOW CEILING, WHICHEVER IS LOWER. "100d" DENOTES STROBE CANDELA RATING, NO "cd" VALUE INDICATES PROVIDE 75cd STROBE.
Ⓢ	DUPLEX RECEPTACLE - GROUNDING TYPE - GROUND FAULT INTERRUPTING TYPE - MOUNTED 42" A.F.F. OR 6" ABOVE COUNTER TOP OR BACK SPLASH WHERE EXISTENT.	Ⓢ		Ⓢ	FIRE ALARM SMOKE DETECTOR.
Ⓢ	DUPLEX RECEPTACLE - ISOLATED GROUND TYPE - MOUNTED AT 18" A.F.F. UNLESS OTHERWISE INDICATED.	Ⓢ		Ⓢ	FIRE ALARM SMOKE DETECTOR WITH AUXILIARY CONTACTS FOR CROSS ZONING (ELEV. LOBBY).
Ⓢ	DOUBLE DUPLEX RECEPTACLE - GROUNDING TYPE - MOUNTED AT 18" A.F.F. UNLESS OTHERWISE INDICATED. "C" INDICATES MOUNTED 42" A.F.F. OR 6" ABOVE COUNTER.	Ⓢ		Ⓢ	FIRE ALARM SMOKE DETECTOR WITH RELAY BASE.
Ⓢ	FLOOR OUTLET BOX WITH DUPLEX RECEPTACLE. REFER TO SPECIFICATIONS.	Ⓢ		Ⓢ	FIRE ALARM CONTROL PANEL.
Ⓢ	FLOOR OUTLET BOX WITH DOUBLE DUPLEX RECEPTACLE. REFER TO SPECIFICATIONS.	Ⓢ		Ⓢ	FIRE ALARM ANNUNCIATOR PANEL.
Ⓢ	CEILING MOUNTED BOX WITH DUPLEX RECEPTACLE. REFER TO SPECIFICATIONS.	Ⓢ		Ⓢ	DUCT SMOKE DETECTOR REMOTE INDICATOR/TEST STATION MOUNTED 6"-8" A.F.F. OR 6" BELOW FINISHED CEILING WHICHEVER IS LOWER.
Ⓢ	JUNCTION BOX.	Ⓢ		Ⓢ	