



Advancing security, life safety, and communications.

SYSTEM RECORD OF COMPLETION

Form Completion Date: 9/22/17 Supplemental Pages Attached:

1. PROPERTY INFORMATION

Name of property: 1 Portland Square
Address: 1 Portland Square, Portland, ME
Description of property: Office - Multi level
Name of property representative:
Address:
Phone: Fax: E-mail:

2. INSTALLATION, SERVICE, TESTING, AND MONITORING INFORMATION

Installation contractor: Dabois Electric
Address:
Phone: Fax: E-mail:
Service organization: Nords Inc
Address: 2257 W. Broadway, South Portland, Maine
Phone: 883-3473 Fax: E-mail:
Testing organization: Norris Inc
Address: 2257 W. Broadway, South Portland, Maine
Phone: 883-3473 Fax: E-mail:
Effective date for test and inspection contract:
Monitoring organization: Portland Fire
Address:
Phone: Fax: E-mail:
Account number: Boxes 4435 & 4436 Phone line 1: Phone line 2:
Means of transmission: Masterbox
Entity to which alarms are retransmitted: Phone:

3. DOCUMENTATION

On-site location of the required record documents and site-specific software:

4. DESCRIPTION OF SYSTEM OR SERVICE

This is a: [] New system [X] Modification to existing system Permit number:
NFPA 72 edition:

4.1 Control Unit

Manufacturer: Notifier (Existing) Model number: NFS2-640

4.2 Software and Firmware

Firmware revision number: 25.0

4.3 Alarm Verification

[X] This system does not incorporate alarm verification.

Number of devices subject to alarm verification: Alarm verification set for seconds



Advancing security, life safety, and communications.

SYSTEM RECORD OF COMPLETION (continued)

5. SYSTEM POWER

5.1 Control Unit

5.1.1 Primary Power

Input voltage of control panel: 120 VAC Control panel amps: 8

Overcurrent protection: Type: Circuit breaker Amps: _____

Branch circuit disconnecting means location: _____ Number: _____

5.1.2 Secondary Power

Type of secondary power: Batteries (Existing)

Location, if remote from the plant: Above Security Desk

Calculated capacity of secondary power to drive the system:

In standby mode (hours): 24 In alarm mode (minutes): 5

5.2 Control Unit

- This system does not have power extender panels
- Power extender panels are listed on supplementary sheet A

6. CIRCUITS AND PATHWAYS

Pathway Type	Dual Media Pathway	Separate Pathway	Class	Survivability Level
Signaling Line			B	Unknown
Device Power				
Initiating Device				
Notification Appliance				
Other (specify):				

7. REMOTE ANNUNCIATORS

Type	Location

8. INITIATING DEVICES

Type	Quantity	Addressable or Conventional	Alarm or Supervisory	Sensing Technology
Manual Pull Stations	4	Addressable	Alarm	
Smoke Detectors	7	Addressable	Alarm	Photo Electric
Duct Smoke Detectors				
Heat Detectors				
Gas Detectors				
Waterflow Switches				
Tamper Switches				



Advancing security, life safety, and communications.

SYSTEM RECORD OF COMPLETION (continued)

9. NOTIFICATION APPLIANCES

Table with 3 columns: Type, Quantity, Description. Rows include Audible, Visible, and Combination Audible and Visible.

10. SYSTEM CONTROL FUNCTIONS

Table with 2 columns: Type, Quantity. Rows include Hold-Open Door Releasing Devices, HVAC Shutdown, Fire/Smoke Dampers, Door Unlocking, Elevator Recall, and Elevator Shunt Trip.

11. INTERCONNECTED SYSTEMS

- Checkboxes for interconnectivity: 'This system does not have interconnected systems.' and 'Interconnected systems are listed on supplementary sheet'.

12. CERTIFICATION AND APPROVALS

12.1 System Installation Contractor

This system as specified herein has been installed according to all NFPA standards cited herein.

Signed, Printed name, Date, Organization, Title, Phone fields for contractor.

12.2 System Operational Test

This system as specified herein has tested according to all NFPA standards cited herein.

Signed, Printed name (Michael Ford), Date (9/22/17), Organization (Norris Inc), Title (Technician), Phone (803-3473) fields for test.

12.3 Acceptance Test

Date and time of acceptance test (9/22/17 3:00 PM), Installing contractor representative, Testing contractor representative, Property representative, AHJ representative fields.