

BUILDING PERMIT REPORT

DATE 3/31/55  
ADDRESS 1201 1st St  
REASON FOR PERMIT Sprinkler Installation  
BUILDING OWNER Verill & Dene  
CONTRACTOR Sprinkler System  
PERMIT APPLICANT ✓  
APPROVED ✓ DENIED \_\_\_\_\_

CONDITIONS OF APPROVAL:

1. ~~A 4" store fire department connection is required.~~
2. Any new sprinkler construction over 6 sprinkler heads needs to have State Fire Marshall approval.
3. Any renovations of sprinkler systems over 20 sprinkler heads needs to have State Fire Marshall approval.
4. A sprinkler performance test shall be submitted to the Portland Fire Department after completion of sprinkler work.