

Inspection Services
P. Samuel Hoffses
Chief



Planning and Urban Development
Joseph E. Gray Jr.
Director

CITY OF PORTLAND

August 26, 1996

Regan and Company
31 Mill Road
Yarmouth, Maine 04097

RE: One Portland Square

Dear Earl,

Your application to make renovations to the 6th floor, GSA space, has been reviewed and a permit is herewith issued subject to the requirements listed below. This permit does not excuse the applicant from meeting applicable State and Federal laws.

No Certificate of Occupancy will be issued until all requirements of this letter are met.

Building and Fire Code Requirements

1. The stairways shall be maintained with a two hour enclosure.
2. All exit signs, lights and means of egress lighting shall be done in accordance with Chapter 10 of the 1996 BOCA Building Code and NFPA 101 Fire Prevention Code.

If you have any questions regarding these requirements, please do not hesitate to contact this office.

Sincerely,


P. Samuel Hoffses
Chief, Inspection Services Division

cc: M. Schmuckal, Asst. Chief, Insp Svcs Div
Lt. McDougall, PFD