	y of Portland, Main Congress Street, 0410		0				09-0734	Issue Dat	e:	038 B00	2001	
	ation of Construction:	01 1011 (2	Owner Name:	(-		Ow	ner Address:			Phone:		
2 P	ORTLAND SQ		RREEF AMERICA REIT III CORP Z4			PO BOX 4900 DEPT 207			207-874-6000			
Business Name:			Contractor Name: TBD			Contractor Address:			Phone	Phone		
Less	see/Buyer's Name		Phone:			Permit Type: Alterations - Commercial			1	Zone:		
	t Use:		Proposed Use:	al-Prudential Insurance		Permit Fee: Cos \$2,080.00			ost of Work: CE			
Co	mmercial-Prudential Inst	urance.						\$206,000.00		1		
			Interior Renovation to Prudential Insurance 4th Floor		Approved		INSPECTION: Use Group: Type					
Duoi	posed Project Description											
_	erior Renovation to Prud		urance 4th Floor			Signature:		Signature:				
						PEDESTRIAN ACTIVITIES DISTR			TRICT (P.	RICT (P.A.D.)		
						Ac	ction Approv	ved App	proved w/C	Condition	Denied	
						Sig	gnature:		Ι	Date:		
	mit Taken By:		pplied For:	Zoning Approval				l				
	Imd 07/13. This permit application does not papplicant(s) from meeting application Federal Rules.			Special Zone or Revie		ews Zoning Appeal		Historic Preservation				
1.			•	Shoreland			Variance		Not in District or Landr			
2.	Building permits do not include plumbin septic or electrical work.		olumbing,	Wetland			Miscellaneous		☐ Does Not Require Revie			
3.	Building permits are void if work is not started within six (6) months of the date of issuance.			☐ Flood Zon			Conditional Us			Requires Review		
False information may invalidate a bupermit and stop all work			a building	Subdivision			☐ Interpretatio			Approved		
				☐ Si	Site Plan		Approved		Approved w/Condition			
				Maj Mino MM			☐ ☐ Denied		☐ Denied			
			Date:			Date:			Date:			
I ha juris shal	reby certify that I am th ve been authorized by th sdiction. In addition, if a Il have the authority to e uch permit.	ne owner to a permit fo	o make this appli r work described	med procession a	as his authorized application is iss	ie p l ag uec	ent and I agree t l, I certify that th	o conform	to all appl cial's auth	icable laws of orized repres	of this sentative	
191	P											
SIG	NATURE OF APPLICAN				ADDRESS	5		DATE	i.	P	НО	

Location of Construction: 2 PORTLAND SQ	Owner Name: RREEF AMERICA REIT I		Owner Address: PO BOX 4900 DEPT 207	Phone: 207-874-6000		
Business Name:	Contractor Name: TBD		Contractor Address:		Phone	
Lessee/Buyer's Name	Phone:	Phone:		Permit Type: Alterations - Commercial		
Dept: Zoning	Status: Approved with Conditions	Reviewer	: Marge Schmuckal	Approval Dat	te: 07/	/15/2009

Note: Ok to Issue:

- 1) Separate permits shall be required for any new signage.
- 2) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.

07/29/2009 Dept: Building **Status:** Approved with Conditions **Reviewer:** Jeanine Bourke **Approval Date:** Note: Ok to Issue:

- 1) All penetratios through rated assemblies must be protected by an approved firestop system installed in accordance with ASTM 814 or UL 1479, per IBC 2003 Section 712.
- 2) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm or HVAC or exhaust systems. Separate plans may need to be submitted for approval as a part of this process.
- 3) Application approval based upon information provided by applicant. Any deviation from approved plans requires separate review and approrval prior to work.

Dept: **Reviewer:** Capt Keith Gautreau 07/22/2009 Fire **Status:** Approved with Conditions **Approval Date:** Ok to Issue: Note:

- 1) Fire Alarm system shall be maintained.
 - If system is to be off line over 4 hours a fire watch shall be in place.
 - Dispatch notification required 874-8576.
- 2) Sprinkler protection shall be maintained.
 - Where the system is to be shut down for maintenance or repair, the system shall be checked at the end of each day to insure the system has been placed back in service.
- 3) Emergancy lights are required to be tested at the electrical panel.
- 4) Fire extinguishers required. Installation per NFPA 10
- 5) Fire alarm system requires a Masterbox connection per city ordinance. Masterbox design and installation shall be as approved be City Electrical Division.
- 6) Emergancy lights and exit signs are required
- 7) The fire alarm system shall comply with NFPA 72 and Fire Department Technical Standard. A compliance letter is required.
- 8) All construction shall comply with NFPA 101
- 9) The sprinkler system shall be installed in accordance with NFPA 13.

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICAN	ADDRESS	DATE	РНО