



Jeff Levine, AICP, Director
Planning & Urban Development Department

Tammy Munson, Director
Inspections Division

Air Velocity within the duct system 2000 FPM

Grease accumulation prevention system: Yes

Cleanouts: 3 Total Approx every 10'

Grease Duct enclosure: zero clearance Pipe-Masters

Exhaust Termination: Roof _____ Wall X

Fire Suppression System: yes

Exhaust fan mounting and clearance from the roof / wall or Combustibles: Min 18"

Exhaust fan distance from property lines: Wall Exhaust. In-line Fan: 10' from windows

Exhaust fan distance from other vents or openings: 10'

Exhaust fan distance from adjacent buildings: 10'

Exhaust fan height above adjoining grade: 8'

3. Hood Specs

Style of Hood: CANOPY

Type of Filter: High Efficiency Stainless Steel

Height of filter above nearest cooking surface: 48"

Capacity of hood CFM: 1350

Make up Air system description and capacity: NONE. Building HVAC -
Minimal Exhaust with speed control