

From: Scott Cote <SCote@deanandallyn.com>
To: Building Inspections <buildinginspections@portlandmaine.gov>
CC: Derek Narvaez <dnarvaez@deanandallyn.com>
Date: 11/4/2015 12:47 PM
Subject: Casco Bay Eye Care
Attachments: PERMIT APPLICATION.pdf

Please find attached sprinkler layout drawing and permit application for Casco Bay Eye Care.

Work is limited to the relocation of existing sprinkler drop locations of existing wet sprinkler system to provide compliant sprinkler coverage for new tenant fit out in subject space. The existing space resides within a fully sprinklered building and was defined as Ordinary Hazard II occupancy and is now being changed to Light Hazard occupancy use. There is no appreciable increase in the design demand of the existing system and therefor hydraulic calculations will not be submitted, we are instead providing a sprinkler drawing to indicate location, scope and extent of work.

Please send invoice as soon as possible.

As always, any questions or concerns please do not hesitate to contact me.
Thank you,

Scott Cote
System Specialist
Dean and Allyn Inc
P (207) 657-5646
C (207) 272-0122
Email: scote@deanandallyn.com