

NOTIFICATION APPLIANCE CIRCUIT VOLTAGE DROPS

Casco Bay Eye Care

Portland, Maine

PANEL	CIRCUIT	WIRE GAUGE	LENGTH	CURRENT DRAW	VOLTAGE DROP	VOLTAGE LOSS	END VOLTAGE	CIRCUIT LOAD
FCPS	NAC 1	14	142 FT	.484A	.35VDC	1.46%	24.65VDC	16%

**FCPS: .484A/8A Spare Capacity: 94%**

Calculated @ Maximum Distance/Current