



# Norris Inc.

Advancing security, life safety, and communications.

## SYSTEM RECORD OF COMPLETION

Form Completion Date: 12/22/2017 Supplemental Pages Attached: 1

### 1. PROPERTY INFORMATION

Name of property: 2 PORTLAND SQUARE – 477 FORE ST FIT UP  
Address: 477 FORE ST PORTLAND ME  
Description of property: COMMERCIAL - RETAIL  
Name of property representative: Tim Cox  
Address: \_\_\_\_\_  
Phone: 207-831-5917 Fax: \_\_\_\_\_ E-mail: tcox@9milemaine.com

### 2. INSTALLATION, SERVICE, TESTING, AND MONITORING INFORMATION

Installation contractor: Norris Inc  
Address: 2257 Broadway S. Portland Me  
Phone: 207-883-3473 Fax: \_\_\_\_\_ E-mail: \_\_\_\_\_  
Service organization: Norris Inc  
Address: 2257 W. Broadway, South Portland, Maine  
Phone: 883-3473 Fax: \_\_\_\_\_ E-mail: \_\_\_\_\_  
Testing organization: Norris Inc  
Address: 2257 W. Broadway, South Portland, Maine  
Phone: 883-3473 Fax: \_\_\_\_\_ E-mail: \_\_\_\_\_  
Effective date for test and inspection contract: \_\_\_\_\_  
Monitoring organization: HSMC  
Address: \_\_\_\_\_  
Phone: \_\_\_\_\_ Fax: \_\_\_\_\_ E-mail: \_\_\_\_\_  
Account number: 202-8263 Phone line 1: \_\_\_\_\_ Phone line 2: \_\_\_\_\_  
Means of transmission: Digital Dialer, AES Box  
Entity to which alarms are retransmitted: Portland Fire Phone: 207-874-8576

### 3. DOCUMENTATION

On-site location of the required record documents and site-specific software: \_\_\_\_\_

### 4. DESCRIPTION OF SYSTEM OR SERVICE

This is a:  New system  Modification to existing system Permit number: \_\_\_\_\_  
NFPA 72 edition: \_\_\_\_\_

#### 4.1 Control Unit

Manufacturer: Notifier (Existing) Model number: NFS-640

#### 4.2 Software and Firmware

Firmware revision number: 3.0

#### 4.3 Alarm Verification

This system does not incorporate alarm verification.

Number of devices subject to alarm verification: \_\_\_\_\_ Alarm verification set for \_\_\_\_\_ seconds



# Norris Inc.

Advancing security, life safety, and communications.

## SYSTEM RECORD OF COMPLETION (continued)

### 5. SYSTEM POWER

#### 5.1 Control Unit

##### 5.1.1 Primary Power

Input voltage of control panel: 120 Control panel amps: 20

Overcurrent protection: Type: \_\_\_\_\_ Amps: 30

Branch circuit disconnecting means location: \_\_\_\_\_ Number: \_\_\_\_\_

##### 5.1.2 Secondary Power

Type of secondary power: Battery

Location, if remote from the plant: \_\_\_\_\_

Calculated capacity of secondary power to drive the system:

In standby mode (hours): \_\_\_\_\_ In alarm mode (minutes): \_\_\_\_\_

#### 5.2 Control Unit

- This system does not have power extender panels
- Power extender panels are listed on supplementary sheet A

### 6. CIRCUITS AND PATHWAYS

Pathway Type	Dual Media Pathway	Separate Pathway	Class	Survivability Level
Signaling Line				
Device Power				
Initiating Device			B	0
Notification Appliance			B	0
Other (specify):				

### 7. REMOTE ANNUNCIATORS

Type	Location

### 8. INITIATING DEVICES

Type	Quantity	Addressable or Conventional	Alarm or Supervisory	Sensing Technology
Manual Pull Stations	1	Conventional	Alarm	Existing added back in
Smoke Detectors				
Duct Smoke Detectors				
Heat Detectors				
Gas Detectors				
Waterflow Switches				
Tamper Switches				



# Norris Inc.

Advancing security, life safety, and communications.

## SYSTEM RECORD OF COMPLETION (continued)

### 9. NOTIFICATION APPLIANCES

Type	Quantity	Description
Audible		
Visible	2	Strobes in Restrooms – Not tested
Combination Audible and Visible	2	Speaker Strobe in Large Rm & Outside Restrooms – Not tested

### 10. SYSTEM CONTROL FUNCTIONS

Type	Quantity
Hold-Open Door Releasing Devices	
HVAC Shutdown	
Fire/Smoke Dampers	
Door Unlocking	
Elevator Recall	
Elevator Shunt Trip	


### 11. INTERCONNECTED SYSTEMS

- This system does not have interconnected systems.
- Interconnected systems are listed on supplementary sheet

### 12. CERTIFICATION AND APPROVALS

#### 12.1 System Installation Contractor

This system as specified herein has been installed according to all NFPA standards cited herein.

Signed:  Printed name: Anthony Morris Date: 12-21-2017

Organization: Norris Inc Title: Technician Phone: 207-883-3473

#### 12.2 System Operational Test

This system as specified herein has tested according to all NFPA standards cited herein.

Signed: \_\_\_\_\_ Printed name: \_\_\_\_\_ Date: \_\_\_\_\_

Organization: \_\_\_\_\_ Title: \_\_\_\_\_ Phone: \_\_\_\_\_

#### 12.3 Acceptance Test

Date and time of acceptance test: \_\_\_\_\_

Installing contractor representative: \_\_\_\_\_

Testing contractor representative: \_\_\_\_\_

Property representative: Tim Cox

AHJ representative: \_\_\_\_\_