

City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 10 Cotton St		Owner: Steven Goodrich		Phone:		Permit No: 961241	
Owner Address:		Leasee/Buyer's Name: The Cotton St Gastana/Walter Loeman		Phone:		Business Name:	
Contractor Name: Ken Leigh		Address: RD 2, Box 234E Alfred, ME		Phone: 04002 247-4572		Permit Issued: DEC 26 1996	
Past Use: Taxi Cab Est		Proposed Use: Restaurant		COST OF WORK: \$ 10,670.00		PERMIT FEE: \$ 80.00	
Proposed Project Description: Change Use/Make Interior Renovations				FIRE DEPT. <input type="checkbox"/> Approved <input type="checkbox"/> Denied		INSPECTION: Use Group P/AS Type: 313	
				Signature:		Signature: <i>[Signature]</i>	
				PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)		Zone: 5-3 CBL: 038-C-014	
				Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied		Zoning Approval: Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>	
Permit Taken By: Mary Gresik		Date Applied For: 12 December 1996					

1. This permit application doesn't preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

15333/30-3502 *Not - Sprinkler*

PERMIT ISSUED WITH REQUIREMENTS

CERTIFICATION


I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

12 December 1996

SIGNATURE OF APPLICANT **Ken Leigh** ADDRESS: DATE: PHONE:

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE PHONE:

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector



- Zoning Appeal**
- Variance
 - Miscellaneous
 - Conditional Use
 - Interpretation
 - Approved
 - Denied

- Historic Preservation**
- Not in District or Landmark
 - Does Not Require Review
 - Requires Review

- Action:**
- Approved
 - Approved with Conditions
 - Denied

Date: _____

CEO DISTRICT 2

City of Portland, Maine – Building or Use Permit Application, 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 10 Cotton St		Owner: Steven Goodrich		Phone:		Permit No: 961241	
Owner Address:		Leasee/Buyer's Name: The Cotton St Cantana/Walter Loeman		Phone:		Business Name:	
Contractor Name: Ken Leigh		Address: RD 2, Box 234E Alfred, ME 04002		Phone: 247-4572		Permit Issued: DEC 26 1996	
Past Use: Taxi Cab Est		Proposed Use: Restaurant		COST OF WORK: \$ 10,670.00		PERMIT FEE: \$ 80.00	
				FIRE DEPT. <input type="checkbox"/> Approved <input type="checkbox"/> Denied		INSPECTION: Use Group: <i>BAB</i> Type: <i>3B</i> <i>BOCA 96</i> Signature: <i>[Signature]</i>	
Proposed Project Description: Change Use/Make Interior Renovations		Signature:		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved with Conditions <input type="checkbox"/> Denied		Zone: <i>B-3</i> CBL: 038-C-014 Zoning Approval: <i>done with conditions 12/17/96</i> Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan <input type="checkbox"/> maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>	
Permit Taken By: Mary Gresik		Date Applied For: 12 December 1996		Signature:		Date:	

1. This permit application doesn't preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

15333/30-3502

Non-Sprinkler

PERMIT ISSUED WITH REQUIREMENTS

subject to site plan review

Approved Any other's alternative including signage! subject to separate review.

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

[Signature]
SIGNATURE OF APPLICANT Ken Leigh

12 December 1996

ADDRESS: DATE: PHONE:

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE

PHONE:

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

CEO DISTRICT

2

A. Kowl

done with conditions 12/17/96
Special Zone or Reviews:
 Shoreland
 Wetland
 Flood Zone
 Subdivision
 Site Plan maj minor mm

BUILDING PERMIT REPORT

DATE: 20/dec/96 ADDRESS: 10 Cotton ST.

REASON FOR PERMIT: Change of use / make Interior Renovations

BUILDING OWNER: Steven Goodrich

CONTRACTOR: Ken Leigh


PERMIT APPLICANT: ↑

APPROVAL: *5 *6 *7 *8
DENIED: *14 *15 *17 *18 *22
 *23 *24

CONDITION OF APPROVAL OR DENIAL

1. Before concrete for foundation is placed, approvals from the Development Review coordinator and Inspection Services must be obtained. (A 24 hour notice is required prior to inspection)
2. Precaution must be taken to protect concrete from freezing.
3. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify that the proper setbacks are maintained.
4. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of 1/2 inch gypsum board or the equivalent applied to the garage means of 1/2 inch gypsum board or the equivalent applied to the garage side. (Chapter 4 Section 407.0 of the BOCA/1996)
- * 5. Guardrail & Handrails A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42" , except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-1, I-2 M and R and public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect.
- * 6. Headroom in habitable space is a minimum of 7'6".
- * 7. Stair construction in Use Group R-3 & r-4 is a minimum of 10" tread and 7 3/4" maximum rise. All other Use group minimum 11" tread. 7" maximum rise.
- * 8. The minimum headroom in all parts of a stairway shall not be less than 80 inches.
9. Every sleeping room below the fourth story in buildings of use Groups ~~R~~ and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft.
10. Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units.
11. All vertical openings shall be enclosed with construction having a fire rating of at least one (1)hour, including fire doors with self closer's.
12. The boiler shall be protected by enclosing with (1) hour fire-rated construction including fire doors and ceiling, or by providing automatic extinguishment.
13. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's building code Chapter 9, Section 19, 919.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 18 & 19. (Smoke detectors shall be installed and maintained at the following locations):
 - In the immediate vicinity of bedrooms
 - In all bedrooms
 - In each story within a dwelling unit, including basements
 In addition to the required AC primary power source, required smoke detectors in occupancies in Use Groups R-2, R-3 and I-1 shall receive power from a battery when the AC primary power source is interrupted. (Interconnection is required)
- * 14. A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved type.

- *15. The Fire Alarm System shall be maintained to NFPA #72 Standard.
- 16. The Sprinkler System shall maintained to NFPA #13 Standard.
- *17. All exit signs, lights, and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023. & 1024. Of the City's building code. (The BOCA National Building Code/1996)
- *18. All construction and demolition debris must be disposed at the City's authorized reclamation site. The fee rate is attached. Proof of such disposal must be furnished to the office of Inspection Services before final Certificate of Occupancy is issued or demolition permit is granted.
- 19. Section 25-135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".
- 20. The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification to the Division of Inspection Services.
- 21. This permit does not excuse the applicant from obtaining any license which may be needed from the City Clerk's office.
- 22. This proposed work must have the approval of the State Fire Marshall's office -
- 23. Any exterior alteration including signage is subject to Historic Preservation Review -
- 24. Please read and implement Attached Land Use Zoning Report Requirements
- 25. _____


 P. Samuel Hoffes, Chief of Code Enforcement

cc: Lt. McDougall, PFD — D. Andrews — M. Schmuckel

LAND USE - ZONING REPORT

ADDRESS: 10 Cotton St. DATE: 12/17/96

REASON FOR PERMIT: change of use from TAXI Cab Est to Restaurant

BUILDING OWNER: ~~Ken Leigh~~ Steven Goodrich C-B-L: 038-C-014

PERMIT APPLICANT: Ken Leigh (contractor)

APPROVED: with conditions DENIED: _____
#7

CONDITION(S) OF APPROVAL

1. During its existence, all aspects of the Home Occupation criteria, Section 14-410, shall be maintained.
2. The footprint of the existing _____ shall not be increased during maintenance reconstruction.
3. All the conditions placed on the original, previously approved, permit issued on _____ are still in effect for this amendment.
4. Your present structure is legally nonconforming as to rear and side setbacks. If you were to demolish the building on your own volition, you will not be able to maintain these same setbacks. Instead you would need to meet the zoning setbacks set forth in today's ordinances. In order to preserve these legally non-conforming setbacks, you may only rebuild the garage in place and in phases.
5. This property shall remain a single family dwelling. Any change of use shall require a separate permit application for review and approval.
6. Our records indicate that this property has a legal use of _____ units. Any change in this approved use shall require a separate permit application for review and approval.
7. Separate permits shall be required for any signage.
8. Separate permits shall be required for future decks and/or garage.
9. Other requirements of condition _____

Marge Schmuckal Marge Schmuckal, Zoning Administrator,
Asst. Chief of Code Enforcement

Applicant: Ken Leigh
Address: 10 Cotton St

Date: 12/17/96
C-B-L: ~~██████████~~ 38-C-14

CHECK-LIST AGAINST ZONING ORDINANCE

Date - Existing
Zone Location - B-3

Not in a FAD district

Interior or corner lot -

Proposed Use/Work - change of use from Taxi Cabs to Restaurant

Sewage Disposal -

Existing Bldg - No Address

Lot Street Frontage -

Front Yard -

Rear Yard -

Side Yard -

Existing

Projections -

Width of Lot -

Height -

Lot Area -

Lot Coverage/ Impervious Surface -

Area per Family -

Off-street Parking - Not required in B-3

Loading Bays -

Site Plan - N/A - under ^{5000 #} → 4876 #

Shoreland Zoning/ Stream Protection - N/A

Flood Plains - N/A



CITY OF PORTLAND, MAINE
Department of Building Inspection

Certificate of Occupancy

LOCATION 10 Cotton St 038-G-014

Issued to 10 Cotton Street LLC Date of Issue 21 May 1997

This is to certify that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. 961241, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

Entire

Restaurant

Limiting Conditions:

This certificate supersedes
certificate issued

Approved:

5/21/97

(Date)

P. Rowe

Inspector

[Signature]

Inspector of Buildings

10/1/97

[Signature]

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

COMMENTS

5/7/97 work progressing, A.R.
 5/12/97 work progressing, A.R.
 5/15/97 still to go. Handrails. Plumbing. Self-
 Closures on bath doors. Painting in Ft area. A.R.
 5/19/97 work almost finished. A.R.
 5/20/97 O.K. for Coj Co. A.R.

A

Inspection Record

Type

Date

Foundation:

Framing: O.K. A.R.

Plumbing: O.K. A.R.

Final: O.K. for Coj Co. A.R.

Other:

2/26/97

2/26/97

5/20/97