


REQUEST ADD'L INFO 3/15/02



4/4/02 - Framing completed with no issues seen -
Stairs not finished will return to check them. JRM

5/29/02 Needs proper 42" gtd on second floor,
OK 

38-C-14
02-0169