

City of Portland Health Inspection Report

Establishment Name <i>Rivalries</i>		As Authorized by 22 MRSA § 2496		Date <i>3-10-09</i>	
License/EST. ID # <i>8046</i>	Address <i>10 Cotton St</i>	City/State <i>Portland, Me.</i>	Zip Code <i>04101</i>	Telephone <i>774-6044</i>	

TEMPERATURE OBSERVATIONS

Item/Location	Temp	Item/Location	Temp	Item/Location	Temp
Bar coolers	34°	Sand cooler 1	34°		
" "	36°	" " 2	40°		
Bar chest cooler	34°	" " 3	40°		
Walk-in cooler	34°	Dishwasher w/heat	160°		
" " cooler	38°	small chest freezer	14°		
Chest freezer	10°				
Glass cooler	40°				

OBSERVATIONS AND CORRECTIVE ACTIONS

Item Number	Violations cited in this report must be corrected within the time frames below, or as stated in sections 8-405.11 and 8-406.11 of the Food Code.
# 14	Clean + sanitize cooler shelves 3-302
# 34	Thermometers in all coolers 4-203
	PFD: waves -
	1. Areas around electrical panels + water heater need 3' all around.
	2. Replace plug ends on appliance above chest freezer.
	3. Emergency lights not working

Person in Charge (Signature) <i>[Signature]</i>	Date <i>3-10-09</i>
Health Inspector (Signature) <i>[Signature]</i>	Date <i>3-10-09</i>