## City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 505 Fore St	Owner: Tracy-Causer 1	Phone:		Permit No 970885
Owner Address:	Lessee/Buyer's Name:	Phone: Busines		PERMIT ISSUED
Contractor Name: Justin O'Reilly	Address: 71 Carleton St Pt1d, NB	dress: Phone:		Permit issued:
Past Use:	Proposed Use:	COST OF WORK: \$ 12,000.00	PERMIT FEE: \$ 85.00	AUG 1 5 1997
Retail (The King & 1)	Bar	FIRE DEPT.  Approved Denied Signature:	INSPECTION: Use Group: Type: Signature:	CITY OF PORTLAND
Proposed Project Description: PEDESTRIAN ACTIVIT Action: Approved			a set of the set of th	□ Shoreland □ Wetland □ Flood Zone □ Subdivision
Permit Taken By: Hary Gresik	Date Applied For:	August 1997 Zoning Appeal		
<ol> <li>This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.</li> <li>Building permits do not include plumbing, septic or electrical work.</li> <li>Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work</li> </ol>				<ul> <li>□ Variance</li> <li>□ Miscellaneous</li> <li>□ Conditional Use</li> <li>□ Interpretation</li> <li>□ Approved</li> <li>□ Denied</li> </ul>
ant in the second			Historic Preservation	
I hereby certify that I am the owner of record of the authorized by the owner to make this application a if a permit for work described in the application is areas covered by such permit at any reasonable he	as his authorized agent and I agree to c issued, I certify that the code official's	conform to all applicable laws of th s authorized representative shall ha	is jurisdiction. In addition,	□ Denied
SIGNATURE OF APPLICANT Justin O'Re	ADDRESS:	13 August 1997 DATE:	PHONE:	1. Junilar let
RESPONSIBLE PERSON IN CHARGE OF WOR			PHONE:	
White-Pe	rmit Desk Green-Assessor's Ca	nary-D.P.W. Pink-Public File	lvory Card-Inspector	Acoul

## LAND USE - ZONING REPORT

ADDRESS: 505 Fore DATE: Ô Changed, Use from retail to BAR REASON FOR PERMIT: BUILDING OWNER: Tracy-CAuser LLC C-B-L: 38-C-16 PERMIT APPLICANT: Justin O'Reilly APPROVED: WWD anditions DENTED: IC. CONDITION(S) OF APPROVAL During its existence, all aspects of the Home Occupation criteria, Section 14-410, shail be 1. maintained. The footprint of the existing shall not be increased during maintenance 2. reconstruction. All the conditions placed on the original, previously approved, permit issued on \_\_\_\_\_ 3. are still in effect for this amendment. 4. Your present structure is legally nonconforming as to rear and side setbacks. If you were to demolish the building on your own volition, you will not be able to maintain these same setbacks. Instead you would need to meet the zoning setbacks set forth in today's ordinances. In order to preserve these legally non-conforming setbacks, you may only rebuild the garage in place and in phases. 5. This property shall remain a single family dwelling. Any change of use shall require a separate permit application for review and approval.

Our records indicate that this property has a legal use of \_\_\_\_\_\_ units. Any change in this approved use shall require a separate permit application for review and approval.
Separate permits shall be required for any signage.

Separate permits shall be required for future decks and/or garage.

Other requirements of condition Prior to work the proper be Applied for in The City Clark's scattion is within The Old Port Overlag I liquor licenses Are- restricted -Mure tal Marge Schmuckal, Zoning Administrator, Asst Chief of Code Enforcement

## **BUILDING PERMIT REPORT**

DATE: 15 AUGUST 97 ADDRESS: 505 Fores ST.
REASON FOR PERMIT: Change of Use make interior renovations
BUILDING OWNER: Trucy-Causer LLC
CONTRACTOR: JUSTIN O'ROILLY
PERMIT APPLICANT:

CONDITION(S) OF APPROVAL

- $\neq$  1. This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.
  - Before concrete for foundation is placed, approvals from the Development Review Coordinator and Inspection Services must be obtained. (A 24 hour notice is required prior to inspection)
  - 3. Precaution must be taken to protect concrete from freezing.
  - It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. 'This is done to verify that the proper setbacks are maintained.
  - 5. Private garages located <u>beneath habitable rooms</u> in occupancies in Use Group R-1, R-2, R-3 or 1-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of ½ inch gypsum board or the equivalent applied to the garage means of ½ inch gypsum board or the equivalent applied to the garage means of ½ inch gypsum board or the BOCA/1996)
  - All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993) U.L. 103.
- 7. Sound transmission control in residential building shall be done in accordance with Chapter 12 section 1214.0 of the city's building code.
- 48. Guardrail & Handrails A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42", except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-1, I-2 M and R and public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect.
- 9. Headroom in habitable space is a minimum of 7'6".
- 10. Stair construction in Use Group R-3 & R-4 is a minimum of 10" trend and 7 3/4" maximum rise. All other Use group minimum 11" trend, 7" maximum rise.
- 11. The minimum headroom in all parts of a stairway shall not be less than 80 inches.
- 12. Every sleeping room below the fourth story in buildings of use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft.
- 13. Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units.
- 14. All vertical openings shall be enclosed with construction having a fire rating of at lest one (1)hour, including fire doors with self closer's.
- 15. The boiler shall be protected by enclosing with (1) hour fire-rated construction including fire doors and ceiling, or by providing automatic extinguishment.
- 16. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9, Section 19, 920.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 18 & 19. (Sinoke detectors shall be installed and maintained at the following locations):
  - In the immediate vicinity of bedrooms
  - In all bedrooms
  - In each story within a dwelling unit, including basements

In addition to the required AC primary power source, required smoke detectors in occupancies in Use Groups R-2, R-3 and

I-I shall receive power from a battery when the AC primary power source is interrupted. (Interconnection is required)

- \$17. A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved type.
- The Fire Alarm System shall be maintained to NFPA #72 Standard.
- The Sprinkler System shall maintained to NFPA #13 Standard.
- 6 18. 20. All exit signs, lights, and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023, & 1024, Of the City's building code. (The BOCA National Building Code/1996)
- 421. No construction or demolition work shall begin until you have obtained permits for dumpsters or containers. A work Stop Order shall be issued if this requirement is not met.
- 22. Section 25-135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".
- 23. The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification to the Division of Inspection Services.
- This permit does not excuse the applicant from obtaining any license which may be needed from the City Clerk's office. 24.
- \$ 25. Ventilation shall meet the requirements of Chapter 12 Sections 1210, of the City's Building Code.
- \$ 26. All electrical and plumbing permits must be obtained by a Master Licensed holders of their trade.

3

427. All requirements must be met before a finial Certificate of Occupancy is issued.

ntteche itens LISTEd 28 00

29.

ver loffses, Chief of Code Enforcement

cc: LI. McDougall, PFD Marge Schmuckal

