



... **Fire Protection by Computer Design**

DEAN AND ALLYN, INC.
116 LEWISTON ROAD
GRAY MAINE
207 657 5646

Job Name : BRIAN BORU SECOND FLOOR
Building :
Location : 57 CENTER STREET PORTLAND MAINE
System : ONE
Contract : C171475
Data File : BRIAN BORU SECOND FLOOR.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - BRIAN BORU SECOND FLOOR Date - 11-5-17
Location - 57 CENTER STREET PORTLAND MAINE
Building - System No. - ONE
Contractor - DEAN AND ALLYN, INC. Contract No. - C171475
Calculated By - H. KING Drawing No. - 1 OF 1
Construction: (X) Combustible () Non-Combustible Ceiling Height 8'
OCCUPANCY - PUB AND LOUNGE

S Type of Calculation: ()NFPA 13 Residential ()NFPA 13R ()NFPA 13D
Y Number of Sprinklers Flowing: ()1 ()2 ()4 ()
S ()Other LIGHT HAZARD
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 14.8 Gpm System Type
Listed Pres. at Start Point - 7 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 10 x 12 () Deluge () PreAction
E Domestic Flow Added - Gpm Sprinkler or Nozzle
S Additional Flow Added - Gpm Make RELIABLE Model F1FR56
I Elevation at Highest Outlet - 25' Feet Size 1/2" K-Factor 5.6
G Note:CUSHION 17.6 PSI Temperature Rating 155
N

Calculation Gpm Required 266.1 Psi Required 64.3 AT CITY
Summary C-Factor Used: Overhead 120 Underground 120

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 6-22-17 Rated Cap. Cap.
T Time of Test - @ Psi Elev.
E Static (Psi) - 82 Elev.
R Residual (Psi) - 80 Other Well
Flow (Gpm) - 1209 Proof Flow Gpm
S Elevation - 0

P Location: IN FRONT OF BUILDING ON 10" CITY MAIN

P Source of Information: PORTLAND WATER DEPT.
L
Y

Final Calculations - Hazen-Williams

DEAN AND ALLYN, INC.
BRIAN BORU SECOND FLOOR

Page 2
Date 11-5-17

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
01 to 02	-15.65	1.38 120.0	2E	6.0 0.0	10.000 6.000	7.349 0.0			K Factor = 5.60	
02 to 03	-15.65	-0.0217		0.0	16.000	-0.348			Vel = 3.36	
02 to 03	14.82	1.38 120.0		0.0 0.0	8.800 0.0	7.001 0.0			K Factor = 5.60	
03 to 05	-0.83	-0.0001		0.0	8.800	-0.001			Vel = 0.18	
03 to 05	14.82	1.38 120.0		0.0 0.0	8.800 0.0	7.000 0.0			K Factor = 5.60	
05 to 07	13.99	0.0176		0.0	8.800	0.155			Vel = 3.00	
05 to 07	14.98	1.38 120.0		0.0 0.0	8.800 0.0	7.155 0.0			K Factor = 5.60	
07 to 09	28.97	0.0680		0.0	8.800	0.598			Vel = 6.21	
07 to 09	15.59	1.38 120.0		0.0 0.0	9.000 0.0	7.753 0.0			K Factor = 5.60	
09 to 10	44.56	0.1507		0.0	9.000	1.356			Vel = 9.56	
09 to 10	16.90	1.38 120.0	2E	6.0 0.0	10.000 6.000	9.109 0.0			K Factor = 5.60	
10 to 04	61.46	0.2731		0.0	16.000	4.369			Vel = 13.18	
10 to 04	0.0 61.46					13.478			K Factor = 16.74	
04 to 06	46.76	1.38 120.0		0.0 0.0	9.800 0.0	8.095 0.0			K Factor = 5.60	
06 to 08	46.76	0.1648		0.0	9.800	1.615			Vel = 10.03	
06 to 08	17.45	1.38 120.0		0.0 0.0	9.800 0.0	9.710 0.0			K Factor = 5.60	
08 to 20	64.21	0.2961		0.0	9.800	2.902			Vel = 13.77	
08 to 20	19.89	1.38 120.0	T	6.0 0.0	3.700 6.000	12.612 0.0			K Factor = 5.60	
20 to 10	84.1	0.4878		0.0	9.700	4.732			Vel = 18.04	
20 to 10	0.0 84.10					17.344			K Factor = 20.19	
10 to 20	82.02	1.38 120.0	T	6.0 0.0	2.300 6.000	13.478 0.0			K Factor = 5.60	
20 to 01	82.02	0.4658		0.0	8.300	3.866			Vel = 17.59	
20 to 01	0.0 82.02					17.344			K Factor = 19.69	
01 to 04	30.83	1.38 120.0		0.0 0.0	9.800 0.0	7.349 0.0				
04 to 20	30.83	0.0761		0.0	9.800	0.746			Vel = 6.61	
04 to 20	0.0 30.83					8.095			K Factor = 10.84	
20 to 21	166.12	2.067 120.0	2E	10.0 0.0	1.800 10.000	17.344 0.0				
21 to 22	166.12	0.2403		0.0	11.800	2.836			Vel = 15.88	
21 to 22	0.0	2.067 120.0	E	5.0 0.0	15.700 5.000	20.180 6.930				
22 to 23	166.12	0.2402		0.0	20.700	4.973			Vel = 15.88	
22 to 23	0.0	2.067 120.0	T	10.0 0.0	1.700 10.000	32.083 0.0				
23 to 21	166.12	0.2403		0.0	11.700	2.811			Vel = 15.88	

Final Calculations - Hazen-Williams

DEAN AND ALLYN, INC.
BRIAN BORU SECOND FLOOR

Page 3
Date 11-5-17

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
23 to 24	0.0 166.12	2.067 120.0 0.2403	T 0.0	10.0 0.0 10.000	2.300 0.0 10.000	34.894 0.0 2.956		Vel = 15.88	
24 to 25	0.0 166.12	2.067 120.0 0.2403	E 0.0	5.0 0.0 5.000	1.800 0.0 5.000	37.850 0.0 1.634		Vel = 15.88	
25 to 26	0.0 166.12	2.067 120.0 0.2403	E 0.0	5.0 0.0 5.000	10.000 0.0 5.000	39.484 3.898 3.604		Vel = 15.88	
26 to TR	0.0 166.12	2.067 120.0 0.2403	2E T 0.0	10.0 10.0 0.0	11.000 20.000 31.000	46.986 0.0 7.448		Vel = 15.88	
TR to FF	0.0 166.12	2.067 120.0 0.2403	S 0.0	11.0 0.0 11.000	7.000 11.000 18.000	54.434 5.000 4.325		** Fixed Loss = 5 Vel = 15.88	
FF to CTY	0.0 166.12	4.1 120.0 0.0086	T 0.0	21.855 0.0 21.855	40.000 21.855 61.855	63.759 0.0 0.529		Vel = 4.04	
	100.00 266.12					64.288		Qa = 100.00 K Factor = 33.19	

Pressure / Flow Summary - STANDARD

DEAN AND ALLYN, INC.
BRIAN BORU SECOND FLOOR

Page 4
Date 11-5-17

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
01	25.0	5.6	7.35	na	15.18	0.1	148	7.0
02	25.0	5.6	7.0	na	14.82	0.1	148	7.0
03	25.0	5.6	7.0	na	14.82	0.1	148	7.0
05	25.0	5.6	7.16	na	14.98	0.1	148	7.0
07	25.0	5.6	7.75	na	15.59	0.1	148	7.0
09	25.0	5.6	9.11	na	16.9	0.1	148	7.0
04	25.0	5.6	8.1	na	15.93	0.1	148	7.0
06	25.0	5.6	9.71	na	17.45	0.1	148	7.0
08	25.0	5.6	12.61	na	19.89	0.1	148	7.0
10	25.0	5.6	13.48	na	20.56	0.1	148	7.0
20	25.0		17.34	na				
21	25.0		20.18	na				
22	9.0		32.08	na				
23	9.0		34.89	na				
24	9.0		37.85	na				
25	9.0		39.48	na				
26	0.0		46.99	na				
TR	0.0		54.43	na				
FF	0.0		63.76	na				
CTY	0.0		64.29	na	100.0			

The maximum velocity is 18.04 and it occurs in the pipe between nodes 08 and 20

Water Supply Curve C

DEAN AND ALLYN, INC.
BRIAN BORU SECOND FLOOR

Page 5
Date 11-5-17

City Water Supply:
C1 - Static Pressure : 82
C2 - Residual Pressure: 80
C2 - Residual Flow : 1209

Demand:
D1 - Elevation : 10.827
D2 - System Flow : 166.118
D2 - System Pressure : 64.288
Hose (Demand) : 100
D3 - System Demand : 266.118
Safety Margin : 17.590

