SINK COMBS DETHLEFS

Copyright by Sink Combs Dethlefs, P.C.
4204 Lincoln Street, Suite 100 Denver, Colorado 80216
303 399 8000 FAX 399 0202

TECHNICAL NOTES:

1. MOUNT TO FACE OF SOFFIT. REFER TO SECTION 1/A5.0 FOR MORE INFORMATION.
2. REFEED EXISTING TEL/DATA JACKS TO POS SYSTEM SERVER VIA NEAREST IDF. REFER TO DETAIL J1/E5.0.
3. DATA JACK FOR POS SYSTEM. CONNECT TO POS SYSTEM SERVER VIA NEAREST IDF. REFER TO DETAIL J1/E5.0.
4. DUCT MOUNTED SMOKE DETECTOR PROVIDED BY DIV. 28, INSTALLED BY DIV. 23, & CONNECTED TO THE FIRE ALARM SYSTEM BY DIV. 28. OBTAIN 120V POWER FROM NEARBY RECEPTACLE CIRCUIT.

REV.	DESCRIPTION	DATE
0	CONSTRUCTION DOCUMENTS	01-21-2013

CONSTRUCTION DOCUMENTS

01-21-2013

CURRENT ISSUE STATUS

Date: 09/05/13

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

CITY OF PORTLAND, MAINE
RESURGAM

01/21/2013 7:28:12 PM
J:\Projects\1976\00\Drawings\CCCC Electric.dwg