605 Urinals

605.1 General. Urinals shall comply with 605.

Advisory 605.1 General. Stall-type urinals provide greater accessibility for a broader range of persons, including people of short stature.

605.2 Height and Depth. Urinals shall be the stall-type or the wall-hung type with the rim 17 inches (430 mm) maximum above the finish floor or ground. Urinals shall be 13½ inches (345 mm) deep minimum measured from the outer face of the urinal rim to the back of the fixture.

Figure 605.2
Height and Depth of Urinals

Figure 604.8.1.1
Size of Wheelchair Accessible Toilet Compartr

Figure 604.8.1.4
Wheelchair Accessible Toilet Compartment Toe Clearance

ACCESSIBILITY ACCESSORY MOUNTING HEIGHTS

GRAB BARS	33" - 36"
TOILET PAPER HOLDER	19" MIN
TOWEL BAR/ PAPER TOWEL DISPENSER	48" MAX
BUILT IN PAPER TOWEL DISPENSER	48" MAX
SOAP DISH/ DISPENSER AT WALL	48" MAX
SANITARY NAPKIN DISPENSER	48" MAX
SANITARY NAPKIN DISPOSAL	19" MAX
MIRROR (BOTTOM)	40" MAX
SHELVES/ STORAGE	48" MAX
ELECTRICAL SWITCHES/ OUTLECTS	48" MAX
COAT HOOKS/ RODS	48" MAX
SIGNAGE (TO BRAILLE COMPONENT)	60" MAX

Inspections Division

Date: 04/30/14

MEN'S TOILET RM
ADA UPGRADE
241-245 COMMERCIAL ST
PORTLAND, MAINE

ADA DETAILS

DATE 4-22-14
SCALE NONE
DRAWN MFH
JOB NO. 140415
SHEET A3

COPYRIGHT
REPRODUCTION OR USE OF THIS DOCUMENT WITHOUT WRITTEN PERMISSION FROM GRANT MAY ASSOCIATES IS PROHIBITED.