

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT

**This is to certify that**

CASCO VIEW HOLDINGS LLC /Village Builders

**Located at**

245 COMMERCIAL ST

**PERMIT ID:** 2014-00850

**ISSUE DATE:** 05/05/2014

**CBL:** 038 F006001

has permission to **Renovate 3rd floor mens toilet; Add an ADA urinal and toilet. Partition at existing ADA toilet. New paint, etc.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

|  |  |
|--|--|
| Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED. | A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy. |
|--|--|

N/A

/s/ Tammy Munson

**Fire Official**

**Building Official**

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

*Approved Property Use - Zoning*

*Building Inspections*

*Fire Department*

BUILDING PERMIT INSPECTION PROCEDURES  
Please call 874-8703 (ONLY)  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

**Check the Status or Schedule an Inspection On-Line at  
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

## **REQUIRED INSPECTIONS:**

Close-in Plumbing/Framing w/Fire & Draft Stopping

Electrical Close-in w/Fire & Draftstopping

Above Ceiling Inspection

Final Inspection

Final - Electric

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

|   |   |                                 |  |                            |
|---|---|---------------------------------|--|----------------------------|
| <b>City of Portland, Maine - Building or Use Permit</b>   |   | <b>Permit No:</b><br>2014-00850 | <b>Date Applied For:</b><br>04/25/2014 | <b>CBL:</b><br>038 F006001 |
| 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716   |   |                                 |  |                            |
| <b>Proposed Use:</b><br>Business Offices  | <b>Proposed Project Description:</b><br>Renovate 3rd floor mens toilet; Add an ADA urinal and toilet. Partition at existing ADA toilet. New paint, etc. |                                 |  |                            |
| <b>Dept:</b> Historic <b>Status:</b> Approved w/Conditions <b>Reviewer:</b> Robert Wiener <b>Approval Date:</b> 04/30/2014<br><b>Note:</b> <span style="float: right;"><b>Ok to Issue:</b> <input checked="" type="checkbox"/></span><br><b>Conditions:</b><br>1) No exterior alterations are approved with this permit. If any exterior alterations are added to the scope of work, they must be reviewed and approved by HP staff prior to construction.  |   |                                 |  |                            |
| <hr/> <b>Dept:</b> Zoning <b>Status:</b> Approved w/Conditions <b>Reviewer:</b> Tammy Munson <b>Approval Date:</b> 04/28/2014<br><b>Note:</b> <span style="float: right;"><b>Ok to Issue:</b> <input checked="" type="checkbox"/></span><br><b>Conditions:</b><br>1) Separate permits shall be required for any new signage.<br>2) This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work.<br>3) ANY exterior work requires a separate review and approval thru Historic Preservation. This property is located within an Historic District. |   |                                 |  |                            |