City of Portland Maine, Fire Department Requirements May 12, 2016

Project:

MEMIC, 245 Commercial Street, Portland Maine

4th Floor Tenant Improvement to 3983 square feet of existing tenant space

Applicant

MEMIC, 261 Commercial Street, Portland Maine, 04101 Tenant Contact: Catherine Lamson, Senior Vice President, Chief Administrative Officer (207) 791 3304

Architect:

Josef Chalat, Architect 327 Ocean House Road, Cape Elizabeth, Maine 04107 Phone: (207) 318-3234, Email: azimuth@maine.rr.com

Proposed Use of Structure (unchanged from existing)

IBC Business Occupancy B, Section 305, NFPA Chapter 39, Existing Business Occupancy

Area of Work

4th floor: 3983 sf

Fire Protection of Structure:

The existing building appears to be fully sprinklered. The existing sprinkler system within the work area shall be modified on a design/build basis to accommodate revisions to the floor plan.