



REVISIONS

DRAWING NAME

MEMIC
RENOVATION TO THE
FOURTH FLOOR OFFICES
245 COMMERCIAL ST. PORTLAND, MAINE 04101

/SHEET

**FOURTH FLOOR
LIFE SAFETY PLAN**

DATE
26 MAY 2017

/SCALE

DRAWN
CAT

JOB NO.
170515

/SHEET

LS-1
COPYRIGHT
REPRODUCTION OR REV. OF THIS
DOCUMENT WITHOUT WRITTEN
PERMISSION FROM GRANT HAYS
ASSOCIATES IS PROHIBITED.

ISSUED FOR PERMIT ONLY



GENERAL NOTE:
ALL FIRE ALARM DEVICES SHALL BE CONNECTED TO EXISTING SYSTEM.

FOURTH FLOOR PARTIAL FLOOR PLAN
SCALE: 1/4" = 1'-0"

SYMBOL LEGEND

- SELF CONTAINED EMERGENCY LIGHT W/2 (5W) HEADS DUAL-LITE LZ SERIES MODEL L22DI, 10 WATTS CAPACITY FOR 90 MINUTES, COLOR BY ARCHITECT
- EXIT LIGHT FIXTURE, UNSWITCHED, DUAL-LITE LX-U-R-W-E OR APPROVED EQUAL
- EXIT/ EMERGENCY LIGHT COMBO, DUAL-LITE No EVCU-R-D4-1 OR APPROVED EQUAL COLOR BY ARCHITECT
- FIRE ALARM AUDIO/VISUAL, MOUNT 6'-8" AFF, NUMBER DENOTES CANDELA RATING. "MH" DENOTES MINHORN, "CL" DENOTES CEILING MOUNTED. NO DESIGNATION EQUALS 15cd
- FIRE ALARM PULL STATION, MOUNT 48" AFF
- FIRE ALARM VISUAL STROBE ONLY, FLUSH MOUNT 6'-8" AFF, NUMBER DENOTES CANDELA RATINGS. "CL" DENOTES CEILING MOUNTED
- SMOKE DETECTOR, PHOTOELECTRIC TYPE, SYSTEM CONNECTED.
- SMOKE DETECTOR, PHOTOELECTRIC TYPE, SYSTEM CONNECTED. "ER" DENOTES ELEV RECALL