



REVISIONS

DRAWING NAME

MEMIC
RENOVATION TO THE
FOURTH FLOOR OFFICES
245 COMMERCIAL ST. PORTLAND, MAINE 04101

SHEET

**FOURTH FLOOR
MECHANICAL
PIPING**

DATE
26 MAY 2017
SCALE
AS NOTED
DRAWN
MEB
JOB NO.
170515

SHEET
M-2
COPYRIGHT
REPRODUCTION OR REVISE OF THE
DOCUMENT WITHOUT WRITTEN
PERMISSION FROM GRANT HAY



BRANCH PIPES RUNNING PARALLEL TO BEAMS SHALL BE TUCKED UP BETWEEN BEAMS, TYPICAL.

CONCEAL PIPING ABOVE CEILING OR IN SOFFITS WHERE POSSIBLE, TYPICAL.

BRANCH PIPES RUNNING PARALLEL TO BEAMS SHALL BE TUCKED UP BETWEEN BEAMS, TYPICAL.

BRANCH PIPES RUNNING PERPENDICULAR TO BEAMS SHALL BE ROUTED ALONG BRICK WALLS, TUCKED UP TIGHT TO BEAMS, TYPICAL.

BRANCH PIPES RUNNING PARALLEL TO BEAMS SHALL BE TUCKED UP BETWEEN BEAMS, TYPICAL.

REFER TO VRF DETAILS/SCHEMATICS FOR PIPE LAYOUT AND SIZING

BRANCH CIRCUIT BOXES SHALL BE CONCEALED ABOVE CEILING, TYPICAL.

CONCEAL PIPING ABOVE CEILING OR IN SOFFITS WHERE POSSIBLE, TYPICAL.

REF. PIPES FROM ACCU-1 ON ROOF FIELD LOCATE ACCU-1. COORDINATE WITH OWNER AND PROVIDE REQUIRED EQUIPMENT CURB

FOURTH FLOOR PARTIAL FLOOR PLAN
SCALE: 1/4" = 1'-0"



ISSUED FOR PERMIT ONLY