

10/15/02 - punch list find ① provide returns
on lockers on stairs ② open risers must
be no more than 4" AL

10/22/02 - Corrected above issues - stairs OK now -
Cafe not ready. work in retail area
complete. AM

11/5/02 OK for CGO. AL

02-1050

038-F008



Certificate of Occupancy

468 Fore St

CBL 038 F008001

LOCATION

Issued to Dictar Associates II/Foss Welding & Fabrication

Date of Issue 11/05/2002

This is to certify that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. 02-1050, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

Basement Level

APPROVED OCCUPANCY

Cafe'
Use Group: B

Limiting Conditions:
None

This certificate supersedes
certificate issued

Approved:

11/5/02
(Date)

Inspector

Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

11/6/02
PWA
CLM